



This certificate is not valid if the serial number has been defaced or altered

40159943

EICR18_3C

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR (*Where applicable)	DETAILS OF THE CLIENT	DETAILS OF THE INSTALLATION
Registration No: 609526000 Branch No*: 000	Contractor Reference Number (CRN): N/A	Occupier: N/A
Trading Title: Andrew D'auria Solutions Limited T/A AD Gas	Name: Pobl	UPRN: N/A
Address: 197 Neath Road, Landore, Swansea, West Glamorgan	Address: POBL House, Pheonix Way, Swansea Enterprise Park, SWANSEA	Address: Swansea University, Cefn Bryn, Singleton Park, Swansea
Postcode: SA1 2JT Tel No: 01792701074	Postcode: SA7 9EQ Tel No: 01792488056	Postcode: SA2 8PS Tel No: 01792488056

PART 2 : PURPOSE OF THE REPORT

Purpose for which this report is required:
For safety due to change of residence & 5 year periodic inspection date.

Date(s) when inspection and testing was carried out: (08/09/2025) Records available (651.1): (X) Previous inspection report available (651.1): (X) Previous report date: (N/A)

PART 3 : SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety): The installation is now satisfactory for continued use

Description of premises Dwelling: (✓) Commercial: (✓) Industrial: (N/A) Other (include brief description): (N/A)

Estimated age of electrical installation: (25) years Evidence of additions or alterations: (✓) if Yes, estimated age (10) years Overall assessment of the installation for continued use: Satisfactory/Unsatisfactory** (delete as appropriate)

**An unsatisfactory assessment indicates that dangerous (Code C1) and/or potentially dangerous (Code C2) conditions have been identified (listed in PART 5 of this report) and it is recommended that these are acted upon as a matter of urgency.

PART 4 : DECLARATION

INSPECTION AND TESTING

I/We, being the person responsible for the inspection and testing of the electrical installation (as indicated by my/our signature below), particulars of which are described in PART 6, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations (PART 5) and the attached Schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in PART 6 of this report.

Name (capitals) on behalf of the contractor identified in PART 1: GARETH PRITCHARD Signature: [Signature] Date: 08/09/2025

I/We further RECOMMEND, subject to the necessary remedial action being taken, that the installation is inspected and tested by: 08/09/2030 (date)

Give reason for recommendation: The installation is now satisfactory for continued use

The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.

REVIEWED BY THE REGISTERED QUALIFIED SUPERVISOR FOR THE CONTRACTOR

Name (capitals) on behalf of the contractor identified in PART 1: PETER ROBERTS Signature: [Signature] Date: 11/09/2025

Original (to the person ordering the work)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART 9 : SCHEDULE OF ITEMS INSPECTED (enter ✓, N/A or Classification Code C1, C2, C3 or FI, as applicable)

1.0 Intake equipment (visual inspection only)

An outcome against an item in section 1.1, other than access to live parts, should not be used to determine the overall assessment of the installation. Where inadequacies are identified, a cross should be put against the appropriate item and a comment made in Part 5 of this report.

- 1.1 Distributor / supplier intake equipment
 - Service cable (.....✓)
 - Service head (.....✓)
 - Earthing arrangement (.....✓)
 - Meter tails (.....✓)
 - Metering equipment (.....✓)
 - Isolator, where present (.....✓)

Where inadequacies in the intake equipment are encountered, which may result in a dangerous or potentially dangerous situation, the person ordering the work and / or dutyholder must be informed. It is strongly recommended that the person ordering the work informs the appropriate authority.

- 1.2 Consumer's isolator, where present (.....✓)
- 1.3 Consumer's meter tails (.....N/A)

2.0 Presence of adequate arrangements for parallel or switched alternative sources

- 2.1 Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6) (.....N/A)
- 2.2 Adequate arrangements where a generating set operates in parallel with the public supply (551.7) (.....N/A)

3.0 Methods of protection

- 3.1 Automatic disconnection of supply (ADS)
 - Main earthing / bonding arrangement (411.3; Chap. 54) (.....✓)
 - Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2), or presence of installation earth electrode arrangement (542.1.2.3) (.....✓)
 - Adequacy of earthing conductor size (542.3; 543.1.1) (.....✓)
 - Adequacy of earthing conductor connections (542.3.2) (.....✓)
 - Accessibility of earthing conductor connections (543.3.2) (.....✓)
 - Adequacy of main protective bonding conductor sizes (544.1.1) (.....✓)
 - Adequacy and location of main protective bonding conductor connections (544.1.2) (.....✓)

- Accessibility of all protective bonding connections (543.3.2) (.....✓)
- Provision of earthing / bonding labels at all appropriate locations (514.13.1) (.....✓)
- 3.2 FELV - requirements satisfied (411.7) (.....N/A)
- 3.3 Other methods of protection

Where any of the methods listed below are employed, details should be provided on separate sheets

 - Non-conducting location (418.1) (.....N/A)
 - Earth-free local equipotential bonding (418.2) (.....N/A)
 - Electrical separation (413; 418.3) (.....N/A)
 - Double insulation (412) (.....✓)
 - Reinforced insulation (412) (.....✓)
 - Provisions where automatic disconnection of supply is not feasible (419) (.....N/A)

4.0 Distribution equipment, including consumer units and distribution boards

- 4.1 Adequacy of working space / accessibility to equipment (132.12; 513.1) (.....✓)
- 4.2 Security of fixing (134.1.1) (.....✓)
- 4.3 Condition of insulation of live parts (416.1) (.....✓)
- 4.4 Adequacy security of barriers or enclosures (416.2.3) (.....✓)
- 4.5 Condition of enclosure(s) in terms of IP rating, etc. (416.2) (.....✓)
- 4.6 Condition of enclosure(s) in terms of fire rating, etc. (421.1.201; 421.1.6; 526.5) (.....✓)
- 4.7 Enclosure not damaged / deteriorated so as to impair safety (651.2) (.....✓)
- 4.8 Presence and effectiveness of obstacles (417.2) (.....✓)
- 4.9 Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2) (.....✓)
- 4.10 Operation of main switch(es) (functional check) (643.10) (.....✓)
- 4.11 Manual operation of circuit-breakers, RCDs and AFDDs to prove functionality (643.10) (.....✓)
- 4.12 Confirmation that integral test button / switch causes RCD(s) to trip when operated (functional check) (643.10) (.....✓)
- 4.13 RCD(s) provided for fault protection - includes RCBOs (411.4.204; 411.4.5; 411.5.2; 531.2) (.....N/A)
- 4.14 RCD(s) provided for additional protection / requirements, where required - includes RCBOs (411.3.3; 415.1) (.....✓)
- 4.15 Presence of RCD six-monthly test notice, where required (514.12.2) (.....C3)

- 4.16 Confirmation that integral test button / switch, where present, causes AFDD to trip when operated (643.10) (.....C3)
- 4.17 Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1) (.....✓)
- 4.18 Presence of alternative supply warning notice at or near equipment, where required (514.15) (.....N/A)
- 4.19 Presence of next inspection recommendation label, where required (514.12.1) (.....✓)
- 4.20 Presence of other required labelling (please specify) (514) (.....✓)
- 4.21 Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (432; 433; 434) (.....✓)
- 4.22 Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3) (.....✓)
- 4.23 Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11) (.....✓)
- 4.24 Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1) (.....✓)
- 4.25 Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1) (.....✓)

5.0 Distribution circuits

- 5.1 Identification of conductors (514.3) (.....✓)
- 5.2 Cables correctly supported throughout their run (521.10.202; 522.8.5) (.....✓)
- 5.3 Condition of insulation of live parts (416.1) (.....✓)
- 5.4 Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1) (.....✓)
- 5.5 Suitability of containment systems for continued use (including flexible conduit) (522) (.....✓)
- 5.6 Cables correctly terminated in enclosures (526) (.....✓)
- 5.7 Examination of cables for signs of unacceptable thermal or mechanical damage / deterioration (421.1; 522.6) (.....✓)
- 5.8 Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (523) (.....✓)



This certificate is not valid if the serial number has been defaced or altered

40159943

EICR18_3C

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART 9 : SCHEDULE OF ITEMS INSPECTED (enter ✓, N/A or Classification Code C1, C2, C3 or FI, as applicable)

5.9	Adequacy of protective devices; type and rated current for fault protection (411.3)	(✓)	6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	(LIM)	6.14	Provision of fire barriers, sealing arrangements and protection against thermal effects (527)	(LIM)
5.10	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	(✓)	6.3	Condition of insulation of live parts (416.1)	(✓)	6.15	Band II cables segregated / separated from Band I cables (528.1)	(LIM)
5.11	Coordination between conductors and overload protective devices (433.1; 533.2.1)	(✓)	6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	(✓)	6.16	Cables segregated / separated from non-electrical services (528.3)	(LIM)
5.12	Cable installation methods / practices with regard to the type and nature of installation and external influences (522)	(✓)	6.5	Suitability of containment systems for continued use (including flexible conduit) (522)	(✓)	6.17	Termination of cables at enclosures - identify / record numbers and locations of items inspected (526) -	(✓)
5.13	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	(N/A)	6.6	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation (523)	(✓)	6.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2)	(✓)
5.14	Cables concealed under floors, above ceilings, in walls / partitions, adequately protected against damage (522.6.201; 522.6.202; 522.6.203; 522.6.204) -	(✓)	6.7	Adequacy of protective devices; type and rated current for fault protection (411.3)	(✓)	6.19	Suitability of accessories for external influences (512.2)	(✓)
	▪ Installed in prescribed zones (see Section D. <i>Extent and limitations</i>) (522.6.202)	(LIM)	6.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	(✓)	6.20	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	(✓)
	▪ Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D) (522.6.201; 522.6.204)	(✓)	6.9	Co-ordination between conductors and overload protective devices (433.1; 533.2.1)	(✓)			
5.15	Provision of fire barriers, sealing arrangements and protection against thermal effects (527)	(✓)	6.10	Wiring system(s) appropriate for the type and nature of the installation and external influences (522)	(✓)	7.0 Isolation and switching		
5.16	Band II cables segregated / separated from Band I cables (528.1)	(LIM)	6.11	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	(✓)	7.1	Isolators -	
5.17	Cables segregated / separated from non-electrical services (528.3)	(LIM)	6.12	Cables concealed under floors, above ceilings, in walls / partitions, adequately protected against damage (522.6.201; 522.6.202; 522.6.203; 522.6.204) -	(✓)		▪ Presence and condition of appropriate devices (462; 537.2)	(✓)
5.18	Condition of circuit accessories (651.2)	(✓)		▪ Installed in prescribed zones (see Section D. <i>Extent and limitations</i>) (522.6.202)	(LIM)		▪ Acceptable location - state if local or remote from equipment in question (462; 537.2.7)	(✓)
5.19	Suitability of circuit accessories for external influences (512.2)	(✓)		▪ Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D) (522.6.201; 522.6.204)	(✓)		▪ Capable of being secured in the OFF position (462.3)	(✓)
5.20	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	(✓)	6.13	Provision of additional protection by RCD having rated residual operating current not exceeding 30 mA -	(✓)		▪ Correct operation verified (643.10)	(✓)
5.21	Adequacy of connections, including cpcs, within accessories and to fixed and stationary equipment - identify / record numbers and locations of items inspected (526)	(✓)		▪ *For all socket-outlets of rating 32 A or less (411.3.3)	(✓)		▪ Clearly identified by position and / or durable marking (537.2.7)	(✓)
5.22	Presence, operation and correct location of appropriate devices for isolation and switching (Chap. 46; 537)	(✓)		<i>Additional protection by RCD may not have been provided as a noted exception in certain non-domestic installations covered by indent (ii) of Regulation 411.3.3.</i>			▪ Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	(N/A)
5.23	General condition of wiring system (651.2)	(✓)		▪ *For the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	(✓)			
5.24	Temperature rating of cable insulation (522.11; Table 52.1)	(✓)		▪ *For cables concealed in walls at a depth of less than 50 mm (522.6.202)	(N/A)			
6.0 Final circuits								
6.1	Identification of conductors (514.3)	(✓)						

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

40159943

EICR18_3C

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART 9 : SCHEDULE OF ITEMS INSPECTED (enter ✓, N/A or Classification Code C1, C2, C3 or FI, as applicable)

7.2	Switching off for mechanical maintenance –		8.5	Security of fixing (134.1.1)	(✓)	▪ Low voltage (e.g. 230 volt) socket-outlets sited at least 2.5 m from zone 1 (701.512.3)	(N/A)
	▪ Presence and condition of appropriate devices (464.1; 537.3.2)	(✓)	8.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: list number and location of luminaires inspected (separate page) (527.2)	(LIM)	▪ Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	(✓)
	▪ Capable of being secured in the OFF position where not under continuous supervision (464.2)	(✓)				▪ Suitability of accessories and controlgear etc. for a particular zone (701.512.3)	(✓)
	▪ Correct operation verified (643.10)	(✓)	8.7	Recessed luminaires (downlighters) –		▪ Suitability of current-using equipment for particular position within the location (701.55)	(✓)
	▪ Clearly identified by position and / or durable marking (537.3.2.4)	(✓)		▪ Correct type of lamps fitted (559.3.1)	(✓)	9.2	Other special installations or locations –
7.3	Emergency switching off –			▪ Installed to minimise build-up of heat by use of “fire rated” fittings, insulation displacement box or similar (421.1.2)	(✓)	N/A	(N/A)
	▪ Presence and condition of appropriate devices (465; 537.3.3; 537.4)	(✓)		▪ No signs of overheating to surrounding building fabric (559.4.1)	(✓)	(.....)
	▪ Readily accessible for operation where danger might occur (537.3.3.6)	(✓)		▪ No signs of overheating to conductors / terminations (526.1)	(✓)	(.....)
	▪ Correct operation verified (643.10)	(✓)	9.0	Special locations and installations		(.....)
	▪ Clearly identified by position and / or durable marking (537.3.3.5; 537.3.3.6; 537.4.3; 537.4.4)	(✓)		Where special installations or locations relating to a particular Section of Part 7, an additional Inspection Schedule(s) should be provided on separate pages.		(.....)
7.4	Functional switching –		9.1	Location(s) containing a bath or shower –		(.....)
	▪ Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	(✓)		▪ Additional protection by RCD having rated residual operating current not exceeding 30 mA for all low voltage (LV) circuits serving the location or passing through zones 1 and / or 2 of the location (701.411.3.3)	(✓)	10.0	Prosumer's low voltage installation
	▪ Correct operation verified (643.10)	(✓)		▪ Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)	(✓)	(N/A)	
8.0	Current-using equipment (permanently connected)			▪ Shaver supply units complying with BS EN 61558-2-5 formerly BS 3535 (701.512.3)	(N/A)	Where elements of a prosuming installation falling within the scope of Chapter 82 are covered by the report, additional schedules detailing the associated inspection and testing should be provided on separate pages.	
8.1	Condition of equipment in terms of IP rating, etc. (416.2; 422.3; 422.4; 522.4)	(✓)		▪ Presence of supplementary bonding conductors, unless not required by BS 7671: 2018 (701.415.2)	(N/A)	Schedule of Items Inspected by	
8.2	Equipment does not constitute a fire hazard (421)	(✓)				Name (capitals): GARETH PRITCHARD	
8.3	Enclosure not damaged / deteriorated so as to impair safety (134.1.1; 416.2)	(✓)				Signature: Date: 08/09/2025	
8.4	Suitability for the environment and external influences (512.2)	(✓)					

PART 10 : SCHEDULES AND ADDITIONAL PAGES (the pages identified are an essential part of this report (see Regulation 653.2))

Schedule of Inspections	Schedule of Circuit Details and Test Results for the installation	Additional pages, including data sheets for additional sources	Special installations or locations (indicated in item 9.2 above)	Schedules relating to Prosumer's installations (indicated in item 10 above)	Continuation sheets
Page No(s): (4, 5 & 6)	Page No(s): (7 & 8)	Page No(s): (57)	Page No(s): (None)	Page No(s): (None)	Page No(s): (58-82)

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

40159943

EICR18.3C

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART 11A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part 11B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to PART 11B)	Reference Method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Zs* (Ω)	BS (EN)	Type	Rating (A)	Operating current, I _{Δn} (mA)
0	Main Switch	N/A	N/A	N/A	N/A	N/A	N/A	60947-3	3	125	N/A	N/A	N/A	N/A	N/A	N/A
1L1	Lighting rooms 914-920	A	B	13	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
1L2	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1L3	Lighting rooms 901-907	A	B	15	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
2L1	Lighting Hallway	A	B	13	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
2L2	Lighting rooms 908-909, 912-913	A	B	12	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
2L3	Lighting Showers North	A	B	6	1.5	1	0.4	61009	C	6	10	2.91	61009	A	6	30
3L1	Sockets Hallway North	A	B	2	2.5	1.5	0.4	61009	C	20	10	0.87	61009	A	20	30
3L2	Sockets Kitchen	A	B	8	2.5	1.5	0.4	61009	C	32	10	0.54	61009	A	32	30
3L3	Lighting Hallway South	A	B	19	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
4L1	Sockets 914-917	A	B	16	2.5	1.5	0.4	61009	C	32	10	0.54	61009	A	32	30
4L2	Sockets 908-909	A	B	8	2.5	1.5	0.4	61009	C	32	10	0.54	61009	A	32	30
4L3	Sockets 904-907	A	B	16	2.5	1.5	0.4	61009	B	32	10	1.08	61009	A	32	30
5L1	Sockets 918-920	A	B	16	2.5	1.5	0.4	61009	C	32	10	0.54	61009	A	32	30
5L2	Sockets 912-913	A	B	8	2.5	1.5	0.4	61009	C	32	10	0.54	61009	A	32	30
5L3	Sockets 901-903	A	B	16	2.5	1.5	0.4	61009	B	32	10	1.08	61009	A	32	30
6L1	Cooker	A	B	2	6	2.5	0.4	61009	B	32	10	1.37	N/A	N/A	N/A	N/A
6L2	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: **DB09**
 Location of DB: **9th Floor Cupboard**
 Z_{db} : **0.31** (Ω) I_{pf} at DB†: **2.4** (kA)
 Confirmation of supply polarity: (✓) Phase sequence confirmed†: (✓)
 SPD Details** Types: T1 (N/A) T2 (N/A) T3 (N/A) N/A (N/A)
 Status indicator checked (where functionality indicator is present): (N/A)

**SPD Type.
 Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.
 Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART 11B), (See Section 534 for further details).
 Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: **Main DB - 7L1, 7L2, 7L3**
Overcurrent protective device for the distribution circuit
 BS (EN): (60947-2) Type: (N/A) Nominal voltage: (.415...) V Rating: (.400...) A No. of phases: (3)
Associated RCD (if any)
 BS (EN): (N/A) RCD Type: (N/A) $I_{Δn}$: (N/A) mA No. of poles: (N/A) Operating time: (N/A) ms



This certificate is not valid if the serial number has been defaced or altered

40159943 EICR18_3C

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART 11B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part 11A)

Circuit number	Continuity (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD		AFDD**		Comments and additional information, where required
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live	Live / Earth	Test voltage DC			Operating time*	Test button	AFDD test button		
	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂	(MΩ)	(MΩ)	(V)			(ms)	(✓)	(✓)		
0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	✓	N/A	N/A	N/A	N/A	N/A	
1L1	N/A	N/A	N/A	1.54	N/A	LIM	>200	500	✓	1.72	33	✓	N/A	N/A	
1L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
1L3	N/A	N/A	N/A	1.22	N/A	LIM	>200	500	✓	1.55	32	✓	N/A	N/A	
2L1	N/A	N/A	N/A	1.33	N/A	LIM	>200	500	✓	1.48	32	✓	N/A	N/A	
2L2	N/A	N/A	N/A	1.60	N/A	LIM	>200	500	✓	1.91	32	✓	N/A	N/A	
2L3	N/A	N/A	N/A	1.18	N/A	LIM	>200	500	✓	1.49	27	✓	N/A	N/A	
3L1	N/A	N/A	N/A	0.25	N/A	N/A	>200	500	✓	0.60	29	✓	N/A	N/A	
3L2	0.51	0.50	0.82	0.32	N/A	N/A	>200	500	✓	0.51	28	✓	N/A	N/A	
3L3	N/A	N/A	N/A	1.47	N/A	LIM	>200	500	✓	1.78	33	✓	N/A	N/A	
4L1	0.50	0.50	0.84	0.35	N/A	N/A	>200	500	✓	0.49	27	✓	N/A	N/A	
4L2	0.44	0.45	0.72	0.31	N/A	N/A	>200	500	✓	0.47	29	✓	N/A	N/A	
4L3	0.52	0.52	0.84	0.36	N/A	N/A	>200	500	✓	0.52	31	✓	N/A	N/A	
5L1	0.42	0.42	0.70	0.29	N/A	N/A	>200	500	✓	0.55	28	✓	N/A	N/A	
5L2	0.33	0.33	0.55	0.25	N/A	N/A	>200	500	✓	0.49	28	✓	N/A	N/A	
5L3	0.37	0.36	0.61	0.24	N/A	N/A	>200	500	✓	0.53	34	✓	N/A	N/A	
6L1	N/A	N/A	N/A	0.16	N/A	N/A	>200	500	✓	0.28	34	✓	N/A	N/A	
6L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Circuits/equipment vulnerable to damage when testing (where applicable): All vulnerable equipment has been disconnected for testing

TESTED BY Name (capitals): GARETH PRITCHARD Position: Electrician Signature: [Signature] Date: 08/09/2025

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)					
Multi-function: 28K-1011	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{Δn})

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	--------------------

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

40159943

ISN18.3c

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to PART B)	Reference Method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Z _s * (Ω)	BS (EN)	Type	Rating (A)	Operating current, I _{Δn} (mA)
0	Main Switch	N/A	N/A	N/A	N/A	N/A	N/A	60947-3	3	100	N/A	N/A	N/A	N/A	N/A	N/A
1L1	Lighting rooms 815-820	A	B	13	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
1L2	Lighting rooms 807-809, 812-814	A	B	12	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
1L3	Lighting rooms 801-806	A	B	13	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
2L1	Lighting Hallway	A	B	14	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
2L2	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L3	Lighting Hallway North	A	B	6	1.5	1	0.4	61009	C	6	10	2.91	61009	A	6	30
3L1	Sockets Hallway North	A	B	2	2.5	1.5	0.4	61009	C	20	10	0.87	61009	A	20	30
3L2	Sockets Kitchen	A	B	8	2.5	1.5	0.4	61009	C	32	10	0.54	61009	A	32	30
3L3	Lighting Hallway South	A	B	18	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
4L1	Sockets 815-817	A	B	12	2.5	1.5	0.4	61009	B	32	10	1.08	61009	A	32	30
4L2	Sockets 807-809	A	B	12	2.5	1.5	0.4	61009	B	32	10	1.08	61009	A	32	30
4L3	Sockets 804-806	A	B	12	2.5	1.5	0.4	61009	B	32	10	1.08	61009	A	32	30
5L1	Sockets 818-820	A	B	16	2.5	1.5	0.4	61009	C	32	10	0.54	61009	A	32	30
5L2	Sockets 812-814	A	B	12	2.5	1.5	0.4	61009	C	32	10	0.54	61009	A	32	30
5L3	Sockets 801-803	A	B	16	2.5	1.5	0.4	61009	B	32	10	1.08	61009	A	32	30
6L1	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L2	Cooker	A	B	2	6	2.5	0.4	60898	C	32	10	0.54	N/A	N/A	N/A	N/A

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: DB08

Location of DB: 8th Floor Cupboard

Z_{db}: 0.28 (Ω) I_{pf} at DB†: 2.1 (kA)

Confirmation of supply polarity: (✓) Phase sequence confirmed†: (✓)

SPD Details** Types: T1 (N/A) T2 (N/A) T3 (N/A) N/A (N/A)

Status indicator checked (where functionality indicator is present): (N/A)

**SPD Type.

Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.

Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B), (See Section 534 for further details).

Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: Main DB - 7L1, 7L2, 7L3

Overcurrent protective device for the distribution circuit

BS (EN): (60947-2) Type: (N/A) Nominal voltage: (.415...) V Rating: (.400...) A No. of phases: (3)

Associated RCD (if any)

BS (EN): (N/A) RCD Type: (N/A) I_{Δn}: (N/A) mA No. of poles: (N/A) Operating time: (N/A) ms

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

40159943

ISN18.3c


CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD		AFDD**	Comments and additional information, where required
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live	Live / Earth	Test voltage DC			Operating time*	Test button	AFDD test button	
	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂	(MΩ)	(MΩ)	(V)			(ms)	(✓)	(✓)	
0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	✓	N/A	N/A	N/A	N/A	N/A
1L1	N/A	N/A	N/A	1.54	N/A	LIM	>200	500	✓	1.83	33	✓	N/A	N/A
1L2	N/A	N/A	N/A	1.54	N/A	LIM	>200	500	✓	1.83	32	✓	N/A	N/A
1L3	N/A	N/A	N/A	1.54	N/A	LIM	>200	500	✓	1.83	32	✓	N/A	N/A
2L1	N/A	N/A	N/A	1.54	N/A	LIM	>200	500	✓	1.83	33	✓	N/A	N/A
2L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L3	N/A	N/A	N/A	1.54	N/A	LIM	>200	500	✓	1.83	27	✓	N/A	N/A
3L1	N/A	N/A	N/A	0.35	N/A	N/A	>200	500	✓	0.59	29	✓	N/A	N/A
3L2	0.29	0.29	0.48	0.20	N/A	N/A	>200	500	✓	0.42	28	✓	N/A	N/A
3L3	N/A	N/A	N/A	1.54	N/A	LIM	>200	500	✓	1.83	29	✓	N/A	N/A
4L1	0.42	0.43	0.72	0.30	N/A	N/A	>200	500	✓	0.53	32	✓	N/A	N/A
4L2	0.51	0.50	0.84	0.37	N/A	N/A	>200	500	✓	0.65	33	✓	N/A	N/A
4L3	0.39	0.41	0.65	0.27	N/A	N/A	92	500	✓	0.50	32	✓	N/A	N/A
5L1	0.44	0.45	0.73	0.29	N/A	N/A	>200	500	✓	0.48	28	✓	N/A	N/A
5L2	0.37	0.37	0.61	0.24	N/A	N/A	>200	500	✓	0.47	28	✓	N/A	N/A
5L3	0.29	0.30	0.49	0.21	N/A	N/A	>200	500	✓	0.44	35	✓	N/A	N/A
6L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L2	N/A	N/A	N/A	0.13	N/A	N/A	>200	500	✓	0.29	26	N/A	N/A	N/A

Circuits/equipment vulnerable to damage when testing (where applicable): All vulnerable equipment has been disconnected for testing

TESTED BY Name (capitals): GARETH PRITCHARD Position: Electrician Signature:  Date: 08/09/2025

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)					
Multi-function: 28K-1011	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{Δn})

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	--------------------

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

40159943

ISN18.3c

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to PART B)	Reference Method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Z _s * (Ω)	BS (EN)	Type	Rating (A)	Operating current, I _{Δn} (mA)
0	Main Switch	N/A	N/A	N/A	N/A	N/A	N/A	60947-3	3	100	N/A	N/A	N/A	N/A	N/A	N/A
1L1	Lighting rooms 714-720	A	B	16	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
1L2	Lighting rooms 712-713	A	B	4	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
1L3	Lighting rooms 701-707	A	B	13	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
2L1	Lighting Hallway	A	B	13	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
2L2	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L3	Lighting Shower North	A	B	5	1.5	1	0.4	61009	C	6	10	2.91	61009	A	6	30
3L1	Sockets Kitchen	A	B	8	2.5	1.5	0.4	61009	C	32	10	0.54	61009	A	32	30
3L2	Sockets Hallway North	A	B	2	2.5	1.5	0.4	61009	C	20	10	0.87	61009	A	20	30
3L3	Lighting Hallway South	A	B	19	1.5	1	0.4	61009	B	6	10	5.82	61009	A	6	30
4L1	Sockets 708-709	A	B	8	2.5	1.5	0.4	61009	C	32	10	0.54	61009	A	32	30
4L2	Sockets 714-717	A	B	16	2.5	1.5	0.4	61009	C	32	10	0.54	61009	A	32	30
4L3	Sockets 704-707	A	B	16	2.5	1.5	0.4	61009	B	32	10	1.08	61009	A	32	30
5L1	Sockets 718-720	A	B	16	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
5L2	Sockets 712-713	A	B	8	2.5	1.5	0.4	61009	C	32	10	0.54	61009	A	32	30
5L3	Sockets 701-793	A	B	16	2.5	1.5	0.4	61009	B	32	10	1.08	61009	A	32	30
6L1	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L2	Kitchen Water Heater	A	B	1	2.5	1.5	0.4	60898	B	20	10	1.74	N/A	N/A	N/A	N/A

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: DB07
 Location of DB: 7th Floor Cupboard
 Z_{db} : 0.26 (Ω) I_{pf} at DB†: 1.8 (kA)
 Confirmation of supply polarity: (✓) Phase sequence confirmed†: (✓)
 SPD Details** Types: T1 (N/A) T2 (N/A) T3 (N/A) N/A (N/A)
 Status indicator checked (where functionality indicator is present): (N/A)

**SPD Type.
 Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.
 Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B), (See Section 534 for further details).
 Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: Main DB - 7L1, 7L2, 7L3
Overcurrent protective device for the distribution circuit
 BS (EN): (60947-2) Type: (N/A) Nominal voltage: (.415...) V Rating: (.400...) A No. of phases: (3)
Associated RCD (if any)
 BS (EN): (N/A) RCD Type: (N/A) $I_{Δn}$: (N/A) mA No. of poles: (N/A) Operating time: (N/A) ms

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

40159943

ISN18.3c

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD		AFDD**	Comments and additional information, where required
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live	Live / Earth	Test voltage DC			Operating time*	Test button	AFDD test button	
	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂	(MΩ)	(MΩ)	(V)			(ms)	(✓)	(✓)	
0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	✓	N/A	N/A	N/A	N/A	N/A
1L1	N/A	N/A	N/A	1.62	N/A	LIM	>200	500	✓	1.83	19	✓	N/A	N/A
1L2	N/A	N/A	N/A	1.32	N/A	LIM	>200	500	✓	1.57	19	✓	N/A	N/A
1L3	N/A	N/A	N/A	1.44	N/A	LIM	>200	500	✓	1.67	19	✓	N/A	N/A
2L1	N/A	N/A	N/A	1.27	N/A	LIM	>200	500	✓	1.49	19	✓	N/A	N/A
2L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L3	N/A	N/A	N/A	1.12	N/A	LIM	>200	500	✓	1.37	19	✓	N/A	N/A
3L1	0.37	0.37	0.61	0.24	N/A	N/A	>200	500	✓	0.45	23.6	✓	N/A	N/A
3L2	N/A	N/A	N/A	0.31	N/A	N/A	>200	500	✓	0.53	23.6	✓	N/A	N/A
3L3	N/A	N/A	N/A	1.21	N/A	LIM	>200	500	✓	1.54	19	✓	N/A	N/A
4L1	0.42	0.42	0.70	0.28	N/A	N/A	>200	500	✓	0.47	23.6	✓	N/A	N/A
4L2	0.49	0.48	0.82	0.32	N/A	N/A	>200	500	✓	0.53	23.6	✓	N/A	N/A
4L3	0.39	0.39	0.68	0.26	N/A	N/A	>200	500	✓	0.49	23.6	✓	N/A	N/A
5L1	0.42	0.42	0.74	0.31	N/A	N/A	>200	500	✓	0.54	23.6	✓	N/A	N/A
5L2	0.29	0.30	0.50	0.22	N/A	N/A	>200	500	✓	0.48	23.6	✓	N/A	N/A
5L3	0.51	0.52	0.82	0.32	N/A	N/A	>200	500	✓	0.53	23.6	✓	N/A	N/A
6L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L2	N/A	N/A	N/A	0.35	N/A	N/A	>200	500	✓	0.59	28	✓	N/A	N/A

Circuits/equipment vulnerable to damage when testing (where applicable): All vulnerable equipment has been disconnected for testing

TESTED BY Name (capitals): GARETH PRITCHARD Position: Electrician Signature:  Date: 08/09/2025

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)					
Multi-function: 28K-1011	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{Δn})

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	--------------------

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

40159943

ISN18.3c

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to PART B)	Reference Method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Z _s * (Ω)	BS (EN)	Type	Rating (A)	Operating current, I _{Δn} (mA)
0	Main Switch	N/A	N/A	N/A	N/A	N/A	N/A	60947-3	3	100	N/A	N/A	N/A	N/A	N/A	N/A
1L1	Lighting rooms 615-620	A	B	13	1.5	1	0.4	61009	B	6	10	7.28	61009	A	6	30
1L2	Lighting rooms 614-612	A	B	6	1.5	1	0.4	61009	B	6	10	7.28	61009	A	6	30
1L3	Lighting rooms 601-606	A	B	13	1.5	1	0.4	61009	B	6	10	7.28	61009	A	6	30
2L1	Lighting Hallway	A	B	14	1.5	1	0.4	61009	B	6	10	7.28	61009	A	6	30
2L2	Kitchen Water Heater	A	B	1	2.5	1.5	0.4	61009	B	20	10	2.19	61009	A	20	30
2L3	Lighting Shower North	A	B	6	1.5	1	0.4	61009	C	6	10	3.64	61009	A	6	30
3L1	Sockets Hallway South	A	B	2	2.5	1.5	0.4	61009	B	20	10	2.19	61009	A	20	30
3L2	Sockets Hallway North	A	B	4	2.5	1.5	0.4	61009	B	20	10	2.19	61009	A	20	30
3L3	Lighting Hallway South	A	B	19	1.5	1	0.4	61009	B	6	10	7.28	61009	A	6	30
4L1	Sockets 615-617	A	B	12	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
4L2	Sockets 609-607	A	B	12	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
4L3	Sockets 604-606	A	B	12	2.5	1.5	0.4	61009	B	32	10	1.37	61009	A	32	30
5L1	Sockets 618-620	A	B	16	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
5L2	Sockets 612-614	A	B	18	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
5L3	Sockets 601-603	A	B	16	2.5	1.5	0.4	61009	B	32	10	1.37	61009	A	32	30
6L1	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L2	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: DB06
 Location of DB: 6th Floor Cupboard
 Z_{db} : 0.24 (Ω) I_{pf} at DB†: 2.2 (kA)
 Confirmation of supply polarity: (✓) Phase sequence confirmed†: (✓)
 SPD Details** Types: T1 (N/A) T2 (N/A) T3 (N/A) N/A (N/A)
 Status indicator checked (where functionality indicator is present): (N/A)

**SPD Type.
 Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.
 Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B), (See Section 534 for further details).
 Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: Main DB - 7L1, 7L2, 7L3
Overcurrent protective device for the distribution circuit
 BS (EN): (60947-2) Type: (N/A) Nominal voltage: (.415...) V Rating: (.400...) A No. of phases: (3)
Associated RCD (if any)
 BS (EN): (N/A) RCD Type: (N/A) $I_{Δn}$: (N/A) mA No. of poles: (N/A) Operating time: (N/A) ms

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

40159943

ISN18.3c

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD		AFDD**	Comments and additional information, where required
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live	Live / Earth	Test voltage DC			Operating time*	Test button	AFDD test button	
	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂	(MΩ)	(MΩ)	(V)			(ms)	(✓)	(✓)	
0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	✓	N/A	N/A	N/A	N/A	N/A
1L1	N/A	N/A	N/A	1.19	N/A	LIM	>200	500	✓	1.44	19	✓	N/A	N/A
1L2	N/A	N/A	N/A	1.42	N/A	LIM	>200	500	✓	1.68	31	✓	N/A	N/A
1L3	N/A	N/A	N/A	1.32	N/A	LIM	>200	500	✓	1.58	31	✓	N/A	N/A
2L1	N/A	N/A	N/A	1.27	N/A	LIM	178	500	✓	1.42	31	✓	N/A	N/A
2L2	N/A	N/A	N/A	0.27	N/A	LIM	>200	500	✓	0.49	33	✓	N/A	N/A
2L3	N/A	N/A	N/A	1.09	N/A	LIM	123	500	✓	1.32	31	✓	N/A	N/A
3L1	N/A	N/A	N/A	0.43	N/A	LIM	>200	500	✓	0.66	28	✓	N/A	N/A
3L2	N/A	N/A	N/A	0.32	N/A	LIM	>200	500	✓	0.58	33	✓	N/A	N/A
3L3	N/A	N/A	N/A	1.67	N/A	LIM	>200	500	✓	1.89	33	✓	N/A	N/A
4L1	0.32	0.32	0.53	0.21	N/A	LIM	>200	500	✓	0.46	33	✓	N/A	N/A
4L2	0.29	0.29	0.48	0.19	N/A	LIM	>200	500	✓	0.40	26	✓	N/A	N/A
4L3	0.27	0.28	0.45	0.18	N/A	LIM	>200	500	✓	0.43	33	✓	N/A	N/A
5L1	0.35	0.35	0.60	0.26	N/A	LIM	>200	500	✓	0.49	28	✓	N/A	N/A
5L2	0.19	0.20	0.31	0.12	N/A	LIM	>200	500	✓	0.38	27	✓	N/A	N/A
5L3	0.26	0.28	0.43	0.17	N/A	LIM	>200	500	✓	0.41	28	✓	N/A	N/A
6L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Circuits/equipment vulnerable to damage when testing (where applicable): All vulnerable equipment has been disconnected for testing

TESTED BY Name (capitals): GARETH PRITCHARD Position: Electrician Signature:  Date: 08/09/2025

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)					
Multi-function: 28K-1011	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{Δn})

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	--------------------

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

40159943

ISN18.3c

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to PART B)	Reference Method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Zs* (Ω)	BS (EN)	Type	Rating (A)	Operating current, I _{Δn} (mA)
0	Main Switch	N/A	N/A	N/A	N/A	N/A	N/A	60947-3	3	125	N/A	N/A	N/A	N/A	N/A	N/A
1L1	Lighting rooms 514-520	A	B	13	1.5	1	0.4	61009	B	6	10	7.28	61009	A	6	30
1L2	Lighting rooms 512-513	A	B	12	1.5	1	0.4	61009	B	6	10	7.28	61009	A	6	30
1L3	Lighting rooms 501-507	A	B	13	1.5	1	0.4	61009	B	6	10	7.28	61009	A	6	30
2L1	Lighting Hallway	A	B	14	1.5	1	0.4	61009	B	6	10	7.28	61009	A	6	30
2L2	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L3	Lighting Shower North	A	B	6	1.5	1	0.4	61009	C	6	10	3.64	61009	A	6	30
3L1	Sockets Hallway North	A	B	2	2.5	1.5	0.4	61009	C	20	10	1.09	61009	A	20	30
3L2	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L3	Lighting Hallway South	A	B	18	1.5	1	0.4	61009	B	6	10	7.28	61009	A	6	30
4L1	Sockets 514-517	A	B	12	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
4L2	Sockets 508-509	A	B	12	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
4L3	Sockets 503-507	A	B	12	2.5	1.5	0.4	61009	B	32	10	1.37	61009	A	32	30
5L1	Sockets 519-520	A	B	16	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
5L2	Sockets 512-513	A	B	12	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
5L3	Sockets 501-513	A	B	16	2.5	1.5	0.4	61009	B	32	10	1.37	61009	A	32	30
6L1	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L2	DB5A	A	B	1	16	10	5	60898	C	63	10	0.35	N/A	N/A	N/A	N/A

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: DB05
 Location of DB: 5th Floor Cupboard
 Z_{db} : 0.22 (Ω) I_{pf} at DB†: 1.9 (kA)
 Confirmation of supply polarity: (✓) Phase sequence confirmed†: (✓)
 SPD Details** Types: T1 (N/A) T2 (N/A) T3 (N/A) N/A (N/A)
 Status indicator checked (where functionality indicator is present): (N/A)

**SPD Type.
 Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.
 Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B), (See Section 534 for further details).
 Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: Main DB - 7L1, 7L2, 7L3
Overcurrent protective device for the distribution circuit
 BS (EN): (60947-2) Type: (N/A) Nominal voltage: (.415...) V Rating: (.400...) A No. of phases: (3)
Associated RCD (if any)
 BS (EN): (N/A) RCD Type: (N/A) $I_{Δn}$: (N/A) mA No. of poles: (N/A) Operating time: (N/A) ms

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

40159943

ISN18.3c

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD		AFDD**	Comments and additional information, where required
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)			Operating time* (ms)	Test button (✓)	AFDD test button (✓)	
	(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂									
0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	✓	N/A	N/A	N/A	N/A	N/A
1L1	N/A	N/A	N/A	1.19	N/A	LIM	>200	500	✓	1.44	33	✓	N/A	N/A
1L2	N/A	N/A	N/A	1.40	N/A	LIM	>200	500	✓	1.64	33	✓	N/A	N/A
1L3	N/A	N/A	N/A	1.29	N/A	LIM	>200	500	✓	1.52	32	✓	N/A	N/A
2L1	N/A	N/A	N/A	1.17	N/A	LIM	>200	500	✓	1.40	33	✓	N/A	N/A
2L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L3	N/A	N/A	N/A	1.33	N/A	LIM	>200	500	✓	1.57	28	✓	N/A	N/A
3L1	N/A	N/A	N/A	0.45	N/A	N/A	179	500	✓	0.65	28	✓	N/A	N/A
3L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L3	N/A	N/A	N/A	1.04	N/A	LIM	167	500	✓	1.29	19	✓	N/A	N/A
4L1	0.29	0.29	0.49	0.19	N/A	N/A	>200	500	✓	0.39	28	✓	N/A	N/A
4L2	0.24	0.24	0.42	0.16	N/A	N/A	>200	500	✓	0.34	27	✓	N/A	N/A
4L3	0.32	0.34	0.53	0.22	N/A	N/A	>200	500	✓	0.45	33	✓	N/A	N/A
5L1	0.37	0.37	0.60	0.25	N/A	N/A	>200	500	✓	0.47	28	✓	N/A	N/A
5L2	0.25	0.28	0.44	0.17	N/A	N/A	>200	500	✓	0.59	28	✓	N/A	N/A
5L3	0.22	0.22	0.36	0.14	N/A	N/A	>200	500	✓	0.38	33	✓	N/A	N/A
6L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6L2	N/A	N/A	N/A	0.01	N/A	N/A	>200	500	✓	0.24	N/A	N/A	N/A	N/A

Circuits/equipment vulnerable to damage when testing (where applicable): All vulnerable equipment has been disconnected for testing

TESTED BY Name (capitals): GARETH PRITCHARD Position: Electrician Signature:  Date: 08/09/2025

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)					
Multi-function: 28K-1011	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A

* RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{Δn})

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	--------------------

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

40159943 ISN18.3c

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see footer to PART B)	Reference Method (BS 7671)	Number of points served	Circuit conductor (number & csa)		Max. disconnection time (BS 7671) (s)	Overcurrent protective device					RCD			
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Maximum permitted Zs* (Ω)	BS (EN)	Type	Rating (A)	Operating current, I _{Δn} (mA)
0	Main Switch	N/A	N/A	N/A	N/A	N/A	N/A	60947-3	3	100	N/A	N/A	N/A	N/A	N/A	N/A
1	Cooker	A	B	2	6	2.5	0.4	61009	B	32	10	1.37	61009	A	32	N/A
2	Cooker 2	A	B	2	6	2.5	0.4	61009	B	32	10	1.37	61009	A	32	N/A
3	Cooker 3	A	B	2	6	2.5	0.4	61009	B	32	10	1.37	61009	A	32	N/A
4	Sockets Kitchen	A	B	8	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
5	Sockets Kitchen Diner	A	B	16	2.5	1.5	0.4	61009	C	32	10	0.68	61009	A	32	30
6	Kitchen Water Heater	A	B	1	2.5	1.5	0.4	61009	B	20	10	1.74	61009	A	20	N/A
7	Lighting Shower South	A	B	4	1.5	1	0.4	61009	C	6	10	3.64	61009	A	10	30
8	Lighting Kitchen, Room 508-509	A	B	7	1.5	1	0.4	61009	B	6	10	7.28	61009	A	6	N/A
9	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12	spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: DB5A

Location of DB: 5th Floor Cupboard

Z_{db}: 0.24 (Ω) I_{pf} at DB†: 0.9 (kA)

Confirmation of supply polarity: (✓) Phase sequence confirmed†: (✓)

SPD Details** Types: T1 (N/A) T2 (N/A) T3 (N/A) N/A (N/A)

Status indicator checked (where functionality indicator is present): (N/A)

**SPD Type.

Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.

Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B), (See Section 534 for further details).

Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: Main DB - 7L1, 7L2, 7L3

Overcurrent protective device for the distribution circuit

BS (EN): (60947-2) Type: (N/A) Nominal voltage: (415) V Rating: (400) A No. of phases: (3)

Associated RCD (if any)

BS (EN): (N/A) RCD Type: (N/A) I_{Δn}: (N/A) mA No. of poles: (N/A) Operating time: (N/A) ms

Original (to the person ordering the work)



This certificate is not valid if the serial number has been defaced or altered

40159943

ISN18.3c

CONTINUATION SHEET : EIC and EICR

Issued in accordance with BS 7671: 2018 (as amended) – Requirements for Electrical Installations

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

Circuit number	Continuity (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z_s (Ω)	RCD		AFDD**		Comments and additional information, where required
	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live	Live / Earth	Test voltage DC			Operating time*	Test button	AFDD test button		
	(Line) r_1	(Neutral) r_n	(cpc) r_2	($R_1 + R_2$)	R_2	(M Ω)	(M Ω)	(V)			(ms)	(✓)	(✓)		
0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	✓	N/A	N/A	N/A	N/A	N/A	
1	N/A	N/A	N/A	0.16	N/A	N/A	62.5	500	✓	0.39	23.6	N/A	N/A	N/A	
2	N/A	N/A	N/A	0.17	N/A	N/A	62.5	500	✓	0.42	23.6	N/A	N/A	N/A	
3	N/A	N/A	N/A	0.19	N/A	N/A	62.5	500	✓	0.47	23.6	N/A	N/A	N/A	
4	0.24	0.25	0.40	0.16	N/A	N/A	62.5	500	✓	0.35	23.6	✓	N/A	N/A	
5	0.32	0.32	0.53	0.22	N/A	N/A	62.5	500	✓	0.39	23.6	✓	N/A	N/A	
6	N/A	N/A	N/A	0.31	N/A	N/A	62.5	500	✓	0.49	23.6	N/A	N/A	N/A	
7	N/A	N/A	N/A	0.90	N/A	LIM	>200	500	✓	1.11	19	✓	N/A	N/A	
8	N/A	N/A	N/A	1.25	N/A	LIM	>200	500	✓	1.57	19	N/A	N/A	N/A	
9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Circuits/equipment vulnerable to damage when testing (where applicable): All vulnerable equipment has been disconnected for testing

TESTED BY Name (capitals): GARETH PRITCHARD Position: Electrician Signature: Date: 08/09/2025

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)					
Multi-function: 28K-1011	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A

* RCD effectiveness is verified using an alternating current test at rated residual operating current ($I_{\Delta n}$)

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state): N/A
--------------------------	---	--	--	---	---	--------------------------------	--------------------------------	------------------------------	--------------------

Original (to the person ordering the work)