

Electrical Installation Condition Report

Requirements for Electrical Installations - BS 7671:2018
(IET Wiring Regulations 18th Edition)



Information for recipients:

The purpose of this report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).

The person ordering the report should have received the Original©Report and the inspector should have retained a duplicate.

The Original©Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.

Where the installation incorporates residual current devices (RCDs) there should be a notice at or near the devices stating that they should be tested every 6 months. **For safety reasons it is important that these instructions are followed.**

Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The Inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licencing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.

For items classified in Section K as C1 (“Danger Present”), **the safety of those using the installation is at risk**, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.

For items classified in Section K as C2 (“Potentially Dangerous”), **the safety of those using the installation may be at risk** and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where it has been stated in Section K that an observation requires further investigation code FI the inspection has revealed an apparent deficiency which may result on a code C1 or C2 could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated as soon as possible. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons competent in such work. The recommended date by which the next inspection is due is stated in Section F of the report under ‘Recommendations’ and on label at or near to the consumer unit/distribution board.

ELECTRICAL INSTALLATION CONDITION REPORT

FT/
EICR 110148205

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



A. Details of the Installation

| | | | |
|----------|---|--------------|---|
| Client | UPP Residential Services Ltd | Installation | Swansea University Bay Campus - Deganwy 13 |
| Address | First Floor 12 Arthur Street London | Address | Reception - Ground Floor Tower Information Centre Fabian Way Crymlyn Burrows Swansea |
| Postcode | EC4R 9AB | Postcode | SA1 8EN |

B. Reason for Producing this Report *This form is to be used only for reporting on the condition of an existing installation.*

Essential information requested by the client in accordance with the electricity at work regulations 1989.

Date(s) on which the inspection and testing were carried out to

C. Details of Installation which is the Subject of this Report

Description of premises Domestic Commercial Industrial Other (please specify)

Estimated age of the wiring system years

Evidence of alterations or addition Yes No Not apparent if 'Yes', estimated years

Records of installation available Yes No Records held by

Date of last inspection Electrical Installation Certificate No. or previous Inspection Report No.

D. Extent of Electrical Installation Covered by this Report:

Testing of all sub mains, lighting and power circuits, within the constraints of the agreed limitations.

Agreed Limitations and Operational Limitations (Regulations 653.2)

Unable to completely isolate the installation. Unable to access the sealed supply device characteristics. Ze and Ipf have been taken with all earthing and bonding in place. Insulation resistance testing has been carried out to regulation 612.3.3 on circuits where it was impracticable to disconnect load. DB LL2/P and DB LL2/L have not had breakers in there designated as there is almost no way into the distribution board, i cannot verify if breakers installed in the DB have outgoing circuits, the door opens onto a duct pipe which prevents access into the DB leaving a number of breakers with unverified cable sizes and unverified designations also cannot perform ZE, Ipf, R1+R2, IR and ring tests on --Please see Continuation Page--

Agreed with:

The inspection and testing detailed within this report and accompanying schedule has been carried out in accordance with BS 7671: 2018 (IET Wiring Regulations) amended to

It should be noted that cables concealed within trunkings and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

E. Summary of the Condition of the Installation

General conditions of the installation (in terms of electrical safety)

Incoming system is a three phase TN-C-S (Terra Neutral Combined Separate) earthing system. Mains are located in the mains room located on the ground floor of the installation, on the left hand side of the building. Cables used through out installation are BS6242Y twin and earth PVC/PVC double --Please see Continuation Page--

Overall assessment of the installation in terms of its suitability for continued use **SATISFACTORY** ***UNSATISFACTORY**

*An UNSATISFACTORY assessment indicates that dangerous (code C1), or potentially dangerous (code C2), Further investigation (code FI) conditions have been identified

F. Recommendations

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potential dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further Investigation required' (code FI). Observations classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by (date)

ELECTRICAL INSTALLATION CONDITION REPORT

FT/ 110148205
EICR

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



G. Declaration

I/we being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

| | | | |
|------------|---------------------------------------|-------------------------|--------------------------|
| Company | PHS Compliance | Inspected and tested by | Authorised for issue by |
| Address | Kid Glove Road, Golborne, Warrington, | Name: | Liam Kimble |
| | | Signature: | |
| Postcode | WA3 3GR | | |
| Branch No. | | Position: | Electrical Test Engineer |
| Scheme No. | | Date: | 04/07/2022 |
| | | | Technical Auditor |
| | | | 18/08/2022 |

EICRs are produced by a UKAS accredited inspection body, No. 0433

H. Schedule(s)

1 schedule(s) of inspection and 129 schedule(s) of test results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

I. Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S TN-C-S TT Other Please specify _____

Number & Type of live conductors AC DC No. of phases 3 No. of wires 4

Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)

Nominal voltage, U/U₀ ⁽¹⁾ 400/230 v Nominal frequency, f⁽¹⁾ 50 Hz Confirmation of supply polarity

Prospective fault current, I_{pr} ⁽²⁾ 4.8 kA External loop impedance, Z_e ⁽²⁾ 0.10 Ω

Supply Protective Device BS (EN) LIM Type LIM Rated Current LIM A

No. of Additional Supplies N/A

J. Particulars of Installation Referred to in this Report

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) _____ Distributors facility Installation Earth Electrode

Location _____ Electrode resistance to earth _____ Ω Maximum Demand (load) LIM Amps KVA

| Main Protective Conductors | Material | csa | (✓) or Value | (✓) or Value |
|---|----------|-----|---|---|
| Earthing Conductor | Copper | 120 | Continuity Verified <input checked="" type="checkbox"/> | Ω Connection Verified <input checked="" type="checkbox"/> |
| Protective Bonding Conductor (to extraneous-conductive-parts) | Copper | 50 | Continuity Verified <input checked="" type="checkbox"/> | Ω Connection Verified <input checked="" type="checkbox"/> |

Main Supply Conductor Copper 120 (connection / continuity) (✓) or Value (✓) or Value

Main Switch Location Main Electrical Room Water installation Ω To structural steel Ω

Fuse/device rating or setting 400 A Voltage rating 400 V Gas installation pipes Ω To lightning protection NA Ω

If RCD main switch: Rated residual operating current I Δn N/A mA Oil installation pipes NA Ω Other IT Cabinet Ω

BS(EN) 60947-3 No. of Poles 4 Current Rating 400 A Rated time delay N/A ms Measured operating trip time N/A ms

K. Observations

Referring to the attached schedule of inspection and test results, and subject to the limitations at Section D.

- No remedial work required
- The following observations are made

Explanation of codes

| | |
|-----------|---|
| C1 | Danger present. Risk of Injury. Immediate remedial action required. |
| C2 | Potentially dangerous. Urgent remedial action required. |
| C3 | Improvement recommended. |
| F1 | Further Investigation required without delay |

| Item No. | Observations | Code |
|----------|---|------|
| 1 | Observation: Live conductors are incorrectly identified. Location: DB Main CCT 1/TP Regulation: 514.3.1 | C3 |
| 2 | Observation: No IP2X protection (>12mm hole) on the bottom surface of Socket. Location: DB CL1 14/L1 Regulation: 416.2.1 | C3 |
| 3 | Observation: Ring circuit with conductors of the same size shall have resistance values within 0.05 ohm of each other. Where Twin and earth is used the resistance value differential between live conductors and earth shall be approximately 1.67 times the value of the live readings. Location: DB CL8 CCT 8/L3 Reg 643.2.1 | F1 |
| 4 | Observation: Damaged socket back box. Location: DB CL1 CCT 14/L1 Regulation: 416.2 | C2 |

ELECTRICAL INSTALLATION CONDITION REPORT

FT/
EICR 110148205

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



| | | |
|---|--|----|
| 5 | Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL7 CCT 8/L3 Regulation: 537.2.4 | FI |
| 6 | Observation: Circuit isolated at time of test. Further investigation is required to determine reason for isolation and steps taken to prevent the circuit from being inadvertently energized. Location: DB CL13 CCT 5/L3, 6/L3 Regulation: 537.2.4 | FI |
| 7 | Observation: Limited access to DB Location: DB LL2/L Regulation: 132.12 | FI |
| 8 | Observation: Limited access to DB Location: DB LL2/P Regulation: 132.12 | FI |

One of the following codes, as appropriate, has been allocated to each of the observations made above and/or any attached observation sheets to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

| | |
|--|---|
| C1 Danger present. Risk of Injury. Immediate remedial action required. | 0 |
| C2 Potentially dangerous. Urgent remedial action required. | 1 |
| C3 Improvement recommended. | 2 |
| FI Further Investigation required without delay | 5 |

The above values are a total count of Observation per outcome

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)



Outcomes

| | | | | | | |
|-----------------------|-------------------------------|--------------------------|------------------------|---------------|-------------|-----------------|
| Acceptable condition: | Unacceptable condition: State | Improvement recommended: | Further Investigation: | Not Verified: | Limitation: | Not Applicable: |
| | or | | | | | |

| Item No. | Description | Outcome |
|--|---|---------|
| 1.0 External Condition Of Intake Equipment (Visual Inspection Only) Where inadequacies are encountered, it is recommended that the person ordering the report informs the appropriate authority | | |
| 1.1 | Service cable | |
| 1.2 | Service head | |
| 1.3 | Earthing arrangement | |
| 1.4 | Meter tails | |
| 1.5 | Metering equipment | |
| 1.6 | Isolator (where present) | |
| 2.0 Parallel Or Switched Alternative Sources Of Supply | | |
| 2.1 | Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6) | |
| 2.2 | Adequate arrangements where a generating set operates in parallel with the public supply (551.7) | |
| 3.0 Automatic Disconnection Of Supply | | |
| 3.1 | Main earthing/bonding arrangements (411.3; Chap 54) | |
| 3.1.1 | Presence of distributors earthing arrangement (542.1.2.1; 542.1.2.2) | |
| 3.1.2 | Presence of installation earth electrode arrangement (542.1.2.3) | |
| 3.1.3 | Adequacy of earthing conductor size (542.3; 543.1.1) | |
| 3.1.4 | Adequacy of earthing conductor connections (542.3.2) | |
| 3.1.5 | Accessibility of earthing conductor connections (543.3.2) | |
| 3.1.6 | Adequacy of main protective bonding conductor sizes (544.1) | |
| 3.1.7 | Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2) | |
| 3.1.8 | Accessibility of all protective bonding connections (543.3.2) | |
| 3.1.9 | Provision of earthing/bonding labels at all appropriate locations (514.13) | |
| 3.2 | FELV - requirements satisfied (411.7; 411.7.1) | |
| 4.0 Other Methods Of Protection (Where any of the methods listed below are employed details should be provided on separate sheets) | | |
| 4.1 | Non-conducting location (418.1) | |
| 4.2 | Earth-free local equipotential bonding (418.2) | |
| 4.3 | Electrical separation (Section 413; 418.3) | |
| 4.4 | Double insulation (Section 412) | |
| 4.5 | Reinforced insulation (Section 412) | |
| 5.0 Distribution Equipment | | |
| 5.1 | Adequacy of working space/accessibility to equipment (132.12; 513.1) | |
| 5.2 | Security of fixing (134.1.1) | |
| 5.3 | Condition of insulation of live parts (416.1) | |
| 5.4 | Adequacy/security of barriers (416.2) | |
| 5.5 | Condition of enclosure(s) in terms of IP rating etc (416.2) | |
| 5.6 | Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5) | |
| 5.7 | Enclosure not damaged/deteriorated so as to impair safety (651.2) | |
| 5.8 | Presence and effectiveness of obstacles (417.2) | |
| 5.9 | Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2) | |
| 5.10 | Operation of main switch(es) (functional check) (643.10) | |
| 5.11 | Manual operation of circuit-breakers and RCD(s) to prove disconnection (643.10) | |
| 5.12 | Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (643.10) | |
| 5.13 | RCD(s) provided for fault protection – includes RCBO(s) (411.4.204; 411.5.2; 531.2) | |
| 5.14 | RCD(s) provided for additional protection / requirements, where required - includes RCBO(s) (411.3.3; 415.1) | |
| 5.15 | Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2) | |
| 5.16 | Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1) | |
| 5.17 | Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14) | |
| 5.18 | Presence of alternative supply warning notice at or near equipment, where required (514.15) | |
| 5.19 | Presence of next inspection recommendation label (514.12.1) | |
| 5.2 | Presence of other required labelling (please specify) (Section 514) | |
| 5.21 | Compatibility of protective device, base and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.4.5; 411.4.6; Sections 432; 433) | |
| 5.22 | Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3) | |
| 5.23 | Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11) | |
| 5.24 | Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1) | |
| 6.0 Distribution Circuits | | |

for Industrial/Commercial Premises



**Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)**

| | | |
|--|---|---|
| 6.1 | Identification of conductors (514.3.1) | ✓ |
| 6.2 | Cables correctly supported throughout their run (521.10.202; 522.8.5) | ✓ |
| 6.3 | Condition of insulation of live parts (416.1) | ✓ |
| 6.4 | Non-sheathed cables protected by enclosure in conduit, ducting or trunking. Integrity of containment (521.10.1) | ✓ |
| 6.5 | Suitability of containment systems for continued use (including flexible conduit) (Section 522) | ✓ |
| 6.6 | Cables correctly terminated in enclosures (Section 526) | ✓ |
| 6.7 | Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1) | ✓ |
| 6.8 | Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration (421.1; 522.6) | ✓ |
| 6.9 | Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523) | ✓ |
| 6.10 | Adequacy of protective devices: type and rated current for fault protection (411.3) | ✓ |
| 6.11 | Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1) | ✓ |
| 6.12 | Coordination between conductors and overload protective devices (433.1; 533.2.1) | ✓ |
| 6.13 | Cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522) | ✓ |
| 6.14 | Where exposed to direct sunlight, cable of a suitable type (522.11.1) | ✓ |
| 6.15 | Cables concealed under floors, above ceilings, in walls/partitions less than 50 mm from a surface, and in partitions containing metal parts | |
| 6.15.1 | Installed in prescribed zones (see Section D. Extent and limitations) (522.6.202) or | ✓ |
| 6.15.2 | Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.204) | ✓ |
| 6.16 | Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527) | ✓ |
| 6.17 | Band II cables segregated/separated from Band I cables (528.1) | ✓ |
| 6.18 | Cables segregated/separated from non-electrical services (528.3) | ✓ |
| 6.19 | Condition of circuit accessories (651.2) | ✓ |
| 6.20 | Suitability of circuit accessories for external influences (512.2) | ✓ |
| 6.21 | Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3) | ✓ |
| 6.22 | Adequacy of connections, including cpc's, within accessories and to fixed and stationary equipment – identify/record numbers and locations of items inspected (Section 526) | ✓ |
| 6.23 | Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; 537) | ✓ |
| 6.24 | General condition of wiring systems (651.2) | ✓ |
| 6.25 | Temperature rating of cable insulation (522.1.1; Table 52.1) | ✓ |
| 7.0 CONSUMER UNIT/DISTRIBUTION BOARD(S) | | |
| 7.1 | Adequacy of working space/accessibility to consumer unit/distribution board (132.12; 513.1) | ✓ |
| 7.2 | Security of fixing (134.1.1) | ✓ |
| 7.3 | Condition of enclosure(s) in terms of IP rating (Barriers etc) (416.2) | ✓ |
| 7.4 | Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5) | ✓ |
| 7.5 | Enclosure/obstacles not damaged/deteriorated so as to impair safety (651.2) | ✓ |
| 7.5.1 | Presence and effectiveness of obstacles (417.2) | ✓ |
| 7.6 | Presence of main linked switch (as required by 462.1.201) | ✓ |
| 7.7 | Operation of main switch (functional check) (643.10) | ✓ |
| 7.8 | Manual operation of circuit-breakers and RCD(s) (test button) to prove disconnection (643.10) | ✓ |
| 7.9 | Correct identification of circuit details and protective devices (514.8.1; 514.9.1) | ✓ |
| 7.10 | Presence of RCD six-monthly test notice at or near consumer unit/distribution board (514.12.2) | ✓ |
| 7.11 | Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14) | ✓ |
| 7.12 | Presence of alternative supply warning notice at or consumer unit/distribution board (514.15) | ✓ |
| 7.13 | Presence of other required labelling (Please specify) (Section 514) | ✓ |
| 7.14 | Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432; 433) | ✓ |
| 7.15 | Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3) | ✓ |
| 7.16 | Protection against mechanical damage where cables enter consumer unit/distribution board (132.14.1; 522.8.1; 522.8.5; 522.8.11) | ✓ |
| 7.17 | Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1) | ✓ |
| 7.18 | RCD(s) provided for fault protection - includes RCBO(s)(411.4.204; 411.5.2; 531.2) | ✓ |
| 7.19 | RCD(s) provided for additional protection/requirements, where required - includes RCBO(s) (411.3.3; 415.1) | ✓ |
| 7.20 | Confirmation of indication that SPD is functional (651.4) | ✓ |
| 7.21 | Confirmation that ALL conductor connections, including connections to the busbars are correctly located in terminals and are tight and secure (526.1) | ✓ |
| 7.22 | Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6) | ✓ |
| 7.23 | Adequate arrangements where a generating set operates in parallel with the public supply (551.7) | ✓ |
| 8.0 FINAL CIRCUITS | | |
| 8.1 | Identification of conductors (514.3.1) | ✓ |
| 8.2 | Cables correctly supported throughout their run (521.10.202; 522.8.5) | ✓ |
| 8.3 | Condition of insulation of live parts (416.1) | ✓ |

| | | |
|---|---|---|
| 8.4 | Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1) | ✓ |
| 8.4.1 | To include the integrity of conduit and trunking systems (metallic and plastic) | ✓ |
| 8.5 | Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523) | ✓ |
| 8.6 | Coordination between conductors and overload protective devices (433.1; 533.2.1) | ✓ |
| 8.7 | Adequacy of protective devices: type and rated current for fault protection (411.3) | ✓ |
| 8.8 | Presence and adequacy of circuit protective conductors (411.3.1; Section 543) | ✓ |
| 8.9 | Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522) | ✓ |
| 8.10 | Connected cables installed in prescribed zones (see Section D. Extent and limitations) (522.6.202) | ✓ |
| 8.11 | Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (522.6.204) | ✓ |
| 8.12 | Provision of additional requirements for protection by RCD not exceeding 30 mA: | |
| 8.12.1 | For all socket-outlets of rating 32 A or less unless exempt (4.11.3.3) | ✓ |
| 8.12.2 | For the supply of Mobile equipment not exceeding 32 A rating for use outdoors (411.3.3) | ✓ |
| 8.12.3 | For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203) | ✓ |
| 8.12.4 | For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203) | ✓ |
| 8.12.5 | For circuits supplying luminaires within domestic (household) premises (411.3.4) | ✓ |
| 8.13 | Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527) | ✓ |
| 8.14 | Band II cables segregated/separated from Band I cables (528.1) | ✓ |
| 8.15 | Cables segregated/separated from communications cabling (528.2) | ✓ |
| 8.16 | Cables segregated/separated from non-electrical services (528.3) | ✓ |
| 8.17 | Termination of cables at enclosures - indicate extent of sampling in section d of the report (section 526) | |
| 8.17.1 | Connections soundly made and under no undue strain (526.6) | ✓ |
| 8.17.2 | No basic insulation of a conductor visible outside enclosure (526.8) | ✓ |
| 8.17.3 | Connections of live conductors adequately enclosed (526.5) | ✓ |
| 8.17.4 | Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) | ✓ |
| 8.18 | Condition of accessories including socket-outlets, switches and joint boxes (651.2 (v)) | ✓ |
| 8.19 | Suitability of accessories for external influences (512.2) | ✓ |
| 8.20 | Adequacy or working space/accessibility to equipment (132.12; 513.1) | ✓ |
| 8.21 | Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3) | ✓ |
| 9.0 ISOLATION AND SWITCHING | | |
| 9.1 | Isolators (Section 460; 537) | |
| 9.1.1 | Presence and condition of appropriate devices (462; 537.2.7) | ✓ |
| 9.1.2 | Acceptable location - state if local or remote from equipment in question (462; 537.2.7) | ✓ |
| 9.1.3 | Capable of being secured in the OFF position (462.3) | ✓ |
| 9.1.4 | Correct operation verified (643.10) | ✓ |
| 9.1.5 | Clearly identified by position and/or durable marking (537.2.6) | ✓ |
| 9.1.6 | Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2) | ✓ |
| 9.2 | Switching off for mechanical maintenance (Section 464; 537.3.2) | |
| 9.2.1 | Presence and condition of appropriate devices (464.1; 527.3.2) | ✓ |
| 9.2.2 | Acceptable location - state if local or remote from equipment in question (537.3.2.4) | ✓ |
| 9.2.3 | Capable of being secured in the OFF position (462.3) | ✓ |
| 9.2.4 | Correct operation verified (643.10) | ✓ |
| 9.2.5 | Clearly identified by position and/or durable marking (537.3.2.4) | ✓ |
| 9.3 | Emergency switching/stopping (465; 537.3.3) | |
| 9.3.1 | Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4) | ✓ |
| 9.3.2 | Readily accessible for operation where danger might occur (537.3.3.6) | ✓ |
| 9.3.3 | Correct operation verified (643.10) | ✓ |
| 9.3.4 | Clearly identified by position and/or durable marking (537.3.3.6) | ✓ |
| 9.4 | Functional switching (section 463; 537.3.1) | |
| 9.4.1 | Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2) | ✓ |
| 9.4.2 | Correct operation verified (537.3.1.1; 537.3.1.2) | ✓ |
| 10.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED) | | |
| 10.1 | Condition of equipment in terms of IP rating etc (416.2) | ✓ |
| 10.2 | Equipment does not constitute a fire hazard (Section 421) | ✓ |
| 10.3 | Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2) | ✓ |
| 10.4 | Suitability for the environment and external influences (512.2) | ✓ |
| 10.5 | Security of fixing (134.1.1) | ✓ |
| 10.6 | Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2) | ✓ |
| 10.7 | Recessed luminaires (downlighters) | |
| 10.7.1 | Correct type of lamps fitted (559.3.1) | ✓ |
| 10.7.2 | Installed to minimize build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.1.2) | ✓ |
| 10.7.3 | No signs of overheating to surrounding building fabric (559.4.1) | ✓ |

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)



| | | |
|--------|--|---|
| 10.7.4 | No signs of overheating to conductors/terminations (526.1) | ✓ |
|--------|--|---|

11.0 PART 7 SPECIAL INSTALLATIONS OR LOCATIONS

| | | |
|-------|---|---|
| 11.01 | If any special installations or locations are present, list the particular inspections applied. | ✓ |
|-------|---|---|

12.0 Schedule of Tests

Results to be recorded on Schedule of Test Results

| | | |
|------|--|-----|
| 12.1 | External earth loop impedance, Z ^e | Yes |
| 12.2 | Installation earth electrode | Yes |
| 12.3 | Prospective fault current, I _p ^f | Yes |
| 12.4 | Continuity of Earth Conductors | Yes |
| 12.5 | Continuity of Circuit Protective Conductors | Yes |
| 12.6 | Continuity of ring final circuit | Yes |
| 12.7 | Continuity of Protective Bonding Conductors | Yes |
| 12.8 | Volt drop verified | Yes |

| | | |
|-------|--|-----|
| 12.9 | Insulation Resistance between Live Conductors | Yes |
| 12.10 | Insulation Resistance between Live Conductors & Earth | Yes |
| 12.11 | Polarity (prior to energisation) | Yes |
| 12.12 | Polarity (after energisation) including phase sequence | Yes |
| 12.13 | Earth Fault Loop Impedance | Yes |
| 12.14 | RCDs/RCBOs including selectivity | Yes |
| 12.15 | Functional testing of RCD devices | Yes |
| 12.16 | Functional testing of AFDD(s) devices | N/A |

Inspector's Name: Liam Kimble

Date: 04/07/2022

Signature:

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



**Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)**

| | | | | |
|--|---|-------------------------|-------------------|-------------------|
| Company Name PHS Compliance | Company Address Kid Glove Road | Postcode WA3 3GR | Branch No. | Scheme No. |
| Client UPP Residential Services Ltd | Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode SA1 8EN | | |

| | | | |
|--|--|--|--|
| Distribution board details - Complete in every case | Complete only if the distribution board is not connected directly to the origin of the installation | Characteristics at this distribution board | Test instrument serial number(s) |
| Location: Mains Electrical Room [Schneider] Designation: DB Main Num. of ways: 10 Num. of phases: 3 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/> | Supply to distribution board is from: Overcurrent protective device for the distribution circuit: Type: Rating: A Voltage: 400/230 V | Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn ms 30mA or below Operating at 5 IΔn ms Time delay (if applicable) | Loop impedance: 080408/5657 Insulation resistance: 080408/5657 Continuity: 080408/5657 RCD: 080408/5657 |

| CIRCUIT DETAILS | | | | | | | | | | | | | TEST RESULTS | | | | | | | | | | | | | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|---------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|
| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | |
| | | | | | L/N | CPC | | BS EN Number | Type No | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDO (✓) | |
| | | | | | | | | | | | | | | r1 | r | r2 | | | | | | | | | | | | R1 + R2 |
| 1/TP | SPD | D | B | 1 | 16 | 16 | 0.4 | 60947 MCCB | N/A | 60 | 50 | N/A | N/A | N/A | N/A | N/A | N/A | 0.01 | N/A | 250 | LIM | >299 | N/A | 0.09 | N/A | N/A | N/A | N/A |
| 2/TP | Sub Mains(BB 1) | F | E | 1 | 50 | 25 | 5 | 60947 MCCB | N/A | 160 | 50 | N/A | N/A | N/A | N/A | N/A | N/A | 0.03 | N/A | 250 | LIM | >299 | N/A | 0.10 | N/A | N/A | N/A | N/A |
| 3/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 5/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 6/TP | Sub Mains(BB 2) | F | E | 1 | 50 | 25 | 5 | 60947 MCCB | N/A | 160 | 50 | N/A | N/A | N/A | N/A | N/A | N/A | 0.05 | N/A | 250 | LIM | >299 | ✓ | 0.10 | N/A | N/A | N/A | N/A |
| 7/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 8/L1 | Sub Mains(DB CL1) | A | B | 1 | 16 | 16 | 5 | 60947 MCCB | N/A | 63 | 25 | N/A | N/A | N/A | N/A | N/A | N/A | 0.08 | N/A | 250 | LIM | >299 | ✓ | 0.20 | N/A | N/A | N/A | N/A |
| 8/L2 | Refuge Disabled Alarm | A | B | 1 | 2.5 | 2.5 | 0.4 | 60947 MCCB | N/A | 16 | 25 | N/A | N/A | N/A | N/A | N/A | N/A | 0.22 | N/A | LIM | LIM | LIM | ✓ | 0.30 | N/A | N/A | N/A | N/A |
| 8/L3 | FA Panel | O | B | 1 | 2.5 | 2.5 | 0.4 | 60947 MCCB | N/A | 16 | 25 | N/A | N/A | N/A | N/A | N/A | N/A | 0.17 | N/A | LIM | LIM | LIM | ✓ | 0.28 | N/A | N/A | N/A | N/A |
| 9/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 10/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: G Floor Riser | Designation: BB 1 | Num. of ways: 20 | Num. of phases: 3
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(DB Main, 2/TP)
 Overcurrent protective device for the distribution circuit: Type: BS(EN) 60947 MCCB | Rating: 160 A | Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) | Operating at 1 IΔn: N/A ms | Above 30mA (if applicable)
 Z_s: 0.12 Ω | No. of poles: N/A | 30mA or below
 I_{pr}: 4.4 kA | IΔn: N/A | Operating at 5 IΔn: N/A ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max permitted Z _s Other 80% (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|--|--|-----|-----|----------------|---------------|--|-------------------|------------------------|--------------|----------------------------------|-------------|----------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | | | RCD (✓) | APDD (✓) | | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | Fig 8 check (✓) | R1 + R2 | R2 | |
| 1/L1 | Sub Mains(DB CL2) | A | E | 1 | 16 | 16 | 5 | 88-2 HRC | gG | 63 | 80 | N/A | 0.62 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.22 | N/A | N/A | N/A | N/A | |
| 1/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 1/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 5/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 6/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 6/L2 | Sub Mains(DB CL3) | A | B | 1 | 16 | 16 | 5 | 88-2 HRC | gG | 63 | 80 | N/A | 0.62 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.18 | N/A | N/A | N/A | N/A | N/A |
| 6/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 7/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 8/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 9/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 10/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 10/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 10/L3 | Sub Mains(DB CL7) | A | B | 1 | 16 | 16 | 5 | 88-2 HRC | gG | 63 | 80 | N/A | 0.62 | N/A | N/A | N/A | N/A | 0.12 | N/A | 250 | LIM | >299 | ✓ | 0.20 | N/A | N/A | N/A | N/A | N/A |
| 11/L1 | Sub Mains(DB CL6) | A | B | 1 | 16 | 16 | 5 | 88-2 HRC | gG | 63 | 80 | N/A | 0.62 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.24 | N/A | N/A | N/A | N/A | N/A |
| 11/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | | | |
|--|--|---|--|--|-------------------------|---|
| Company Name PHS Compliance | | Company Address Kid Glove Road | | Postcode WA3 3GR | Branch No. | Scheme No. |
| Client UPP Residential Services Ltd | | Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | | | Postcode SA1 8EN | |
| Distribution board details - Complete in every case | | | | Complete only if the distribution board is not connected directly to the origin of the installation | | Characteristics at this distribution board |
| Location: G Floor Riser | | Supply to distribution board is from: Sub Mains(DB Main, 6/TP) | | Associated RCD(if any): BS (EN) N/A | | Test instrument serial number(s) Loop impedance: 080408/5756 Insulation resistance: 080408/5756 Continuity: 080408/5756 RCD: 080408/5756 |
| Designation: BB 2 | | Overcurrent protective device for the distribution circuit: BS(EN) 60947 MCCB | | Operating at 1 IΔn: N/A ms | | |
| Num. of ways: 24 | | Type: Rating 160 A Voltage 400/230 | | 30mA or below: N/A ms | | |
| Num. of phases: 3 | | Type: Rating 160 A Voltage 400/230 | | Operating at 5 IΔn: N/A ms | | |
| Supply polarity confirmed: <input checked="" type="checkbox"/> | | Phase sequence confirmed: <input checked="" type="checkbox"/> | | Time delay (if applicable): N/A | | |

| CIRCUIT DETAILS | | | | | | | | | | | | | TEST RESULTS | | | | | | | | | | | | | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|---------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----------------|----------------|---------------|---------------|--|------------------------|---------|--------------|----------------------|-------------|---|------------------------------|-----|
| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | |
| | | | | | L/N | CPC | Maximum disconnection | BS EN Number | Type No | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | | | AFCD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r2 | Fig 8 check (✓) | | | | | | | | | | All circuits to be completed using R1R2 or R2, not both | | |
| | | | | | | | | | | | | | | | | | R1 + R2 | | R2 | | | | | | | | | |
| 1/L1 | Sub Mains(DB CL4) | A | E | 1 | 16 | 16 | 5 | 88-2 HRC | gG | 63 | 80 | N/A | 0.62 | N/A | N/A | N/A | N/A | 0.14 | N/A | 250 | LIM | >299 | ✓ | 0.22 | N/A | N/A | N/A | N/A |
| 1/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 1/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | Sub Mains(DB CL5) | A | E | 1 | 16 | 16 | 5 | 88-2 HRC | gG | 63 | 80 | N/A | 0.62 | N/A | N/A | N/A | N/A | 0.15 | N/A | 250 | LIM | >299 | ✓ | 0.26 | N/A | N/A | N/A | N/A |
| 4/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 5/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 6/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 7/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 8/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 9/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 10/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 10/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 10/L3 | Sub Mains(DB CL8) | A | E | 1 | 16 | 16 | 5 | 88-2 HRC | gG | 63 | 80 | N/A | 0.62 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.22 | N/A | N/A | N/A | N/A |
| 11/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | | |
|--------------------------------------|---|-------------------|-------------|-------------|--|
| Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.: | |
| Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN | | | |

| | | | |
|--|--|---|---|
| Distribution board details - Complete in every case | Complete only if the distribution board is not connected directly to the origin of the installation | Characteristics at this distribution board | Test instrument serial number(s) |
| Location: G Floor Kitchen [Schneider] | Supply to distribution board is from: Sub Mains(DB Main, 8/L1) | Associated RCD(if any): BS (EN) N/A | Loop impedance: 080408/5756 |
| Designation: DB CL1 | Overcurrent protective device for the distribution circuit: BS(EN) 60947 MCCB | Operating at 1 IΔn: N/A ms | Insulation resistance: 080408/5756 |
| Num. of ways: 18 | Type: Type Rating 63 A Voltage V | 30mA or below: N/A ms | Continuity: 080408/5756 |
| Supply polarity confirmed: <input checked="" type="checkbox"/> | | Operating at 5 IΔn: N/A ms | RCD: 080408/5756 |
| Phase sequence confirmed: <input type="checkbox"/> | | Time delay (if applicable): N/A | |

CIRCUIT DETAILS

TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|--|----------------|-------------|---------------|---|-------|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|--|--|------|------|--------------|---|----------|--|---------------------|---------|--------------|----------------------|-------------|-----------------|------------------------------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage | L/L, L/N | L/E, N/E | Above 30mA IΔn | 30mA or below 5 IΔn | RCD (✓) | | | APDD (✓) | | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | Fig 8 check (✓) | R1 + R2 | R2 | V |
| | | | | | | | | | | | | | | | | | | All circuits to be completed using R1R2 or R2, not both | | | | | | | | | | | |
| 1/L1 | Common Room Lights | A | B | 9 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.38 | N/A | 250 | LIM | >299 | ✓ | 0.52 | 36.3 | 16.4 | ✓ | N/A | |
| 2/L1 | Lighting Rooms 1,3 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.47 | N/A | 250 | LIM | >299 | ✓ | 0.77 | 38.2 | 18.8 | ✓ | N/A | |
| 3/L1 | Lighting Rooms 2,4,6 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.55 | N/A | 250 | LIM | >299 | ✓ | 0.83 | 40.4 | 20.4 | ✓ | N/A | |
| 4/L1 | Lighting Rooms 5,7 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.41 | N/A | 250 | LIM | >299 | ✓ | 0.73 | 22.6 | 18.4 | ✓ | N/A | |
| 5/L1 | Lighting Rooms 8,9 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.82 | N/A | 250 | LIM | >299 | ✓ | 1.04 | 51.2 | 29.1 | ✓ | N/A | |
| 6/L1 | Lighting Rooms 10,11 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.28 | N/A | 250 | LIM | >299 | ✓ | 0.57 | 22.4 | 19.3 | ✓ | N/A | |
| 7/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 8/L1 | Sub Mains(DB CL1/8, DB CL1/8-1) | A | B | 2 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.51 | 0.51 | 0.62 | N/A | 0.28 | N/A | 250 | LIM | >299 | ✓ | 0.37 | 30.4 | 20.4 | ✓ | N/A | |
| 9/L1 | Sub Mains(DB CL1/9, DB CL1/9-1) | A | B | 2 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.47 | 0.50 | 0.58 | N/A | 0.26 | N/A | 250 | LIM | >299 | ✓ | 0.44 | 28.2 | 16.4 | ✓ | N/A | |
| 10/L1 | Sub Mains(DB CL1/10-2, DB CL1/10, DB CL1/10-1) | A | B | 2 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.48 | 0.48 | 0.55 | N/A | 0.26 | N/A | 250 | LIM | >299 | ✓ | 0.40 | 32.2 | 18.8 | ✓ | N/A | |
| 11/L1 | Sub Mains(DB CL1/11-1, DB CL1/11) | A | B | 3 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.47 | 0.47 | 0.53 | N/A | 0.25 | N/A | 250 | LIM | >299 | ✓ | 0.44 | 29.2 | 18.9 | ✓ | N/A | |
| 12/L1 | Sub Mains(DB CL1/12-1, DB CL1/12) | A | B | 2 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.56 | 0.56 | 0.63 | N/A | 0.30 | N/A | 250 | LIM | >299 | ✓ | 0.41 | 28.4 | 20.0 | ✓ | N/A | |
| 13/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 14/L1 | Common Room Ring 1 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.30 | 0.30 | 0.39 | N/A | 0.17 | N/A | 250 | LIM | >299 | ✓ | 0.44 | 29.2 | 16.4 | ✓ | N/A | |
| 15/L1 | Common Room Ring 2 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.38 | 0.38 | 0.44 | N/A | 0.21 | N/A | 250 | LIM | >299 | ✓ | 0.44 | 34.0 | 18.8 | ✓ | N/A | |
| 16/L1 | HOB 1 | A | B | 1 | 10 | 6 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.17 | N/A | 250 | LIM | >299 | ✓ | 0.28 | 32.6 | 18.8 | ✓ | N/A | |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Riser Room 3 [Schneider]
 Designation: DB CL1/9
 Num. of ways: 5 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL1, 9/L1)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn 28.2 ms
 Zs 0.44 Ω No. of poles 30mA or below
 Ipf kA IΔn 30 Operating at 5 IΔn 16.4 ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance 080408/5756
 Insulation resistance 080408/5756
 Continuity 080408/5756
 RCD 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|-----|-----|-----------------|---|--|---------------|---------------|--------------|----------------------|-------------------|------------------------|------------------------------|----------|---------|-----|-----|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | | | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| 2/L1 | Room 3 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.20 | | 250 | LIM | >299 | ✓ | 0.44 | N/A | N/A | N/A | N/A | | |
| 3/L1 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | N/A | N/A | N/A | N/A | |
| 4/L1 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | N/A | N/A | N/A | N/A |
| 5/L1 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | N/A | N/A | N/A | N/A |
| 6/L1 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser [Schneider] | Designation: DB CL1/11 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL1, 11/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) | Operating at 1 IΔn: 29.2 ms (Above 30mA) | 18.9 ms (30mA or below)
 Z_s: 0.44 Ω | No. of poles: | I_{pr}: kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L1 | Room 8 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.40 | N/A | 250 | LIM | >299 | ✓ | 0.77 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Riser Room 5 [Schneider] | Designation: DB CL1/8-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL1, 8/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) | Operating at 1 IΔn: 30.4 ms (Above 30mA) | 20.4 ms (30mA or below)
 Zs: 0.37 Ω | No. of poles: N/A | Ipf: 0.77 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|-----|--|---------------|---------------|--------------|----------------------|-------------------|------------------------|------------------------------|----------|-----|-----|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | | | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | R1 + R2 | R2 | | | | | | | | | | | |
| | | | | | 80% | 80% | | 80% | 80% | 80% | | | | 80% | 80% | | | | | | | | | | | | | | | |
| 1/L1 | Sockets Room 5 | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.26 | N/A | 250 | LIM | >299 | ✓ | 0.72 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Riser Room 1 [Schneider]
 Designation: DB CL1/9-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL1, 9/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) | Above 30mA (if applicable): Operating at 1 IΔn: 28.2 ms
 Z_s: 0.44 Ω | No. of poles: | 30mA or below: I_{pf}: kA | IΔn: 30 | Operating at 5 IΔn: 16.4 ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | 80% | | 80% | 80% | 80% | | | | 80% | 80% | 80% | 80% | 80% | 80% | 80% | 80% | 80% | | | 80% | 80% | 80% | 80% | 80% | |
| 1/L1 | Room 1 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.18 | N/A | 250 | LIM | >299 | ✓ | 0.47 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider] | Designation: DB CL1/10-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL1, 10/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) | Operating at 1 IΔn: 32.2 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.40 Ω | No. of poles: | Ipf: kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 |
| | | | | | 80% | r1 | | rn | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | |
| 1/L1 | Room 4 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.20 | N/A | 250 | LIM | >299 | ✓ | 0.46 | N/A | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser [Schneider] | Designation: DB CL1/10-2 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL1, 10/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) | Operating at 1 IΔn: 32.2 ms (Above 30mA) | 18.8 ms (30mA or below)
 Z_s: 0.40 Ω | No. of poles: | I_{pr}: kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 |
| | | | | | 80% | (Ω) | | (V) | (M(Ω)) | (M(Ω)) | | | | (ms) | (ms) | (✓) | (✓) | | | | | | | | | | | | |
| 1/L1 | Room 6 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.48 | N/A | 250 | LIM | >299 | ✓ | 0.64 | N/A | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance Company Address: Kid Glove Road Postcode: WA3 3GR Branch No.: Scheme No.:
 Client: UPP Residential Services Ltd Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Kitchen RHS [Schneider]
 Designation: DB CL2
 Num. of ways: 18 Num. of phases: 1
 Supply polarity confirmed: Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(BB 1, 1/L1)
 Overcurrent protective device for the distribution circuit: Type: gG Rating: 63 A Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn: N/A ms
 Z_s: 0.22 Ω No. of poles: N/A 30mA or below
 I_{pr}: 1.02 kA IΔn: N/A Operating at 5 IΔn: N/A ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max permitted Z _s Other 80% (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|---|----------------|-------------|---------------|---|-------|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|--|--|----------------|------|--------------|----------|--|----------------|---------------------|--------------|----------------------------------|-------------|----------|------------------------------|---------|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage | L/L, L/N | L/E, N/E | Above 30mA IΔn | 30mA or below 5 IΔn | | | RCD (✓) | APDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | Fig 8 check (✓) | R1 + R2 | R2 |
| | | | | | | | | | | | | | | | | | | V | M(Ω) | M(Ω) | ms | | | ms | | | | |
| 1/L1 | Common Room Lights | A | B | 9 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.51 | N/A | 250 | LIM | >299 | ✓ | 0.73 | 28.3 | 20.2 | ✓ | N/A |
| 2/L1 | Lighting Rooms 8,9 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.59 | N/A | 250 | LIM | >299 | ✓ | 0.82 | 18.4 | 18.0 | ✓ | N/A |
| 3/L1 | Lighting Rooms 6,7 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.68 | N/A | 250 | LIM | >299 | ✓ | 0.91 | 24.6 | 20.2 | ✓ | N/A |
| 4/L1 | Lighting Rooms 2,4 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.50 | N/A | 250 | LIM | >299 | ✓ | 0.75 | 25.2 | 18.2 | ✓ | N/A |
| 5/L1 | Lighting Rooms 1,3,5 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.41 | N/A | 250 | LIM | >299 | ✓ | 0.68 | 30.2 | 15.4 | ✓ | N/A |
| 6/L1 | Lighting Rooms 10,11 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.53 | N/A | 250 | LIM | >299 | ✓ | 0.77 | 26.4 | 18.3 | ✓ | N/A |
| 7/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 8/L1 | Sub Mains(DB CL1/8-2, DB CL2/8, DB CL2/8-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.55 | 0.55 | 0.63 | N/A | 0.30 | N/A | 250 | LIM | >299 | ✓ | 0.44 | 32.4 | 18.8 | ✓ | N/A |
| 9/L1 | Sub Mains(DB CL2/9-1, DB CL2/9) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.51 | 0.51 | 0.59 | N/A | 0.28 | N/A | 250 | LIM | >299 | ✓ | 0.42 | 28.3 | 18.4 | ✓ | N/A |
| 10/L1 | Sub Mains(DB CL2/10-1, DB CL2/10) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.38 | 0.42 | 0.51 | N/A | 0.23 | N/A | 250 | LIM | >299 | ✓ | 0.50 | 30.6 | 16.4 | ✓ | N/A |
| 11/L1 | Sub Mains(DB CL2/11-1, DB CL2/11) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.40 | 0.40 | 0.52 | N/A | 0.23 | N/A | 250 | LIM | >299 | ✓ | 0.47 | 34.6 | 18.2 | ✓ | N/A |
| 12/L1 | Sub Mains(DB CL2/12-1, DB CL2/12) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.38 | 0.38 | 0.47 | N/A | 0.21 | N/A | 250 | LIM | >299 | ✓ | 0.43 | 30.2 | 14.2 | ✓ | N/A |
| 13/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 14/L1 | Common Room Ring 1 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.29 | 0.29 | 0.53 | N/A | 0.22 | N/A | 250 | LIM | >299 | ✓ | 0.40 | 29.4 | 19.3 | ✓ | N/A |
| 15/L1 | Common Room Ring 2 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.30 | 0.32 | 0.51 | N/A | 0.20 | N/A | 250 | LIM | >299 | ✓ | 0.42 | 32.5 | 16.4 | ✓ | N/A |
| 16/L1 | HOB 1 | A | B | 1 | 10 | 6 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.19 | N/A | 250 | LIM | >299 | ✓ | 0.33 | 19.4 | 15.3 | ✓ | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE Position: Electrical Test Engineer Date: 04/07/2022 Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser (Schneider)
 Designation: DB CL2/10
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL2, 10/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 30.6 ms (Above 30mA) | 16.4 ms (30mA or below)
 Zs: 0.50 Ω | No. of poles: 2 | Ipr: 0.48 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | 80% | | 80% | 80% | 80% | | | | 80% | 80% | 80% | 80% | 80% | 80% | 80% | 80% | 80% | | | 80% | 80% | 80% | 80% | 80% | |
| 1/L1 | Room 2 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.33 | N/A | 250 | LIM | >299 | ✓ | 0.88 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser [Schneider]
 Designation: DB CL2/11
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL2, 11/L1)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) N/A Above 30mA (if applicable) Operating at 1 IΔn 34.6 ms
 Zs 0.47 Ω No. of poles N/A 30mA or below
 Ipf 0.50 kA IΔn 30 Operating at 5 IΔn 18.2 ms
 Time delay (if applicable) N/A

Test instrument serial number(s)
 Loop impedance 080408/5756
 Insulation resistance 080408/5756
 Continuity 080408/5756
 RCD 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|--|---------------|---------------|--------------|----------------------|-------------------|------------------------|------------------------------|----------|---------|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | | | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 |
| 1/L1 | Room 8 Sockets | A | B | 1 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.09 | | 250 | LIM | >299 | ✓ | 0.55 | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | N/A | N/A |
| 3/L1 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | N/A | N/A |
| 4/L1 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 3 Riser [Schnieder]
 Designation: DB CL2/8-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL2, 8/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 32.4 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.44 Ω | No. of poles: 2 | Ipf: 0.55 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|--|---------------|---------------|--------------|----------------------|-------------------|------------------------|------------------------------|----------|---------|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | | | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 |
| 1/L1 | Room 3 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.38 | N/A | 250 | LIM | >299 | ✓ | 0.70 | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 04/07/2022 To 04/07/2022 | Date(s) live testing: 04/07/2022 To 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 5 Riser [Schnieder]
 Designation: DB CL1/8-2
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL2, 8/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 32.4 ms (Above 30mA)
 Zs: 0.44 Ω | No. of poles: 2 | 30mA or below: Ipf: 0.55 kA | IΔn: 30 | Operating at 5 IΔn: 18.8 ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|-----|--|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | | |
| | | | | | 80% | r1 | | rn | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | | |
| 1/L1 | Room 5 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.30 | N/A | 250 | LIM | >299 | ✓ | 0.57 | N/A | N/A | N/A | N/A | N/A | N/A | |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 7 Riser [Schnieder]
 Designation: DB CL2/9-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL2, 9/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 32.4 ms (Above 30mA) | 18.8 ms (30mA or below)
 Z_s: 0.44 Ω | No. of poles: 2 | I_{pn}: 0.55 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L1 | Room 7 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.44 | N/A | 250 | LIM | >299 | ✓ | 0.73 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | |
|--|---|-------------------------|-------------------|-------------------|
| Company Name PHS Compliance | Company Address Kid Glove Road | Postcode WA3 3GR | Branch No. | Scheme No. |
| Client UPP Residential Services Ltd | Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode SA1 8EN | | |

| | | | | | | | |
|--|--|--|--|---|-----------------------------|---|------------------------------------|
| Distribution board details - Complete in every case | | Complete only if the distribution board is not connected directly to the origin of the installation | | Characteristics at this distribution board | | Test instrument serial number(s) | |
| Location: Room 9 Riser [Schnieder] | Designation: DB CL2/11-1 | Supply to distribution board is from: Sub Mains(DB CL2, 11/L1) | Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V | Associated RCD(if any): BS (EN) 61009 | Operating at 1 IΔn: 32.4 ms | Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 |
| Num. of ways: 4 | Num. of phases: 1 | Sub Mains(DB CL2, 11/L1) | BS(EN) 61009 RCD/RCBO | Zs: 0.46 Ω | 30mA or below: 18.8 ms | Continuity: 080408/5756 | RCD: 080408/5756 |
| Supply polarity confirmed: <input checked="" type="checkbox"/> | Phase sequence confirmed: <input type="checkbox"/> | | | Ipf: 0.48 kA | Operating at 5 IΔn: 18.8 ms | | |
| | | | | Time delay (if applicable): N/A | | | |

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 |
| | | | | | 80% | | | | | | | | | | | | | | | | | | | | | | | |
| 1/L1 | Room 9 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.19 | N/A | 250 | LIM | >299 | ✓ | 0.55 | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | | |
|--------------------------------------|---|-------------------|-------------|-------------|--|
| Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.: | |
| Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN | | | |

| | | | |
|---|---|--|--|
| Distribution board details - Complete in every case | Complete only if the distribution board is not connected directly to the origin of the installation | Characteristics at this distribution board | Test instrument serial number(s) |
| Location: Flat 4 Kitchen [Schneider] Designation: DB CL4 Num. of ways: 18 Num. of phases: 1 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/> | Supply to distribution board is from: Sub Mains(BB 2, 1/L1) Overcurrent protective device for the distribution circuit: Type: gG Rating: 63 A Voltage: V | Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn: N/A ms Z _s : 0.22 Ω No. of poles: 30mA or below I _{pr} : 1.03 kA IΔn: N/A Operating at 5 IΔn: N/A ms Time delay (if applicable): | Loop impedance: 080408/5756 Insulation resistance: 080408/5756 Continuity: 080408/5756 RCD: 080408/5756 |

CIRCUIT DETAILS

TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max permitted Z _s Other 80% (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|---------------------------------|----------------|-------------|---------------|---|-------|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|--|--|------|------|----------------|---------------|---------------|--|------------------------|---------|--------------|----------------------------------|-------------|-----------|---|-----|-----|
| | | | | | L / N | CPC | Maximum disconnection | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | | | APDD (✓) | | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | Fig 8 (✓) | All circuits to be completed using R1R2 or R2, not both | | |
| | | | | | | | | | | | | | | R1 + R2 | R2 | | | | | | | | | | | | | | |
| 1/L1 | Common Room Lights | A | B | 9 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.33 | N/A | 250 | LIM | >299 | ✓ | 0.52 | 32.5 | 23.5 | ✓ | N/A | |
| 2/L1 | Lighting Rooms 2,3 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.41 | N/A | 250 | LIM | >299 | ✓ | 0.63 | 28.4 | 18.4 | ✓ | N/A | |
| 3/L1 | Lighting Rooms 4,5 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.44 | N/A | 250 | LIM | >299 | ✓ | 0.52 | 36.4 | 24.4 | ✓ | N/A | |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 5/L1 | Sub Mains(DB CL4/5) | A | B | 1 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.19 | 0.22 | 0.30 | N/A | 0.12 | N/A | 250 | LIM | >299 | ✓ | 0.43 | 28.3 | 18.4 | ✓ | N/A | |
| 6/L1 | Sub Mains(DB CL4/6-1, DB CL4/6) | A | B | 1 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.21 | 0.21 | 0.28 | N/A | 0.12 | N/A | 250 | LIM | >299 | ✓ | 0.35 | 25.4 | 18.8 | ✓ | N/A | |
| 7/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 8/L1 | Common Room Ring 1 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.22 | 0.25 | 0.33 | N/A | 0.14 | N/A | 250 | LIM | >299 | ✓ | 0.44 | 28.4 | 18.4 | ✓ | N/A | |
| 9/L1 | Common Room 2 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.28 | 0.28 | 0.38 | N/A | 0.17 | N/A | 250 | LIM | >299 | ✓ | 0.38 | 26.2 | 18.4 | ✓ | N/A | |
| 10/L1 | Hob | A | B | 1 | 10 | 6 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.11 | N/A | 250 | LIM | >299 | ✓ | 0.40 | 28.0 | 16.4 | ✓ | N/A | |
| 11/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 12/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 13/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 14/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 15/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 16/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 17/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance Company Address: Kid Glove Road Postcode: WA3 3GR Branch No.: Scheme No.:
 Client: UPP Residential Services Ltd Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Riser Room 8 [Schneider] Designation: DB CL3/7
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed: Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(DB CL3, 7/L2)
 Overcurrent protective device for the distribution circuit: Type: C Rating: 32 A Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) 61008 Above 30mA (if applicable) Operating at 1 IΔn: 32.2 ms
 Z_s: 0.42 Ω No. of poles: 2 30mA or below
 I_{pn}: 0.55 kA IΔn: 30 Operating at 5 IΔn: 18.4 ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 |
| 1/L2 | Sub Mains(DB CL3/7-2) | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.20 | N/A | 250 | LIM | >299 | ✓ | 0.66 | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE Position: Electrical Test Engineer Date: 04/07/2022 Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance **Company Address** Kid Glove Road **Postcode** WA3 3GR **Branch No.** **Scheme No.**
Client UPP Residential Services Ltd **Installation Address** Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea **Postcode** SA1 8EN

Distribution board details - Complete in every case
 Location: Room 3 Riser [Schneider]
 Designation: DB CL3/8
 Num. of ways: 4 Num. of phases: 1
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(DB CL3, 8/L2)
 Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) 61008 Operating at 1 IΔn 29.8 ms Above 30mA (if applicable)
 Zs 0.44 Ω No. of poles 2 30mA or below
 Ipr 0.53 kA IΔn 30 Operating at 5 IΔn 19.0 ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance 080408/5756
 Insulation resistance 080408/5756
 Continuity 080408/5756
 RCD 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|-----------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|-----|-----|-----------------|---|--|---------------|---------------|--------------|----------------------|-------------------|------------------------|------------------------------|----------|---------|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | | | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 |
| 1/L2 | Sub Mains(DB CL3/8-2, DB CL3/8-1) | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.55 | N/A | N/A | N/A | N/A | |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 9 Riser [Schneider]
 Designation: DB CL3/9
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(DB CL3, 9/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) 61008 | Operating at 1 IΔn: 35.2 ms (Above 30mA)
 Zs: 0.38 Ω | No. of poles: 2 | 30mA or below: Ipf: 0.61 kA | IΔn: 30 | Operating at 5 IΔn: 16.2 ms (if applicable)
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|--|---------------|---------------|--------------|----------------------|-------------------|------------------------|------------------------------|----------|---------|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | | | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 |
| 1/L2 | Sub Mains(DB CL3/9-1) | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.14 | N/A | 250 | LIM | >299 | ✓ | 0.56 | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider]
 Designation: DB CL3/10
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL3, 10/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 39.5 ms (Above 30mA) | 18.8 ms (30mA or below)
 Z_s: 0.35 Ω | No. of poles: 2
 I_{pn}: 0.66 kA | IΔn: 30 | Operating at 5 IΔn: 18.8 ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L2 | Room 4 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.15 | N/A | 250 | LIM | >299 | ✓ | 0.63 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Riser Room 9 [Schneider]
 Designation: DB CL3/7-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL3, 7/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 32.2 ms (Above 30mA)
 Zs: 0.42 Ω | No. of poles: 2 | 30mA or below: Ipf: 0.55 kA | IΔn: 30 | Operating at 5 IΔn: 18.4 ms (if applicable)
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|-----|--|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | | |
| | | | | | 80% | r1 | | rn | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | | |
| 1/L2 | Room 9 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.20 | N/A | 250 | LIM | >299 | ✓ | 0.66 | N/A | N/A | N/A | N/A | N/A | N/A | |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | | |
|--------------------------------------|---|-------------------|-------------|-------------|--|
| Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.: | |
| Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN | | | |

| | | | |
|--|--|--|--|
| Distribution board details - Complete in every case | Complete only if the distribution board is not connected directly to the origin of the installation | Characteristics at this distribution board | Test instrument serial number(s) |
| Location: Room 2 Riser [Schneider] Designation: DB CL4/5 Num. of ways: 4 Num. of phases: 1 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/> | Supply to distribution board is from: Sub Mains(DB CL4, 5/L1) Overcurrent protective device for the distribution circuit: Type: C Rating: 32 A Voltage: V | Associated RCD(if any): BS (EN) 61008 Operating at 1 IΔn: 28.3 ms Zs: 0.43 Ω No. of poles: 2 Ipf: 0.51 kA IΔn: 30 Operating at 5 IΔn: 18.4 ms Time delay (if applicable): | Loop impedance: 080408/5756 Insulation resistance: 080408/5756 Continuity: 080408/5756 RCD: 080408/5756 |

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|--|---------------|---------------|--------------|----------------------|-------------------|------------------------|------------------------------|----------|---------|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | | | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 |
| 1/L1 | Sub Mains(DB CL4/5-1) | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.18 | | 250 | LIM | >299 | ✓ | 0.53 | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | N/A | N/A |
| 3/L1 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | N/A | N/A |
| 4/L1 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 04/07/2022 Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider]
 Designation: DB CL4/6
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL4, 6/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 25.4 ms (Above 30mA) | 30mA or below: 18.8 ms (if applicable)
 Zs: 0.35 Ω | No. of poles: 2 | Ipf: 0.68 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | rn | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L1 | Room 4 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.12 | N/A | 250 | LIM | >299 | ✓ | 0.53 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 3 Riser [Schneider]
 Designation: DB CL4/5-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL4/5, 1/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 25.4 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.38 Ω | No. of poles: 2
 Ipf: 0.68 kA | IΔn: 30 | Operating at 5 IΔn: 18.8 ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | 80% | | 80% | 80% | 80% | | | | 80% | 80% | 80% | 80% | 80% | 80% | 80% | 80% | 80% | | | 80% | 80% | 80% | 80% | 80% | 80% |
| 1/L1 | Room 3 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.18 | N/A | 250 | LIM | >299 | ✓ | 0.62 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | |
|--|---|-------------------------|-------------------------|-------------------|
| Company Name PHS Compliance | Company Address Kid Glove Road | Postcode WA3 3GR | Branch No. | Scheme No. |
| Client UPP Residential Services Ltd | Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | | Postcode SA1 8EN | |

| | | | | | | | | |
|--|-------------------------------------|--|-----------------------|---|-------|---|-----------------------|-------------|
| Distribution board details - Complete in every case | | Complete only if the distribution board is not connected directly to the origin of the installation | | Characteristics at this distribution board | | Test instrument serial number(s) | | |
| Location | Flat 5 Kitchen [Schneider] | Supply to distribution board is from | Sub Mains(BB 2, 4/L2) | Associated RCD(if any): BS (EN) | 61008 | Above 30mA (if applicable) | Loop impedance | 080408/5756 |
| Designation | DB CL5 | Overcurrent protective device for the distribution circuit: Type | BS(EN) 88-2 HRC | Operating at 1 IΔn | N/A | ms | Insulation resistance | 080408/5756 |
| Num. of ways | 18 | Rating | 63 | 30mA or below | N/A | ms | Continuity | 080408/5756 |
| Supply polarity confirmed | <input checked="" type="checkbox"/> | Voltage | | Operating at 5 IΔn | N/A | ms | RCD | 080408/5756 |
| Phase sequence confirmed | <input type="checkbox"/> | | | Time delay (if applicable) | | | | |

CIRCUIT DETAILS

TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|---|----------------|-------------|---------------|---|-------|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|--|--|------|------|--------------|----------|----------|--|---------------------|---------|--------------|----------------------|-------------|-----------|---|-----|-----|
| | | | | | L / N | CPC | Maximum disconnection | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage | L/L, L/N | L/E, N/E | Above 30mA IΔn | 30mA or below 5 IΔn | RCD (✓) | | | APDD (✓) | | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | Fig 8 (✓) | All circuits to be completed using R1R2 or R2, not both | | |
| | | | | | | | | | | | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | ms | ms | | | | | | | | | |
| 1/L2 | Common Room Lights | A | B | 9 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.35 | N/A | 250 | LIM | >299 | ✓ | 0.57 | 28.4 | 20.0 | ✓ | N/A | |
| 2/L2 | Lighting Rooms 1,3,5 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.44 | N/A | 250 | LIM | >299 | ✓ | 0.63 | 32.5 | 18.8 | ✓ | N/A | |
| 3/L2 | Lighting Rooms 2,4,6 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.38 | N/A | 250 | LIM | >299 | ✓ | 0.59 | 28.9 | 18.8 | ✓ | N/A | |
| 4/L2 | Lighting Rooms 7,8 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.37 | N/A | 250 | LIM | >299 | ✓ | 0.61 | 32.2 | 19.4 | ✓ | N/A | |
| 5/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 6/L2 | Sub Mains(DB CL5/6-2, DB CL5/6, DB CL5/6-1) | A | B | 9 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.30 | 0.29 | 0.35 | N/A | 0.16 | N/A | 250 | LIM | >299 | N/A | 0.37 | 29.8 | 18.8 | ✓ | N/A | |
| 7/L2 | Sub Mains(DB CL5/7-1, DB CL5/7, DB CL5/7-2) | A | B | 9 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.25 | 0.28 | 0.40 | N/A | 0.16 | N/A | 250 | LIM | >299 | N/A | 0.35 | 32.2 | 18.0 | ✓ | N/A | |
| 8/L2 | Sub Mains(DB CL5/8-1, DB CL5/8) | A | B | 6 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.20 | 0.25 | 0.33 | N/A | 0.13 | N/A | 250 | LIM | >299 | N/A | 0.44 | 30.8 | 20.2 | ✓ | N/A | |
| 9/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 10/L2 | Common Room Sockets 1 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.24 | 0.24 | 0.36 | N/A | 0.15 | N/A | 250 | LIM | >299 | ✓ | 0.38 | 28.4 | 15.2 | ✓ | N/A | |
| 11/L2 | Common Room Sockets 2 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.28 | 0.28 | 0.51 | N/A | 0.20 | N/A | 250 | LIM | >299 | ✓ | 0.33 | 32.2 | 18.8 | ✓ | N/A | |
| 12/L2 | Hob 1 | A | B | 1 | 2.5 | 1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.22 | N/A | 250 | LIM | >299 | ✓ | 0.49 | 25.6 | 20.4 | ✓ | N/A | |
| 13/L2 | Hob 2 | A | B | 1 | 2.5 | 1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.28 | N/A | 250 | LIM | >299 | ✓ | 0.47 | 32.8 | 19.4 | ✓ | N/A | |
| 14/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 15/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 16/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 17/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser [Schneider]
 Designation: DB CL5/6
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL5, 6/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 29.8 ms (Above 30mA) | 30mA or below: 18.8 ms (if applicable)
 Zs: 0.37 Ω | No. of poles: 2 | Ipf: 0.66 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | 80% | | 80% | 80% | 80% | | | | 80% | 80% | 80% | 80% | 80% | 80% | 80% | 80% | 80% | | | 80% | 80% | 80% | 80% | 80% | |
| 1/L2 | Room 1 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.19 | N/A | 250 | LIM | >299 | ✓ | 0.38 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser [Schneider]
 Designation: DB CL5/7
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL5, 7/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 32.2 ms (Above 30mA) | 18.0 ms (30mA or below)
 Z_s: 0.35 Ω | No. of poles: 2
 I_{pn}: 0.63 kA | IΔn: 30 | Operating at 5 IΔn: 18.0 ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L2 | Room 2 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.38 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 3 Riser [Schneider]
 Designation: DB CL5/6-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL5, 6/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 29.8 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.37 Ω | No. of poles: 2
 Ipf: 0.66 kA | IΔn: 30 | Operating at 5 IΔn: 18.8 ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | rn | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L2 | Room 3 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.12 | N/A | 250 | LIM | >299 | ✓ | 0.44 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | |
|--|---|-------------------------|-------------------|-------------------|
| Company Name PHS Compliance | Company Address Kid Glove Road | Postcode WA3 3GR | Branch No. | Scheme No. |
| Client UPP Residential Services Ltd | Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode SA1 8EN | | |

| | | | | | | | |
|---|---|--|--|---|-----------------------------|---|------------------------------------|
| Distribution board details - Complete in every case | | Complete only if the distribution board is not connected directly to the origin of the installation | | Characteristics at this distribution board | | Test instrument serial number(s) | |
| Location: Room 5 Riser [Schneider] | Designation: DB CL5/6-2 | Supply to distribution board is from: Sub Mains(DB CL5, 6/L2) | Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage V | Associated RCD(if any): BS (EN) 61008 | Operating at 1 IΔn: 29.8 ms | Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 |
| Num. of ways: 4 | Num. of phases: 1 | Sub Mains(DB CL5, 6/L2) | BS(EN) 61009 RCD/RCBO | Zs: 0.37 Ω | No. of poles: 2 | 30mA or below | Continuity: 080408/5756 |
| Supply polarity confirmed <input checked="" type="checkbox"/> | Phase sequence confirmed <input type="checkbox"/> | | | Ipf: 0.66 kA | IΔn: 30 | Operating at 5 IΔn: 18.8 ms | RCD: 080408/5756 |
| | | | | | | | |

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1/L2 | Room 5 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.17 | N/A | 250 | LIM | >299 | ✓ | 0.49 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 04/07/2022 To 04/07/2022 Date(s) live testing 04/07/2022 To 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 04/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser [Schneider]
 Designation: DB CL5/8-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL5, 8/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61008 | Operating at 1 IΔn: 29.8 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.37 Ω | No. of poles: 2 | Ipf: 0.66 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | 80% | | 80% | 80% | 80% | | | | 80% | 80% | 80% | 80% | 80% | 80% | 80% | 80% | 80% | | | 80% | 80% | 80% | 80% | 80% | |
| 1/L2 | Room 8 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 10 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.25 | N/A | 250 | LIM | >299 | ✓ | 0.65 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 04/07/2022 To: 04/07/2022 Date(s) live testing: 04/07/2022 To: 04/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 04/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | |
|--|---|-------------------------|--------------------|--------------------|
| Company Name PHS Compliance | Company Address Kid Glove Road | Postcode WA3 3GR | Branch No. | Scheme No. |
| Client UPP Residential Services Ltd | Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode SA1 8EN | | |

| | | | |
|---|--|---|--|
| Distribution board details - Complete in every case | Complete only if the distribution board is not connected directly to the origin of the installation | Characteristics at this distribution board | Test instrument serial number(s) |
| Location Flat 8 Kitchen [Schneider] | Supply to distribution board is from Sub Mains(BB 2, 10/L3) | Associated RCD(if any): BS (EN) N/A Above 30mA (if applicable) N/A ms Operating at 1 IΔn N/A ms | Loop impedance 080408/5756 |
| Designation DB CL8 | Sub Mains(BB 2, 10/L3) | Z _s 0.22 Ω No. of poles N/A 30mA or below | Insulation resistance 080408/5756 |
| Num. of ways 18 Num. of phases 1 | Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage V | I _{pr} 1.08 kA IΔn N/A Operating at 5 IΔn N/A ms | Continuity 080408/5756 |
| Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/> | | Time delay (if applicable) N/A | RCD 080408/5756 |

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Z _s Other 80% (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|---|----------------|-------------|---------------|---|-------|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|------|------|----------------|---------------|--|-------------------|------------------------|--------------|----------------------------------|-------------|----------|------------------------------|---|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | | | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | |
| | | | | | | | | R1 + R2 | | R2 | | | | | | | | | | | | | | | | | | |
| 1/L3 | Common room Lights | A | B | 9 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.44 | | 250 | LIM | >299 | ✓ | 0.69 | 29.5 | 32.2 | ✓ | N/A |
| 2/L3 | Lighting Rooms 1,3,5 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.38 | | 250 | LIM | >299 | ✓ | 0.71 | 32.2 | 20.0 | ✓ | N/A |
| 3/L3 | Lighting Rooms 2,4,6 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.57 | | 250 | LIM | >299 | ✓ | 0.82 | 44.6 | 32.6 | ✓ | N/A |
| 4/L3 | Lighting Room 7,8 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.44 | | 250 | LIM | >299 | ✓ | 0.72 | 28.2 | 16.4 | ✓ | N/A |
| 5/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 6/L3 | Sub Mains(DB CL8/6-2, DB CL8/6, DB CL8/6-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.29 | 0.24 | 0.32 | N/A | 0.15 | | 250 | LIM | >299 | ✓ | 0.37 | 22.4 | 16.3 | ✓ | N/A |
| 7/L3 | Sub Mains(DB CL8/7-2, DB CL8/7, DB CL8/7-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.19 | 0.19 | 0.33 | N/A | 0.13 | | 250 | LIM | >299 | ✓ | 0.35 | 30.4 | 18.8 | ✓ | N/A |
| 8/L3 | Sub Mains(DB CL8/8-1, DB CL8/8) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.27 | 0.20 | 0.34 | N/A | 0.15 | | 250 | LIM | >299 | ✓ | 0.39 | 29.8 | 20.0 | ✓ | N/A |
| 9/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 10/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 11/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 12/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 13/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 14/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 15/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 16/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 17/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing **05/07/2022** To **05/07/2022** Date(s) live testing **05/07/2022** To **05/07/2022**

Tested by: Name (capital letters) **LIAM KIMBLE** Position **Electrical Test Engineer** Date **05/07/2022** Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser [Schneider] | Designation: DB CL8/7 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL8, 7/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 30.4 ms (Above 30mA) | 18.8 ms (30mA or below)
 Z_s: 0.35 Ω | No. of poles: 2 | I_{pr}: 0.70 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|-----|--|---------------|---------------|--------------|----------------------------------|-------------------|------------------------|------------------------------|----------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | | | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | R1 + R2 | R2 | | | | | | | | | | | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L3 | Room 2 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.22 | N/A | 250 | LIM | >299 | ✓ | 0.60 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name Company Address Postcode Branch No. Scheme No.
 Client Installation Address Postcode

Distribution board details - Complete in every case
 Location
 Designation
 Num. of ways Num. of phases
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from
 Overcurrent protective device for the distribution circuit: Type Rating A Voltage V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn ms
 Z_s Ω No. of poles 30mA or below
 I_{pn} kA IΔn Operating at 5 IΔn ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance
 Insulation resistance
 Continuity
 RCD

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | rn | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L3 | Room 4 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.14 | N/A | 250 | LIM | >299 | ✓ | 0.53 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 6 Riser [Schneider]
 Designation: DB CL8/7-2
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL8, 7/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 30.4 ms (Above 30mA) | 18.8 ms (30mA or below)
 Zs: 0.35 Ω | No. of poles: 2 | Ipr: 0.60 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| 1/L3 | Room 6 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.22 | N/A | 250 | LIM | >299 | ✓ | 0.64 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser [Schneider]
 Designation: DB CL8/8-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL8, 8/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 29.8 ms (Above 30mA) | 30mA or below: 20.0 ms (if applicable)
 Zs: 0.39 Ω | No. of poles: 2 | Ipr: 0.56 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | rn | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L3 | Room 8 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.23 | N/A | 250 | LIM | >299 | ✓ | 0.66 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | |
|--|---|-------------------------|-------------------------|-------------------|
| Company Name PHS Compliance | Company Address Kid Glove Road | Postcode WA3 3GR | Branch No. | Scheme No. |
| Client UPP Residential Services Ltd | Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | | Postcode SA1 8EN | |

| | | | |
|---|--|--|---|
| Distribution board details - Complete in every case | Complete only if the distribution board is not connected directly to the origin of the installation | Characteristics at this distribution board | Test instrument serial number(s) |
| Location: Flat 7 Kitchen [Schneider] | Supply to distribution board is from: Sub Mains(BB 1, 10/L3) | Associated RCD(if any): BS (EN) N/A | Loop impedance: 080408/5756 |
| Designation: DB CL7 | Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage V | Operating at 1 IΔn Above 30mA (if applicable) N/A ms | Insulation resistance: 080408/5756 |
| Num. of ways: 18 Num. of phases: 1 | | Zs 0.20 Ω No. of poles N/A | Continuity: 080408/5756 |
| Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/> | | Ipr 1.14 kA IΔn N/A | RCD: 080408/5756 |
| | | Operating at 5 IΔn N/A ms | |
| | | Time delay (if applicable) N/A | |

CIRCUIT DETAILS

TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|---|----------------|-------------|---------------|---|-------|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|--|--|------|------|----------------|---------------|---------------|--|------------------------|---------|--------------|----------------------|-------------|-----------|---|-----|-----|
| | | | | | L / N | CPC | Maximum disconnection | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | | | APDD (✓) | | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | Fig 8 (✓) | All circuits to be completed using R1R2 or R2, not both | | |
| | | | | | | | | | | | | | | R1 + R2 | R2 | | | | | | | | | | | | | | |
| 1/L3 | Common Room Lights | A | B | 9 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.37 | N/A | 250 | LIM | >299 | ✓ | 0.72 | 23.5 | 20.0 | ✓ | N/A | |
| 2/L3 | Lighting Rooms 1,2 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.48 | N/A | 250 | LIM | >299 | ✓ | 0.70 | 30.4 | 18.8 | ✓ | N/A | |
| 3/L3 | Lighting Rooms 3,4,5 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.30 | N/A | 250 | LIM | >299 | ✓ | 0.54 | 29.2 | 19.3 | ✓ | N/A | |
| 4/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 5/L3 | Sub Mains(DB CL7/5-2, DB CL7/5, DB CL7/5-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.40 | 0.37 | 0.44 | N/A | 0.12 | N/A | 250 | LIM | >299 | ✓ | 0.36 | 19.4 | 18.8 | ✓ | N/A | |
| 6/L3 | Sub Mains(DB CL7/6, DB CL7/6-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.40 | 0.40 | 0.60 | N/A | 0.25 | N/A | 250 | LIM | >299 | ✓ | 0.42 | 24.4 | 16.4 | ✓ | N/A | |
| 7/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 8/L3 | Isolated | A | B | LIM | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.30 | 0.30 | 0.42 | N/A | LIM | N/A | 250 | LIM | >299 | LIM | LIM | LIM | LIM | LIM | LIM | N/A |
| 9/L3 | Common Room Ring | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.22 | 0.22 | 0.32 | N/A | 0.13 | N/A | 250 | LIM | >299 | ✓ | 0.40 | 26.2 | 12.4 | ✓ | N/A | |
| 10/L3 | Hob | A | B | 1 | 10 | 6 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.08 | N/A | 250 | LIM | >299 | ✓ | 0.32 | 30.8 | 18.8 | ✓ | N/A | |
| 11/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 12/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 13/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 14/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 15/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 16/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 17/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider] | Designation: DB CL7/5-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL7, 5/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: 230 | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 19.4 ms (Above 30mA) | 30mA or below: 18.8 ms (if applicable)
 Z_s: 0.36 Ω | No. of poles: 2 | I_{pn}: 0.60 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L3 | Room 4 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.20 | N/A | 250 | LIM | >299 | ✓ | 0.72 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | | |
|--------------------------------------|---|-------------------|-------------|-------------|--|
| Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.: | |
| Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN | | | |

| | | | |
|---|--|---|---|
| Distribution board details - Complete in every case | Complete only if the distribution board is not connected directly to the origin of the installation | Characteristics at this distribution board | Test instrument serial number(s) |
| Location: Flat 6 Kitchen [Schneider] | Supply to distribution board is from: Sub Mains(BB 1, 11/L1) | Associated RCD(if any): BS (EN) N/A | Loop impedance: 080408/5657 |
| Designation: DB CL6 | Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V | Operating at 1 IΔn: N/A ms | Insulation resistance: 080408/5657 |
| Num. of ways: 18 Num. of phases: 1 | | No. of poles: N/A | Continuity: 080408/5657 |
| Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/> | | Operating at 5 IΔn: N/A ms | RCD: 080408/5657 |
| | | Time delay (if applicable): N/A | |

CIRCUIT DETAILS

TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|---|----------------|-------------|---------------|---|-------|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|--|--|------|------|--------------|-----------------|--|-------------------|------------------------|--------------|----------------------|-------------|----------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage | L/L, L/N | L/E, N/E | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | | | RCD (✓) | AFDD (✓) | | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | Fig 8 check (✓) | R1 + R2 | R2 | |
| | | | | | | | | | | | | | | | | | | Fig 8 check (✓) | R1 + R2 | R2 | V | | | M(Ω) | M(Ω) | | | | |
| 1/L1 | Common Room Lights | A | B | 9 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.44 | N/A | 250 | LIM | >299 | ✓ | 0.65 | 32.2 | 16.2 | ✓ | N/A | |
| 2/L1 | Lighting Room 8,9,10 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.35 | N/A | 250 | LIM | >299 | ✓ | 0.59 | 39.2 | 20.2 | ✓ | N/A | |
| 3/L1 | Lighting Room 3,5,7 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.48 | N/A | 250 | LIM | >299 | ✓ | 0.72 | 28.4 | 18.8 | ✓ | N/A | |
| 4/L1 | Lighting Room 1,2 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.31 | N/A | 250 | LIM | >299 | ✓ | 0.55 | 33.4 | 20.4 | ✓ | N/A | |
| 5/L1 | Lighting Room 4,6 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.42 | N/A | 250 | LIM | >299 | ✓ | 0.63 | 29.3 | 16.4 | ✓ | N/A | |
| 6/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 7/L1 | Sub Mains(DB CL6/7-2, DB CL6/7, DB CL6/7-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.33 | 0.33 | 0.52 | N/A | 0.21 | N/A | 250 | LIM | >299 | ✓ | 0.45 | 28.4 | 20.4 | ✓ | N/A | |
| 8/L1 | Sub Mains(DB CL6/8-2, DB CL6/8, DB CL6/8-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.29 | 0.29 | 0.35 | N/A | 0.16 | N/A | 250 | LIM | >299 | ✓ | 0.38 | 24.0 | 16.4 | ✓ | N/A | |
| 9/L1 | Sub Mains(DB CL6/9, DB CL6/9-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.28 | 0.25 | 0.32 | N/A | 0.15 | N/A | 250 | LIM | >299 | ✓ | 0.37 | 32.0 | 18.4 | ✓ | N/A | |
| 10/L1 | Sub Mains(DB CL6/10-1, DB CL6/10) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.31 | 0.31 | 0.42 | N/A | 0.18 | N/A | 250 | LIM | >299 | ✓ | 0.35 | 20.2 | 14.2 | ✓ | N/A | |
| 11/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 12/L1 | Common ring 1 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.31 | 0.31 | 0.40 | N/A | 0.18 | N/A | 250 | LIM | >299 | ✓ | 0.42 | 32.4 | 22.6 | ✓ | N/A | |
| 13/L1 | Common Ring 2 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.22 | 0.22 | 0.29 | N/A | 0.13 | N/A | 250 | LIM | >299 | ✓ | 0.37 | 34.6 | 25.4 | ✓ | N/A | |
| 14/L1 | Hob 1 | A | B | 1 | 10 | 6 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.31 | 29.6 | 22.5 | ✓ | N/A | |
| 15/L1 | Hob 2 | A | B | 1 | 10 | 6 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.35 | 25.4 | 19.8 | ✓ | N/A | |
| 16/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 5 Riser [Schneider] | Designation: DB CL6/8-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL6, 8/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 24.0 ms (Above 30mA) | 30mA or below: 16.4 ms (if applicable)
 Zs: 0.38 Ω | No. of poles: 2 | Ipf: 0.61 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|--|---------------|---------------|--------------|----------------------|-------------------|------------------------|------------------------------|----------|---------|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | | | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 |
| 1/L1 | Room 5 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.12 | N/A | 250 | LIM | >299 | ✓ | 0.52 | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Flat 11 Kitchen [Schneider]
 Designation: DB CL11
 Num. of ways: 18 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(BB 2, 15/L2)
 Overcurrent protective device for the distribution circuit: Type: gG | Rating: 63 A | Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) | Above 30mA (if applicable): N/A ms
 Operating at 1 IΔn: N/A | 30mA or below: N/A ms
 Zs: 0.28 Ω | No. of poles: N/A
 Ipr: 0.87 kA | IΔn: N/A | Operating at 5 IΔn: N/A ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|--|----------------|-------------|---------------|---|-------|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|--|--|------|------|-----------------|---|--|---------------|---------------|--------------|----------------------|-------------------|------------------------|------------------------------|----------|---------|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | | | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | APDD (✓) | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 |
| 1/L2 | Common Room Lights | A | B | 9 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.27 | | 250 | LIM | >299 | ✓ | 0.56 | 28.8 | 20.0 | ✓ | N/A |
| 2/L2 | Lighting Rooms 1,3,5 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.47 | | 250 | LIM | >299 | ✓ | 0.73 | 32.4 | 18.8 | ✓ | N/A |
| 3/L2 | Lighting Rooms 2,4,6 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.52 | | 250 | LIM | >299 | ✓ | 0.80 | 42.4 | 22.4 | ✓ | N/A |
| 4/L2 | Lighting Rooms 7,8 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.33 | | 250 | LIM | >299 | ✓ | 0.56 | 38.8 | 19.4 | ✓ | N/A |
| 5/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 6/L2 | Sub Mains(DB CL11/6-2, DB CL11/6, DB CL11/6-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.38 | 0.36 | 0.42 | N/A | 0.20 | | 250 | LIM | >299 | ✓ | 0.42 | 34.5 | 18.4 | ✓ | N/A |
| 7/L2 | Sub Mains(DB CL11/7, DB CL11/7-1, DB CL11/7-2) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.35 | 0.35 | 0.46 | N/A | 0.20 | | 250 | LIM | >299 | ✓ | 0.42 | 28.8 | 20.6 | ✓ | N/A |
| 8/L2 | Sub Mains(DB CL11/8, DB CL11/8-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.26 | 0.26 | 0.33 | N/A | 0.15 | | 250 | LIM | >299 | ✓ | 0.38 | 24.2 | 16.8 | ✓ | N/A |
| 9/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 10/L2 | Common Room Ring 1 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.41 | 0.41 | 0.55 | N/A | 0.24 | | 250 | LIM | >299 | ✓ | 0.45 | 29.2 | 18.8 | ✓ | N/A |
| 11/L2 | Common Room Ring 2 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.35 | 0.35 | 0.42 | N/A | 0.19 | | 250 | LIM | >299 | ✓ | 0.39 | 31.8 | 18.6 | ✓ | N/A |
| 12/L2 | Hob 1 | A | B | 1 | 10 | 6 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.10 | | 250 | LIM | >299 | ✓ | 0.35 | 42.4 | 20.4 | ✓ | N/A |
| 13/L2 | Hob 2 | A | B | 1 | 10 | 6 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.12 | | 250 | LIM | >299 | ✓ | 0.39 | 38.6 | 18.2 | ✓ | N/A |
| 14/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 15/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 16/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 17/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser [Schneider] | Designation: DB CL11/6 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL11, 6/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 34.5 ms (Above 30mA) | 18.4 ms (30mA or below)
 Z_s: 0.42 Ω | No. of poles: 2 | I_{pn}: 0.55 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| 1/L2 | Room 1 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.33 | N/A | 250 | LIM | >299 | ✓ | 0.63 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser [Schneider] | Designation: DB CL11/7 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL11, 7/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 28.8 ms (Above 30mA) | 30mA or below: 20.6 ms (if applicable)
 Z_s: 0.42 Ω | No. of poles: 2 | I_{pn}: 0.57 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|-----|--|---------------|---------------|--------------|----------------------------------|-------------------|------------------------|------------------------------|----------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | | | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | R1 + R2 | R2 | | | | | | | | | | | |
| 1/L2 | Room 2 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.14 | N/A | 250 | LIM | >299 | ✓ | 0.52 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 3 Riser [Schneider] | Designation: DB CL11/6-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL11, 6/L2)
 Overcurrent protective device for the distribution circuit: Type: | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 34.5 ms (Above 30mA) | 30mA or below: 18.4 ms (if applicable)
 Z_s: 0.42 Ω | No. of poles: 2 | I_{pn}: 0.55 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L2 | Room 3 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.55 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 5 Riser [Schneider] | Designation: DB CL11/6-2 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL11, 6/L2)
 Overcurrent protective device for the distribution circuit: Type: | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 34.5 ms (Above 30mA) | 30mA or below: 18.4 ms
 Zs: 0.42 Ω | No. of poles: 2 | Ipf: 0.55 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| 1/L2 | Room 5 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.12 | N/A | 250 | LIM | >299 | ✓ | 0.50 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider]
 Designation: DB CL11/7-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL11, 7/L2)
 Overcurrent protective device for the distribution circuit: Type: | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 28.8 ms (Above 30mA) | 30mA or below: 20.6 ms (if applicable)
 Z_s: 0.42 Ω | No. of poles: 2 | I_{pn}: 0.57 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L2 | Room 4 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.08 | N/A | 250 | LIM | >299 | ✓ | 0.50 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 6 Riser [Schneider]
 Designation: DB CL11/7-2
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL11, 7/L2)
 Overcurrent protective device for the distribution circuit: Type: | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 28.8 ms (Above 30mA) | 30mA or below: 20.6 ms (if applicable)
 Z_s: 0.42 Ω | No. of poles: 2 | I_{pn}: 0.57 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L2 | Room 6 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.14 | N/A | 250 | LIM | >299 | ✓ | 0.55 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser [Schneider] | Designation: DB CL11/8-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL11, 8/L2)
 Overcurrent protective device for the distribution circuit: Type: | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 24.2 ms (Above 30mA) | 30mA or below: 16.8 ms (if applicable)
 Z_s: 0.38 Ω | No. of poles: 2 | I_{pr}: 0.61 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5657 | Insulation resistance: 080408/5657 | Continuity: 080408/5657 | RCD: 080408/5657

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|--|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | | |
| 1/L2 | Room 8 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.52 | N/A | N/A | N/A | N/A | N/A | N/A | |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | |
|--|---|-------------------------|-------------------------|-------------------|
| Company Name PHS Compliance | Company Address Kid Glove Road | Postcode WA3 3GR | Branch No. | Scheme No. |
| Client UPP Residential Services Ltd | Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | | Postcode SA1 8EN | |

| | | | |
|---|--|--|---|
| Distribution board details - Complete in every case | Complete only if the distribution board is not connected directly to the origin of the installation | Characteristics at this distribution board | Test instrument serial number(s) |
| Location: Flat 10 Kitchen [Schneider] | Supply to distribution board is from: Sub Mains(BB 2, 14/L1) | Associated RCD(if any): BS (EN) N/A | Loop impedance: 080408/5756 |
| Designation: DB CL10 | Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage V | Operating at 1 IΔn Above 30mA (if applicable) N/A ms | Insulation resistance: 080408/5756 |
| Num. of ways: 18 Num. of phases: 1 | | No. of poles: N/A | Continuity: 080408/5756 |
| Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/> | | Operating at 5 IΔn N/A ms | RCD: 080408/5756 |
| | | Time delay (if applicable): N/A | |

CIRCUIT DETAILS

TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | |
|--------------------------|--|----------------|-------------|---------------|---|-------|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|--|--|------|------|----------------|---------------|---------------|--|------------------------|---------|--------------|----------------------|-------------|-----------------|---|-----|
| | | | | | L / N | CPC | Maximum disconnection | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | | | APDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | |
| 1/L1 | Common Room Lights | A | B | 9 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.33 | N/A | 250 | LIM | >299 | ✓ | 0.56 | 20.4 | 19.8 | ✓ | N/A |
| 2/L1 | Lighting Room 1,2 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.25 | N/A | 250 | LIM | >299 | ✓ | 0.52 | 34.6 | 25.4 | ✓ | N/A |
| 3/L1 | Lighting Room 3,4,5 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.38 | N/A | 250 | LIM | >299 | ✓ | 0.61 | 28.5 | 18.8 | ✓ | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 5/L1 | Sub Mains(DB CL10/5-1, DB CL10/5) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.29 | 0.27 | 0.31 | N/A | 0.15 | N/A | 250 | LIM | >299 | ✓ | 0.34 | 22.4 | 19.8 | ✓ | N/A |
| 6/L1 | Sub Mains(DB CL10/6-2, DB CL10/6, DB CL10/6-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.34 | 0.34 | 0.40 | N/A | 0.19 | N/A | 250 | LIM | >299 | ✓ | 0.45 | 25.4 | 18.2 | ✓ | N/A |
| 7/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 8/L1 | Common Room Ring 1 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.41 | 0.37 | 0.48 | N/A | 0.23 | N/A | 250 | LIM | >299 | ✓ | 0.46 | 29.4 | 24.2 | ✓ | N/A |
| 9/L1 | Common Room Ring 2 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.38 | 0.35 | 0.42 | N/A | 0.20 | N/A | 250 | LIM | >299 | ✓ | 0.40 | 18.4 | 14.0 | ✓ | N/A |
| 10/L1 | Hob | A | B | 1 | 10 | 6 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.14 | N/A | 250 | LIM | >299 | ✓ | 0.39 | 32.6 | 18.6 | ✓ | N/A |
| 11/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 12/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 13/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 14/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 15/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 16/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 17/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser [Schneider]
 Designation: DB CL10/5
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL10, 5/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 22.4 ms (Above 30mA) | 30mA or below: 19.8 ms (if applicable)
 Zs: 0.34 Ω | No. of poles: 2 | Ipf: 0.68 kA | IΔn: 30 | Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| 1/L1 | Room 1 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.11 | N/A | 250 | LIM | >299 | ✓ | 0.45 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider]
 Designation: DB CL10/6-1
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL10, 6/L1)
 Overcurrent protective device for the distribution circuit: Type: | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 25.4 ms (Above 30mA) | 30mA or below: 18.2 ms (if applicable)
 Z_s: 0.45 Ω | No. of poles: 2 | I_{pn}: 0.51 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 |
| 1/L1 | Room 4 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.18 | N/A | 250 | LIM | >299 | ✓ | 0.55 | N/A | N/A | N/A | N/A | |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | |
|---|---|--|---------------------------------|---|
| Company Name PHS Compliance | Company Address Kid Glove Road | Postcode WA3 3GR | Branch No. | Scheme No. |
| Client UPP Residential Services Ltd | Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | | Postcode SA1 8EN | |
| Distribution board details - Complete in every case | | Complete only if the distribution board is not connected directly to the origin of the installation | | Characteristics at this distribution board |
| Location: Flat 9 Kitchen [Schneider] | Designation: DB CL9 | Supply to distribution board is from: Sub Mains(BB 1, 14/L2) | Associated RCD(if any): BS (EN) | Above 30mA (if applicable) ms |
| Num. of ways: 18 | Num. of phases: 1 | Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage V | Operating at 1 IΔn N/A | 30mA or below |
| Supply polarity confirmed <input checked="" type="checkbox"/> | Phase sequence confirmed <input type="checkbox"/> | | Operating at 5 IΔn N/A | ms |
| | | | Time delay (if applicable) N/A | |
| Test instrument serial number(s) | | | | |
| Loop impedance 080408/5756 | | | | |
| Insulation resistance 080408/5756 | | | | |
| Continuity 080408/5756 | | | | |
| RCD 080408/5756 | | | | |

CIRCUIT DETAILS

TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|---|----------------|-------------|---------------|---|-------|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|--|--|------|------|--------------|----------|--|-------------------|------------------------|--------------|----------------------|-------------|----------|------------------------------|---|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage | L/L, L/N | L/E, N/E | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | | | RCD (✓) | AFDD (✓) | | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | Fig 8 (✓) | All circuits to be completed using R1R2 or R2, not both | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1/L2 | Common room Lights | A | B | 9 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.43 | | 250 | LIM | >299 | ✓ | 0.70 | 42.4 | 24.0 | ✓ | N/A | |
| 2/L2 | Lighting Rooms 8,9,10 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.38 | | 250 | LIM | >299 | ✓ | 0.65 | 36.4 | 22.4 | ✓ | N/A | |
| 3/L2 | Lighting Rooms 3,5,7 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.52 | | 250 | LIM | >299 | ✓ | 0.75 | 30.8 | 18.0 | ✓ | N/A | |
| 4/L2 | Lighting Rooms 1,2 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.46 | | 250 | LIM | >299 | ✓ | 0.70 | 36.2 | 20.4 | ✓ | N/A | |
| 5/L2 | Lighting 4,6 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.38 | | 250 | LIM | >299 | ✓ | 0.64 | 28.4 | 16.4 | ✓ | N/A | |
| 6/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | | N/A | N/A |
| 7/L2 | Sub Mains(DB CL9/7-2, DB CL9/7, DB CL9/7-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.42 | 0.42 | 0.55 | N/A | 0.24 | | 250 | LIM | >299 | ✓ | 0.49 | 22.5 | 19.8 | ✓ | N/A | |
| 8/L2 | Sub Mains(DB CL9/8-2, DB CL9/8, DB CL9/8-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.39 | 0.39 | 0.53 | N/A | 0.23 | | 250 | LIM | >299 | ✓ | 0.46 | 30.4 | 22.1 | ✓ | N/A | |
| 9/L2 | Sub Mains(DB CL9/9-1, DB CL9/9) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.28 | 0.28 | 0.34 | N/A | 0.16 | | 250 | LIM | >299 | ✓ | 0.37 | 28.4 | 14.4 | ✓ | N/A | |
| 10/L2 | Sub Mains(DB CL9/10-1, DB CL9/10) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.24 | 0.24 | 0.35 | N/A | 0.15 | | 250 | LIM | >299 | ✓ | 0.35 | 32.4 | 18.6 | ✓ | N/A | |
| 11/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | | N/A | N/A |
| 12/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | | N/A | N/A |
| 13/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | | N/A | N/A |
| 14/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | | N/A | N/A |
| 15/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | | N/A | N/A |
| 16/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 10 Riser [Schneider]
 Designation: DB CL9/7-2
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL9, 7/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 22.5 ms (Above 30mA) | 30mA or below: 19.8 ms (if applicable)
 Zs: 0.49 Ω | No. of poles: 2 | Ipf: 0.47 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 |
| | | | | | 80% | (Ω) | | (Ω) | (Ω) | (Ω) | | | | (Ω) | (Ω) | | | | | | | | | | | | | |
| 1/L2 | Room 10 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.59 | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser [Schneider]
 Designation: DB CL9/9
 Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL9, 9/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 28.4 ms (Above 30mA) | 14.4 ms (30mA or below)
 Z_s: 0.37 Ω | No. of poles: 2 | I_{pr}: 0.62 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| 1/L2 | Room 1 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.11 | N/A | 250 | LIM | >299 | ✓ | 0.49 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR **110148205**



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name Company Address Postcode Branch No. Scheme No.
 Client Installation Address Postcode

Distribution board details - Complete in every case
 Location
 Designation
 Num. of ways Num. of phases
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from
 Overcurrent protective device for the distribution circuit: Type Rating A Voltage
 BS(EN)

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) Operating at 1 IΔn ms Above 30mA (if applicable)
 Zs Ω No. of poles 30mA or below
 Ipr kA IΔn Operating at 5 IΔn ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance
 Insulation resistance
 Continuity
 RCD

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | rn | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L2 | Room 2 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.14 | N/A | 250 | LIM | >299 | ✓ | 0.62 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider] | Designation: DB CL9/10 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL9, 10/L2)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 32.4 ms (Above 30mA) | 18.6 ms (30mA or below)
 Z_s: 0.35 Ω | No. of poles: 2 | I_{pn}: 0.66 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L2 | Room 4 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.17 | N/A | 250 | LIM | >299 | ✓ | 0.58 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To 05/07/2022 Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Flat 14 Kitchen [Schneider]
 Designation: DB CL14
 Num. of ways: 18 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(BB 2, 19/L3)
 Overcurrent protective device for the distribution circuit: Type: gG | Rating: 63 A | Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) | Above 30mA (if applicable): N/A ms
 Operating at 1 I_{Δn}: N/A | 30mA or below: N/A ms
 Z_s: 0.22 Ω | No. of poles: N/A
 I_{pr}: 1.1 kA | I_{Δn}: N/A | Operating at 5 I_{Δn}: N/A ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | |
|--------------------------|--|----------------|-------------|---------------|---|-------|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|--|--|------|------|----------------|---------------|--|-------------------------------|------------------------------------|--------------|----------------------|-------------|----------|------------------------------|---|
| | | | | | L / N | CPC | Maximum disconnection | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA I _{Δn} ms | 30mA or below 5 I _{Δn} ms | | | RCD (✓) | APDD (✓) | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both |
| | | | | | | | | | | | | | | R1 + R2 | R2 | | | | | | | | | | | | |
| 1/L3 | Common Room Ring | A | B | 9 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.30 | 250 | LIM | >299 | ✓ | 0.55 | 21.4 | 16.2 | ✓ | N/A |
| 2/L3 | Lighting Room 1,3,5 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.36 | 250 | LIM | >299 | ✓ | 0.58 | 22.5 | 18.4 | ✓ | N/A |
| 3/L3 | Lighting Room 2,4,6 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.41 | 250 | LIM | >299 | ✓ | 0.46 | 28.4 | 14.4 | ✓ | N/A |
| 4/L3 | Lighting Room 7,8 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.39 | 250 | LIM | >299 | ✓ | 0.71 | 24.4 | 12.5 | ✓ | N/A |
| 5/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | N/A | | | | N/A | N/A |
| 6/L3 | Sub Mains(DB CL14/6-2, DB CL14/6, DB CL14/6-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.32 | 0.32 | 0.40 | N/A | 0.18 | 250 | LIM | >299 | ✓ | 0.38 | 29.2 | 20.0 | ✓ | N/A |
| 7/L3 | Sub Mains(DB CL14/7-2, DB CL14/7, DB CL14/7-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.35 | 0.35 | 0.44 | N/A | 0.20 | 250 | LIM | >299 | ✓ | 0.44 | 32.4 | 18.2 | ✓ | N/A |
| 8/L3 | Sub Mains(DB CL14/8-1, DB CL14/8) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.25 | 0.25 | 0.32 | N/A | 0.14 | 250 | LIM | >299 | ✓ | 0.37 | 29.4 | 14.4 | ✓ | N/A |
| 9/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | N/A | | | | N/A | N/A |
| 10/L3 | Common Room Rong | A | B | 4 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.44 | 0.42 | 0.51 | N/A | 0.24 | 250 | LIM | >299 | ✓ | 0.44 | 23.4 | 12.2 | ✓ | N/A |
| 11/L3 | Common Room Ring 2 | A | B | 4 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.39 | 0.42 | 0.48 | N/A | 0.22 | 250 | LIM | >299 | ✓ | 0.50 | 32.2 | 16.4 | ✓ | N/A |
| 12/L3 | Hob 1 | A | B | 1 | 10 | 6 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.11 | 250 | LIM | >299 | ✓ | 0.37 | 30.8 | 20.8 | ✓ | N/A |
| 13/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | N/A | | | | N/A | N/A |
| 14/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | N/A | | | | N/A | N/A |
| 15/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | N/A | | | | N/A | N/A |
| 16/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | N/A | | | | N/A | N/A |
| 17/L3 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | N/A | | | | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position: Electrical Test Engineer Date: 05/07/2022 Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 1 Riser [Schneider] | Designation: DB CL14/6 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL14, 6/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 29.2 ms (Above 30mA) | 20.0 ms (30mA or below)
 Z_s: 0.38 Ω | No. of poles: 2 | I_{pr}: 0.61 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| 1/L3 | Room 1 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.21 | N/A | 250 | LIM | >299 | ✓ | 0.44 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name Company Address Postcode Branch No. Scheme No.
 Client Installation Address Postcode

Distribution board details - Complete in every case
 Location
 Designation
 Num. of ways Num. of phases
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from
 Overcurrent protective device for the distribution circuit: Type Rating A Voltage V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn ms
 Z_s Ω No. of poles 30mA or below
 I_{pn} kA IΔn Operating at 5 IΔn ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance
 Insulation resistance
 Continuity
 RCD

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L3 | Room 3 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.11 | N/A | 250 | LIM | >299 | ✓ | 0.51 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 2 Riser [Schneider] | Designation: DB CL14/7 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL14, 7/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 29.2 ms (Above 30mA) | 30mA or below: 20.0 ms (if applicable)
 Z_s: 0.44 Ω | No. of poles: 2 | I_{pn}: 0.52 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L3 | Room 2 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.55 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 4 Riser [Schneider] | Designation: DB CL14/7-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL14, 7/L3)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) 61009 | Operating at 1 IΔn: 29.2 ms (Above 30mA) | 30mA or below: 20.0 ms (if applicable)
 Z_s: 0.44 Ω | No. of poles: 2 | I_{pn}: 0.52 kA | IΔn: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L/N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| 1/L3 | Room 4 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.14 | N/A | 250 | LIM | >299 | ✓ | 0.58 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name Company Address Postcode Branch No. Scheme No.
 Client Installation Address Postcode

Distribution board details - Complete in every case
 Location
 Designation
 Num. of ways Num. of phases
 Supply polarity confirmed Phase sequence confirmed

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from
 Overcurrent protective device for the distribution circuit: Type Rating A Voltage
 BS(EN)

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) Operating at 1 IΔn ms Above 30mA (if applicable)
 Z_s Ω No. of poles 30mA or below
 I_{pn} kA IΔn Operating at 5 IΔn ms
 Time delay (if applicable)

Test instrument serial number(s)
 Loop impedance
 Insulation resistance
 Continuity
 RCD

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFDD (✓) | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | |
| 1/L3 | Room 7 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.14 | N/A | 250 | LIM | >299 | ✓ | 0.58 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing To Date(s) live testing To

Tested by: Name (capital letters) Position Date Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | | |
|--------------------------------------|---|-------------------|-------------|-------------|--|
| Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.: | |
| Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN | | | |

| | | | |
|---|--|---|---|
| Distribution board details - Complete in every case | Complete only if the distribution board is not connected directly to the origin of the installation | Characteristics at this distribution board | Test instrument serial number(s) |
| Location: Flat 13 Kitchen [Schneider] | Supply to distribution board is from: Sub Mains(BB 1, 15/L3) | Associated RCD(if any): BS (EN) N/A | Loop impedance: 080408/5756 |
| Designation: DB CL13 | Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage V | Operating at 1 IΔn: N/A ms | Insulation resistance: 080408/5756 |
| Num. of ways: 18 Num. of phases: 1 | | 30mA or below: N/A ms | Continuity: 080408/5756 |
| Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/> | | Operating at 5 IΔn: N/A ms | RCD: 080408/5756 |
| | | Time delay (if applicable): N/A | |

CIRCUIT DETAILS

TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-------|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|--|--|------|------|----------------|---------------|---------------|--|------------------------|---------|--------------|----------------------|-------------|-----------------|------------------------------|-----|-----|
| | | | | | L / N | CPC | Maximum disconnection | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | | | APDD (✓) | | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | Fig 8 check (✓) | R1 + R2 | R2 | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1/L3 | Common Room Lights | A | B | 9 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.53 | N/A | 250 | LIM | >299 | ✓ | 0.75 | 28.2 | 20.2 | ✓ | N/A | |
| 2/L3 | Lighting Room 1,2 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.48 | N/A | 250 | LIM | >299 | ✓ | 0.70 | 30.0 | 18.2 | ✓ | N/A | |
| 3/L3 | Lighting Rooms 3,4,5 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.56 | N/A | 250 | LIM | >299 | ✓ | 0.76 | 24.4 | 16.6 | ✓ | N/A | |
| 4/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 5/L3 | Isolated | A | B | LIM | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | LIM | N/A | 250 | LIM | >299 | LIM | LIM | LIM | LIM | LIM | LIM | N/A |
| 6/L3 | Isolated | A | B | LIM | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | LIM | N/A | 250 | LIM | >299 | LIM | LIM | LIM | LIM | LIM | LIM | N/A |
| 7/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 8/L3 | Common Room Ring | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.28 | 0.28 | 0.33 | N/A | 0.15 | N/A | 250 | LIM | >299 | ✓ | 0.36 | 19.8 | 14.4 | ✓ | N/A | |
| 9/L3 | Common Room Ring 2 | A | B | 5 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.32 | 0.32 | 0.45 | N/A | 0.19 | N/A | 250 | LIM | >299 | ✓ | 0.40 | 22.4 | 20.0 | ✓ | N/A | |
| 10/L3 | Hob | A | B | 1 | 10 | 6 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.12 | N/A | 250 | LIM | >299 | ✓ | 0.35 | 28.4 | 25.4 | ✓ | N/A | |
| 11/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 12/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 13/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 14/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 15/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 16/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 17/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 18/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | |
|--------------------------------------|---|-------------------|-------------|-------------|
| Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.: |
| Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN | | |

| | | | |
|---|--|---|---|
| Distribution board details - Complete in every case | Complete only if the distribution board is not connected directly to the origin of the installation | Characteristics at this distribution board | Test instrument serial number(s) |
| Location: Flat 12 Kitchen [Schneider] | Supply to distribution board is from: Sub Mains(BB 1, 18/L1) | Associated RCD(if any): BS (EN) N/A | Loop impedance: 080408/5756 |
| Designation: DB CL12 | Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage V | Operating at 1 IΔn: N/A ms | Insulation resistance: 080408/5756 |
| Num. of ways: 18 Num. of phases: 1 | BS(EN) 88-2 HRC | 30mA or below: N/A ms | Continuity: 080408/5756 |
| Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/> | | Operating at 5 IΔn: N/A ms | RCD: 080408/5756 |
| | | Time delay (if applicable): N/A | |

CIRCUIT DETAILS

TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
|--------------------------|--|----------------|-------------|---------------|---|-------|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|--|--|------|------|--------------|----------|--|----------------|---------------------|--------------|----------------------|-------------|----------|------------------------------|---|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage | L/L, L/N | L/E, N/E | Above 30mA IΔn | 30mA or below 5 IΔn | | | RCD (✓) | APDD (✓) | | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | Fig 8 (✓) | All circuits to be completed using R1R2 or R2, not both | | |
| | | | | | | | | R1 + R2 | | R2 | | | | | | | | | | | | | | | | | | | |
| 1/L1 | Common Room Lights | A | B | 9 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.34 | N/A | 250 | LIM | >299 | ✓ | 0.56 | 32.2 | 22.4 | ✓ | N/A | |
| 2/L1 | Lighting Room 8,9,10 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.31 | N/A | 250 | LIM | >299 | ✓ | 0.60 | 30.4 | 20.2 | ✓ | N/A | |
| 3/L1 | Lighting Room 3,5,7 | A | B | 12 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.36 | N/A | 250 | LIM | >299 | ✓ | 0.59 | 29.2 | 18.4 | ✓ | N/A | |
| 4/L1 | Lighting Room 1,2 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.34 | N/A | 250 | LIM | >299 | ✓ | 0.59 | 31.4 | 22.4 | ✓ | N/A | |
| 5/L1 | Lighting Room 4,6 | A | B | 8 | 1.5 | 1 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.38 | N/A | 250 | LIM | >299 | ✓ | 0.60 | 33.6 | 20.4 | ✓ | N/A | |
| 6/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 7/L1 | Sub Mains(DB CL12/7-2, DB CL12/7, DB CL12/7-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.30 | 0.30 | 0.38 | N/A | 0.17 | N/A | 250 | LIM | >299 | ✓ | 0.40 | 29.4 | 18.4 | ✓ | N/A | |
| 8/L1 | Sub Mains(DB CL12/8-2, DB CL12/8, DB CL12/8-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.35 | 0.35 | 0.44 | N/A | 0.20 | N/A | 250 | LIM | >299 | ✓ | 0.41 | 26.4 | 20.2 | ✓ | N/A | |
| 9/L1 | Sub Mains(DB CL12/9-1, DB CL12/9) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.29 | 0.29 | 0.39 | N/A | 0.17 | N/A | 250 | LIM | >299 | ✓ | 0.39 | 32.2 | 18.8 | ✓ | N/A | |
| 10/L1 | Sub Mains(DB CL12/10, DB CL12/10-1) | A | B | 1 | 2x2.5 | 2x1.5 | 5 | 61009 RCD/RCBO | C | 32 | 10 | 30 | 0.54 | 0.26 | 0.26 | 0.37 | N/A | 0.16 | N/A | 250 | LIM | >299 | ✓ | 0.42 | 30.4 | 16.6 | ✓ | N/A | |
| 11/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 12/L1 | Common Room Ring 1 | A | B | 10 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.28 | 0.28 | 0.44 | N/A | 0.18 | N/A | 250 | LIM | >299 | ✓ | 0.49 | 32.5 | 20.4 | ✓ | N/A | |
| 13/L1 | Common Room Ring 2 | A | B | 10 | 2x2.5 | 2x1.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | 0.34 | 0.34 | 0.47 | N/A | 0.20 | N/A | 250 | LIM | >299 | ✓ | 0.43 | 40.2 | 18.4 | ✓ | N/A | |
| 14/L1 | Hob 2 | A | B | 1 | 10 | 6 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.11 | N/A | 250 | LIM | >299 | ✓ | 0.45 | 36.4 | 22.4 | ✓ | N/A | |
| 15/L1 | Hob1 | A | B | 1 | 10 | 6 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | 0.15 | N/A | 250 | LIM | >299 | ✓ | 0.49 | 32.5 | 20.2 | ✓ | N/A | |
| 16/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 8 Riser [Schneider] | Designation: DB CL12/7 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL12, 7/L1)
 Overcurrent protective device for the distribution circuit: Type: C | Rating: 32 | A | Voltage: V

Characteristics at this distribution board
 Associated RCD (if any): BS (EN) | Operating at 1 I_{Δn}: 29.4 ms (Above 30mA) | 18.4 ms (30mA or below)
 Z_s: 0.40 Ω | No. of poles: | I_{pf}: kA | I_{Δn}: 30 | Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 | Continuity: 080408/5756 | RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------------------|--------------|----------------------------------|------------------------------------|---------|------------------------------|---------|-----|-----|--|--|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA I _{Δn} ms | | | 30mA or below 5 I _{Δn} ms | RCD (✓) | AFCD (✓) | | | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | | | |
| 1/L1 | Room 8 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.78 | N/A | N/A | N/A | N/A | N/A | N/A | | |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | | |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | | |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | |
|--|---|-------------------------|-------------------|-------------------|
| Company Name PHS Compliance | Company Address Kid Glove Road | Postcode WA3 3GR | Branch No. | Scheme No. |
| Client UPP Residential Services Ltd | Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode SA1 8EN | | |

| | | | | | | | |
|--|--|--|---|---|-----------------------------|---|------------------------------------|
| Distribution board details - Complete in every case | | Complete only if the distribution board is not connected directly to the origin of the installation | | Characteristics at this distribution board | | Test instrument serial number(s) | |
| Location: Room 9 Riser [Schneider] | Designation: DB CL12/7-1 | Supply to distribution board is from: Sub Mains(DB CL12, 7/L1) | Overcurrent protective device for the distribution circuit: Type: BS(EN) Rating: A Voltage: V | Associated RCD(if any): BS (EN) 61009 | Operating at 1 IΔn: 29.4 ms | Loop impedance: 080408/5756 | Insulation resistance: 080408/5756 |
| Num. of ways: 4 | Num. of phases: 1 | | | Z _s : 0.40 Ω | No. of poles: 2 | Continuity: 080408/5756 | RCD: 080408/5756 |
| Supply polarity confirmed: <input checked="" type="checkbox"/> | Phase sequence confirmed: <input type="checkbox"/> | | | I _{pf} : 0.57 kA | IΔn: 30 | | |
| | | | | | Operating at 5 IΔn: 18.4 ms | | |
| | | | | | Time delay (if applicable): | | |

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|--|---------------|---------------|--------------|----------------------------------|-------------------|------------------------|------------------------------|----------|---------|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | | | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 |
| 1/L1 | Room 9 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.55 | N/A | N/A | N/A | N/A |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 05/07/2022 To 05/07/2022 Date(s) live testing 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 05/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Room 6 Riser [Schneider] | Designation: DB CL12/10-1 | Num. of ways: 4 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains (DB CL12, 10/L1)
 Overcurrent protective device for the distribution circuit: Type: BS(EN) | Rating: | A | Voltage: | V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) | Operating at 1 IΔn: | ms | Above 30mA (if applicable)
 Z_s: 0.42 Ω | No. of poles: | 30mA or below
 I_{pf}: 0.54 kA | IΔn: | Operating at 5 IΔn: | ms
 Time delay (if applicable): |

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Z _s Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Z _s (Ω) | RCD testing | | Manual test button operation | | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|----------------|-----|-----------------|---|----------------|--|---------------|-------------------|--------------|----------------------------------|------------------------|---------|------------------------------|---------|-----|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | | | 30mA or below 5 IΔn ms | RCD (✓) | AFCD (✓) | | | | |
| | | | | | | | | | | | | | | r1 | r _n | r2 | | | | | | | | | | | | R1 + R2 | R2 | | |
| | | | | | 80% | r1 | | r _n | r2 | (✓) | | | | R1 + R2 | R2 | V | M(Ω) | M(Ω) | (✓) | (✓) | | | | | | | | | | | |
| 1/L1 | Room 6 Sockets | A | B | 6 | 2.5 | 1.5 | 0.4 | 60898 MCB | B | 10 | 6 | N/A | 3.49 | N/A | N/A | N/A | N/A | 0.15 | N/A | 250 | LIM | >299 | ✓ | 0.59 | N/A | N/A | N/A | N/A | N/A | N/A | |
| 2/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 3/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |
| 4/L1 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: | Date(s) dead testing: 05/07/2022 To 05/07/2022 | Date(s) live testing: 05/07/2022 To 05/07/2022

Tested by: Name (capital letters) LIAM KIMBLE | Position: Electrical Test Engineer | Date: 05/07/2022 | Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance Company Address: Kid Glove Road Postcode: WA3 3GR Branch No.: Scheme No.:
 Client: UPP Residential Services Ltd Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Plant Room [Schneider] Designation: DB PL Num. of ways: 24 Num. of phases: 3
 Supply polarity confirmed: Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(BB 2, 18/TP)
 Overcurrent protective device for the distribution circuit: Type: gG Rating: 63 A Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) Above 30mA (if applicable) Operating at 1 IΔn: N/A ms
 Zs: 0.18 Ω No. of poles: 30mA or below Ipf: kA IΔn: N/A Operating at 5 IΔn: N/A ms
 Time delay (if applicable):

Test instrument serial number(s)
 Loop impedance: 080408/5657 Insulation resistance: 080408/5657 Continuity: 080408/5657 RCD: 080408/5657

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-------|-----------------------|--------------------------------|-----------------|---|------------------------|--------------------|--|--|-----|-----|----------------|---------------|---------------|--|------------------------|---------|--------------|----------------------|-------------|------|------------------------------|-----|-----|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | | | APDD (✓) | | | | |
| | | | | | r1 | rn | | r2 | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | | | | R1 + R2 | R2 | | | | | | | | | | | | | | |
| 1/L1 | Ext Fan 1 | D | B | 1 | 2.5 | 2.5 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | 250 | LIM | >299 | LIM | LIM | 32.5 | 18.4 | ✓ | N/A | |
| 1/L2 | Ext Fan 2 | D | B | 1 | 2.5 | 2.5 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | 250 | LIM | >299 | LIM | LIM | 34.6 | 22.6 | ✓ | N/A | |
| 1/L3 | Ext Fan 3 | D | B | 1 | 2.5 | 2.5 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | 250 | LIM | >299 | LIM | LIM | 26.4 | 18.4 | ✓ | N/A | |
| 2/L1 | Ext Fan 4 | D | B | 1 | 2.5 | 2.5 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | 250 | LIM | >299 | LIM | LIM | 28.4 | 20.4 | ✓ | N/A | |
| 2/L2 | Isolated | D | B | LIM | 2.5 | 2.5 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | 250 | LIM | >299 | LIM | LIM | LIM | LIM | LIM | N/A | N/A |
| 2/L3 | Ext Fan 6 | D | B | 1 | 2.5 | 2.5 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | 250 | LIM | >299 | LIM | LIM | 32.2 | 20.2 | ✓ | N/A | |
| 3/L1 | Ext Fan 7 | D | B | 1 | 2.5 | 2.5 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | 250 | LIM | >299 | LIM | LIM | 30.6 | 22.6 | ✓ | N/A | |
| 3/L2 | Ext Fan 8 | D | B | 1 | 2.5 | 2.5 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | 250 | LIM | >299 | LIM | LIM | 38.4 | 18.4 | ✓ | N/A | |
| 3/L3 | Ext Fan 9 | D | B | 1 | 2.5 | 2.5 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | 250 | LIM | >299 | LIM | LIM | 32.6 | 20.4 | ✓ | N/A | |
| 4/L1 | Ext Fan 10 | D | B | 1 | 2.5 | 2.5 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | 250 | LIM | >299 | LIM | LIM | 36.8 | 18.4 | ✓ | N/A | |
| 4/L2 | Ext Fan 11 | D | B | 1 | 2.5 | 2.5 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | 250 | LIM | >299 | LIM | LIM | 25.6 | 19.8 | ✓ | N/A | |
| 4/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 5/L1 | Plant ring | D | B | 4 | 2x2.5 | 2x2.5 | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | LIM | N/A | 250 | LIM | >299 | ✓ | LIM | 29.8 | 20.4 | ✓ | N/A | |
| 5/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 5/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 6/L1 | FA Interface | O | B | 1 | 2.5 | 2.5 | 0.4 | 60898 MCB | B | 6 | 10 | N/A | 5.82 | N/A | N/A | N/A | N/A | LIM | N/A | LIM | LIM | LIM | ✓ | 0.44 | N/A | N/A | N/A | N/A | |
| 6/L2 | Plant Room Lights | D | B | 4 | 1.5 | 1.5 | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | 0.32 | N/A | 250 | LIM | >299 | ✓ | 0.62 | 32.2 | 18.8 | ✓ | N/A | |
| 6/L3 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 05/07/2022 To: 05/07/2022 Date(s) live testing: 05/07/2022 To: 05/07/2022
 Tested by: Name (capital letters): LIAM KIMBLE Position: Electrical Test Engineer Date: 05/07/2022
 Signature:

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | |
|--|---|-------------------------|-------------------------|-------------------|
| Company Name PHS Compliance | Company Address Kid Glove Road | Postcode WA3 3GR | Branch No. | Scheme No. |
| Client UPP Residential Services Ltd | Installation Address Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | | Postcode SA1 8EN | |

| | | | | | | | |
|--|-----------------------------|--|---------------------------------|---|----------------------------|---|-----------------------|
| Distribution board details - Complete in every case | | Complete only if the distribution board is not connected directly to the origin of the installation | | Characteristics at this distribution board | | Test instrument serial number(s) | |
| Location | Plant Room Roof [Schneider] | Supply to distribution board is from | Associated RCD(if any): BS (EN) | | Above 30mA (if applicable) | | Loop impedance |
| Designation | DB Mech | Sub Mains(DB PL, 8/TP) | N/A | | Operating at 1 IΔn | | Insulation resistance |
| Num. of ways | 6 | Overcurrent protective device for the distribution circuit: Type | BS(EN) 60898 MCB | | 30mA or below | | Continuity |
| | | Rating | 32 | | Operating at 5 IΔn | | RCD |
| | | Voltage | | | N/A | | |

| CIRCUIT DETAILS | | | | | | | | | | | | | TEST RESULTS | | | | | | | | | | | | | | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|--|--|-----|-----|--------------|----------|----------|--|---------------------|---------|--------------|----------------------|-------------|-----------------|------------------------------|-----|-----|
| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
| | | | | | L / N | CPC | Maximum disconnection | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage | L/L, L/N | L/E, N/E | Above 30mA IΔn | 30mA or below 5 IΔn | RCD (✓) | | | AFDD (✓) | | | | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | Fig 8 check (✓) | R1 + R2 | R2 | |
| | | | | | | | | | | | | | | | | | | V | | M(Ω) | | M(Ω) | | | | | | | |
| 1/L1 | Press Unit | O | B | 1 | 1.5 | 1.5 | 0.4 | 60898 MCB | D | 4 | 10 | N/A | 2.18 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.35 | N/A | N/A | N/A | N/A | |
| 1/L2 | Boiler 1 | O | B | 1 | 1.5 | 1.5 | 0.4 | 60898 MCB | C | 4 | 10 | N/A | 4.37 | N/A | N/A | N/A | N/A | 0.18 | N/A | 250 | LIM | >299 | ✓ | 0.48 | N/A | N/A | N/A | N/A | |
| 1/L3 | Boiler 2 | O | B | 1 | 1.5 | 1.5 | 0.4 | 60898 MCB | C | 4 | 10 | N/A | 4.37 | N/A | N/A | N/A | N/A | 0.15 | N/A | 250 | LIM | >299 | ✓ | 0.42 | N/A | N/A | N/A | N/A | |
| 2/L1 | VT Pump 1 | O | B | 1 | 1.5 | 1.5 | 0.4 | 60898 MCB | D | 4 | 10 | N/A | 2.18 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.38 | N/A | N/A | N/A | N/A | |
| 2/L2 | Water Heat 1 | O | B | 1 | 1.5 | 1.5 | 0.4 | 60898 MCB | C | 10 | 10 | N/A | 1.75 | N/A | N/A | N/A | N/A | 0.10 | N/A | 250 | LIM | >299 | ✓ | 0.42 | N/A | N/A | N/A | N/A | |
| 2/L3 | Water Heat 2 | O | B | 1 | 1.5 | 1.5 | 0.4 | 60898 MCB | C | 10 | 10 | N/A | 1.75 | N/A | N/A | N/A | N/A | 0.14 | N/A | 250 | LIM | >299 | ✓ | 0.42 | N/A | N/A | N/A | N/A | |
| 3/L1 | VT Pumo 2 | O | B | 1 | 1.5 | 1.5 | 0.4 | 60898 MCB | D | 4 | 10 | N/A | 2.18 | N/A | N/A | N/A | N/A | 0.09 | N/A | 250 | LIM | >299 | ✓ | 0.31 | N/A | N/A | N/A | N/A | |
| 3/L2 | Sec Pump | O | B | 1 | 1.5 | 1.5 | 0.4 | 60898 MCB | D | 2 | 10 | N/A | 4.37 | N/A | N/A | N/A | N/A | 0.09 | N/A | 250 | LIM | >299 | ✓ | 0.26 | N/A | N/A | N/A | N/A | |
| 3/L3 | Control Pump | O | B | 1 | 10 | 10 | 0.4 | 60898 MCB | C | 50 | 10 | N/A | 0.35 | N/A | N/A | N/A | N/A | 0.08 | N/A | 250 | LIM | >299 | ✓ | 0.30 | N/A | N/A | N/A | N/A | |
| 4/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 5/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 6/TP | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 14/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

| | | | | | |
|--------------------------------------|---|-------------------|-------------|-------------|--|
| Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.: | |
| Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN | | | |

| | | | |
|--|--|---|---|
| Distribution board details - Complete in every case | Complete only if the distribution board is not connected directly to the origin of the installation | Characteristics at this distribution board | Test instrument serial number(s) |
| Location: Flat 12 Riser [Schneider] | Supply to distribution board is from: Sub Mains(BB 1, 19/L2) | Associated RCD(if any): BS (EN) N/A | Loop impedance: 080408/5756 |
| Designation: DB LL2/L | Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400/230 V | Operating at 1 IΔn: N/A ms | Insulation resistance: 080408/5756 |
| Num. of ways: 12 | | 30mA or below: N/A ms | Continuity: 080408/5756 |
| Num. of phases: 1 | | Operating at 5 IΔn: N/A ms | RCD: 080408/5756 |
| Supply polarity confirmed: <input checked="" type="checkbox"/> | | Time delay (if applicable): N/A | |
| Phase sequence confirmed: <input type="checkbox"/> | | | |

| CIRCUIT DETAILS | | | | | | | | | | | | | TEST RESULTS | | | | | | | | | | | | | | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|---------|------------|------------------------|--------------------|-------------------------------------|--|-----|-----------------|----------------|---------------|---------------|--|------------------------|---------|--------------|----------------------|-------------|---|------------------------------|-----|-----|
| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Zs Other (Ω) | Circuit impedance Ω | | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
| | | | | | L/N | CPC | Maximum disconnection | BS EN Number | Type No | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | | | AFDO (✓) | | | | |
| | | | | | | | | | | | | | | r1 | r2 | Fig 8 check (✓) | | | | | | | | | | All circuits to be completed using R1R2 or R2, not both | | | |
| | | | | | | | | | | | | | | R1 + R2 | R2 | | | | | | | | | | | | | | |
| 1/L2 | Flat 11 corridor | A | B | 9 | LIM | LIM | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | LIM | LIM | LIM | ✓ | 0.35 | 28.4 | 20.6 | ✓ | N/A | |
| 2/L2 | Flat 9 Corridor | A | B | 9 | LIM | LIM | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | LIM | LIM | LIM | ✓ | 0.40 | 18.5 | 19.4 | ✓ | N/A | |
| 3/L2 | Flat 14 Corridor | A | B | 9 | LIM | LIM | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | LIM | LIM | LIM | ✓ | 0.37 | 27.4 | 27.0 | ✓ | N/A | |
| 4/L2 | Flat 12,13 Corridor | A | B | 18 | LIM | LIM | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | LIM | LIM | LIM | ✓ | 0.34 | 28.4 | 21.4 | ✓ | N/A | |
| 5/L2 | Lobby + Stair Lights | A | B | 12 | LIM | LIM | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | LIM | LIM | LIM | ✓ | 0.33 | 22.1 | 22.5 | ✓ | N/A | |
| 6/L2 | Lobby + Stair Lights 2 | A | B | 12 | LIM | LIM | 0.4 | 61009 RCD/ | C | 10 | 10 | 30 | 1.75 | N/A | N/A | N/A | N/A | LIM | N/A | LIM | LIM | LIM | ✓ | 0.38 | 32.1 | 20.4 | ✓ | N/A | |
| 7/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 8/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 9/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 10/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 11/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 12/L2 | SPARE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 14/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance | Company Address: Kid Glove Road | Postcode: WA3 3GR | Branch No.: | Scheme No.:
 Client: UPP Residential Services Ltd | Installation Address: Swansea University Bay Campus - Deganwy 13, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea | Postcode: SA1 8EN

Distribution board details - Complete in every case
 Location: Flat 12 Riser [Schneider]
 Designation: DB LL2/P
 Num. of ways: 24 | Num. of phases: 1
 Supply polarity confirmed: | Phase sequence confirmed:

Complete only if the distribution board is not connected directly to the origin of the installation
 Supply to distribution board is from: Sub Mains(BB 1, 19/L2)
 Overcurrent protective device for the distribution circuit: Type: gG | Rating: 63 A | Voltage: V

Characteristics at this distribution board
 Associated RCD(if any): BS (EN) N/A | Operating at 1 IΔn: N/A ms (Above 30mA)
 Zs: LIM Ω | No. of poles: N/A | 30mA or below
 Ipr: LIM kA | IΔn: N/A | Operating at 5 IΔn: N/A ms
 Time delay (if applicable): N/A

Test instrument serial number(s)
 Loop impedance: 080408/5756
 Insulation resistance: 080408/5756
 Continuity: 080408/5756
 RCD: 080408/5756

CIRCUIT DETAILS TEST RESULTS

| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | operating RCD (mA) | BS 7671 Max. permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|-----|-----|-----------------|---|--|---------------|---------------|--------------|----------------------|-------------------|------------------------|------------------------------|----------|---------|
| | | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω) | | | Above 30mA IΔn ms | 30mA or below 5 IΔn ms | RCD (✓) | APCD (✓) | |
| | | | | | | | | | | | | | | r1 | rn | r2 | | | | | | | | | | | | R1 + R2 |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1/L2 | Sockets Corridor 4th Floor | A | B | 4 | LIM | LIM | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | LIM | LIM | LIM | N/A | LIM | N/A | LIM | LIM | LIM | ✓ | 0.34 | 29.2 | 18.6 | ✓ | N/A |
| 2/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 3/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 4/L2 | Corridor 4th Floor East | A | B | 4 | LIM | LIM | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | LIM | LIM | LIM | N/A | LIM | N/A | LIM | LIM | LIM | ✓ | 0.39 | 26.4 | 22.0 | ✓ | N/A |
| 5/L2 | Corridor 4th Floor West | A | B | 4 | LIM | LIM | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | LIM | LIM | LIM | N/A | LIM | N/A | LIM | LIM | LIM | ✓ | 0.43 | 28.8 | 29.4 | ✓ | N/A |
| 6/L2 | Maglock 3rd Floor | A | B | 1 | LIM | LIM | 0.4 | 61009 RCD/ | C | 32 | 10 | 30 | 0.54 | N/A | N/A | N/A | N/A | LIM | | LIM | LIM | LIM | ✓ | 0.29 | 28.3 | 19.2 | ✓ | N/A |
| 7/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 8/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 9/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 10/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 11/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 12/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 13/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 14/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 15/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 16/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 17/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |
| 18/L2 | SPARE | | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | N/A | | | | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing: _____ Date(s) dead testing: 14/07/2022 To: 14/07/2022 Date(s) live testing: 14/07/2022 To: 14/07/2022

Tested by: Name (capital letters): LIAM KIMBLE | Position: Electrical Test Engineer | Date: 14/07/2022 | Signature:

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148205



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

| CIRCUIT DETAILS | | | | | | | | | | | | | TEST RESULTS | | | | | | | | | | | | | | | | |
|--------------------------|--------------------------------|----------------|-------------|---------------|---|-----|-----------------------|--------------------------------|----------|------------|------------------------|--------------------|---|--|-----|-----|-----------------|---|--|----------------|---------------|--------------|----------------------|---------------|------------------|------------------------------|---------|----------|-----|
| Circuit No. and Line No. | Distribution board Designation | Type of wiring | Ref. method | No. of points | Circuit conductors csa (mm ²) | | Maximum disconnection | Overcurrent protective devices | | | Breaking capacity (KA) | RCD operating (mA) | BS 7671 Max. permitted Zs Other 80% (Ω) | Circuit impedance Ω | | | | | Insulation resistance (Record lower reading) | | | Polarity (✓) | Max. Measured Zs (Ω) | RCD testing | | Manual test button operation | | | |
| | DB LL2/P | | | | L / N | CPC | | BS EN Number | Type No. | Rating (A) | | | | Ring final circuits only (measured end-to-end) | | | Fig 8 check (✓) | All circuits to be completed using R1R2 or R2, not both | | Test voltage V | L/L, L/N M(Ω) | | | L/E, N/E M(Ω) | Above 30mA Δn ms | 30mA or below 5 Δn ms | RCD (✓) | AFDD (✓) | |
| | Circuit designation | | | | r1 | m | | r2 | R1 + R2 | R2 | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 19/L2 | SPARE | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | | | N/A | N/A |
| 20/L2 | SPARE | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | | | N/A | N/A |
| 21/L2 | SPARE | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | | | N/A | N/A |
| 22/L2 | SPARE | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | | | N/A | N/A |
| 23/L2 | SPARE | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | | | N/A | N/A |
| 24/L2 | SPARE | | | | | | | | | | | | N/A | N/A | N/A | N/A | | | | | | | | | | | | N/A | N/A |

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) LIAM KIMBLE Position Electrical Test Engineer Date 14/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

Generic Continuation

Agreed limitations and operational limitations:
circuits.

General Conditions of the Electrical Installation:

insulated solid copper cables, BS5467 XLPE steel wire armoured cables, BSEN6491X Single core copper strand single insulated cables.

DB LL2/P & DB LL2/L are tucked behind a pipe in riser cupboard, this is a problem as you cannot gain access into the distribution board to test the Ze, IPF of the DB or even get the cable sizes of the circuits.

Main Earthing bond for water service is located in the mains room and the main earth bonding cable is tight to the service pipe and wired with a 50mm BS6491X green and yellow PVC copper strand cable labelled with a BS951 label appropriately sited and readable.

Nothing over 3 metres in height has been tested due to health and safety precautions, the circuit will be tested to the nearest available point, the items will only be visually inspected.

Please note that the supplementary conductor's box at the top of the test results page is not applicable in most cases as the area fed from the circuits contained within the associated DB do not require supplementary bonding. This version of the Software does not allow N/A to be selected which is the reason for the boxes being ticked. Our software provider has assured us that this box will be omitted in future versions of the software.

Where stop buttons and isolators have been installed the correct operation of these has not been verified.

To comply with Regulation 643.8 of BS 7671 and to verify that RCD devices within this installation will disconnect within 40ms we have maintained the practice of testing at both 1x and 5x the rated residual operating current to provide an indication of the life cycle of the RCD. The reading recorded in the test results box will be 1x the residual operating current as required by the model form of the EICR in BS 7671.

This installation has been designed and installed prior to July 2018. There is no evidence of over voltage protection within the electrical installation, we recommend Type 2 Surge Protective Devices be installed at the origin to reduce the risk of damage to the installation by external transient over voltage's or switching, Reg 534.4.1.1

Remarks:

DB Main Remarks:

8/L3 - FA Panel: O=FP200

DB PL Remarks:

6/L1 - FA Interface: O=FP200

DB Mech Remarks:

1/L1 - Press Unit: O=YY

1/L2 - Boiler 1: O=YY

1/L3 - Boiler 2: O=YY

2/L1 - VT Pump 1: O=YY

2/L2 - Water Heat 1: O=YY

2/L3 - Water Heat 2: O=YY

3/L1 - VT Pumo 2: O=YY

3/L2 - Sec Pump: O=YY

3/L3 - Control Pump: O=Tails from thermosetting SWA



MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE

(Requirements for Electrical Installations - BS 7671 (IET Wiring Regulations))

To be used only for minor electrical work which does not include the provision of a new circuit

PART 1: Description of the minor works

1. Details of the Client UPP Residential Services Ltd (Swansea) Date minor works completed 16
2. Installation location/address UPP Residential Services Limited Tower Information Centre Fabian Way, Crymlyn Burrows,
3. Description of the minor works PROJECT OVERVIEW UPP remedial works. Replace cable to riser from board
4. Details of departures, if any, from BS 7671:2018 for the circuit altered or extended (Regulation 120.3, 133.1.3, 133.5):
None
5. Comments on (including any defects observed in) the existing installation (Regulation 644.1.2):
R1 + R2 was slightly high so replaced cable

Where applicable a suitable risk assessment(s) must be attached to this Certificate
Risk assessment attached

PART 2: Presence and adequacy of installation earthing and bonding arrangements (Regulation 132.16)

1. System earthing arrangement TN-S TN-C-S TT
2. Earth fault loop impedance at distribution board (Z_{db}) supplying the final circuit 0.19 Ω
3. Presence of adequate main protective conductors: Earthing conductor
Main protective bonding conductor(s) to: Water Gas Oil Structural steel Other Lightning

PART 3: Circuit details

DB Reference No: DB CL8 DB Location and type: Deganwyn floor 3 flat 8 kitchen single phase

Circuit No: L8 Circuit description: Sub main DB CL8/8

Circuit overcurrent protective device: BS(EN) 61009 Type B Rating 32 A

Conductor sizes: Live mm² cpc mm²

PART 4: Test results for the circuit altered or extended (where relevant and practicable)

Protective conductor continuity: $R_1 + R_2$ 0.06 Ω or R_2 N/a Ω

Continuity of ring final circuit conductors: L/L N/a Ω N/N N/a Ω cpc/cpc N/a Ω

Insulation resistance: Live - Live >200 M Ω Live - Earth >200 M Ω

Polarity satisfactory: Maximum measured earth fault loop impedance: Z_s 0.28 Ω

RCD operation: Rated residual operating current ($I_{\Delta n}$) 30 mA

Disconnection time at $I_{\Delta n}$ 39 ms Disconnection time at $5I_{\Delta n}$ 29 ms Satisfactory test button operation

PART 5: Declaration

I certify that the work covered by this certificate does not impair the safety of the existing installation and the work has been designed, constructed, inspected and tested in accordance with BS 7671:2018 (IET Wiring Regulations) amended to and that to the best of my knowledge and belief, at the time of my inspection, complied with BS 7671 except as detailed in Part 1 above. 2022 (date)

Name: James Griffiths Signature:  Date: 16

For and on behalf of: DRS FM Services Ltd Position: Approved electrician

Address: Phoenix House, Llys Felin Newydd Enterprise Park, Swansea SA7 9FG



MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE

Notes for the person producing the Certificate:

The Minor Electrical Installation Works Certificate is intended to be used for additions and alterations to an installation that do not extend to the provision of a new circuit. Examples include the addition of socket-outlets or lighting points to an existing circuit, the relocation of a light switch etc. This Certificate may also be used for the replacement of equipment such as accessories or luminaires, but not for the replacement of distribution boards or similar items. Appropriate inspection and testing, however, should always be carried out irrespective of the extent of work undertaken.

Guidance for Recipients (to be appended to the Certificate)

This Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with British Standard 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the contractor should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a copy of it, to the owner. A separate Certificate should have been received for each existing circuit on which minor works have been carried out. This Certificate is not appropriate if you requested the contractor to undertake more extensive installation work, for which you should have received an Electrical Installation Certificate.

The Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the minor electrical installation work carried out complied with the requirements of British Standard 7671 at the time the Certificate was issued.



MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE

(Requirements for Electrical Installations - BS 7671 (IET Wiring Regulations))

To be used only for minor electrical work which does not include the provision of a new circuit

PART 1: Description of the minor works

1. Details of the Client UPP Residential Services Ltd (Swansea) Date minor works completed 16/01/2023
2. Installation location/address UPP Residential Services Limited Tower Information Centre Fabian Way, Crymlyn Burrows,
3. Description of the minor works PROJECT OVERVIEW UPP remedial works. Replace broken plastic socket patress
4. Details of departures, if any, from BS 7671:2018 for the circuit altered or extended (Regulation 120.3, 133.1.3, 133.5):
None
5. Comments on (including any defects observed in) the existing installation (Regulation 644.1.2):
Load side of double pole switch on kitchen ring feeds fridge socket with broken plastic patress. Replaced patress.

Where applicable a suitable risk assessment(s) must be attached to this Certificate
Risk assessment attached

PART 2: Presence and adequacy of installation earthing and bonding arrangements (Regulation 132.16)

1. System earthing arrangement TN-S TN-C-S TT
2. Earth fault loop impedance at distribution board (Z_{db}) supplying the final circuit 0.15 Ω
3. Presence of adequate main protective conductors: Earthing conductor
Main protective bonding conductor(s) to: Water Gas Oil Structural steel Other Lightning

PART 3: Circuit details

DB Reference No: Deganwyn DB CL1 DB Location and type: Deganwyn ground floor flat 1 kitchen. Single phase
 Circuit No: L15 Circuit description: kitchen ring
 Circuit overcurrent protective device: BS(EN) 61009 Type C Rating 32 A
 Conductor sizes: Live 2.5 mm^2 cpc 1.5 mm^2

PART 4: Test results for the circuit altered or extended (where relevant and practicable)

Protective conductor continuity: $R_1 + R_2$ 0.18 Ω or R_2 N/a Ω
 Continuity of ring final circuit conductors: L/L N/a Ω N/N N/a Ω cpc/cpc N/a Ω
 Insulation resistance: Live - Live >200 $M\Omega$ Live - Earth >200 $M\Omega$
 Polarity satisfactory: Maximum measured earth fault loop impedance: Z_s 0.79 Ω
 RCD operation: Rated residual operating current ($I_{\Delta n}$) 30 mA
 Disconnection time at $I_{\Delta n}$ 32 ms Disconnection time at $5I_{\Delta n}$ 29 ms Satisfactory test button operation

PART 5: Declaration

I certify that the work covered by this certificate does not impair the safety of the existing installation and the work has been designed, constructed, inspected and tested in accordance with BS 7671:2018 (IET Wiring Regulations) amended to and that to the best of my knowledge and belief, at the time of my inspection, complied with BS 7671 except as detailed in Part 1 above. 2022 (date)

Name: James Griffiths

Signature:

Date: 16/01/2023

For and on behalf of: DRS FM Services Ltd

Position: Approved electrician

Address: Phoenix House, Llys Felin Newydd Enterprise Park, Swansea SA7 9FG



MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE

Notes for the person producing the Certificate:

The Minor Electrical Installation Works Certificate is intended to be used for additions and alterations to an installation that do not extend to the provision of a new circuit. Examples include the addition of socket-outlets or lighting points to an existing circuit, the relocation of a light switch etc. This Certificate may also be used for the replacement of equipment such as accessories or luminaires, but not for the replacement of distribution boards or similar items. Appropriate inspection and testing, however, should always be carried out irrespective of the extent of work undertaken.

Guidance for Recipients (to be appended to the Certificate)

This Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with British Standard 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the contractor should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a copy of it, to the owner. A separate Certificate should have been received for each existing circuit on which minor works have been carried out. This Certificate is not appropriate if you requested the contractor to undertake more extensive installation work, for which you should have received an Electrical Installation Certificate.

The Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the minor electrical installation work carried out complied with the requirements of British Standard 7671 at the time the Certificate was issued.