

Electrical Installation Condition Report

Requirements for Electrical Installations - BS 7671:2018
(IET Wiring Regulations 18th Edition)



Information for recipients:

The purpose of this report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).

The person ordering the report should have received the Original©Report and the inspector should have retained a duplicate.

The Original©Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.

Where the installation incorporates residual current devices (RCDs) there should be a notice at or near the devices stating that they should be tested every 6 months. **For safety reasons it is important that these instructions are followed.**

Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The Inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licencing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.

For items classified in Section K as C1 ("Danger Present"), **the safety of those using the installation is at risk**, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.

For items classified in Section K as C2 ("Potentially Dangerous"), **the safety of those using the installation may be at risk** and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where it has been stated in Section K that an observation requires further investigation code FI the inspection has revealed an apparent deficiency which may result on a code C1 or C2 could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated as soon as possible. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons competent in such work. The recommended date by which the next inspection is due is stated in Section F of the report under 'Recommendations' and on label at or near to the consumer unit/distribution board.

ELECTRICAL INSTALLATION CONDITION REPORT

FT/
EICR 110148512

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



A. Details of the Installation

Client	UPP Residential Services Ltd	Installation	Swansea University - Manobier 11A & Llywelyn Fawr 11B
Address	First Floor 12 Arthur Street London,	Address	Reception - Ground Floor Tower Information Centre Fabian Way, Crymlyn Burrows Swansea
Postcode	EC4R 9AB	Postcode	SA1 8EN

B. Reason for Producing this Report *This form is to be used only for reporting on the condition of an existing installation.*

Essential information requested by the client in accordance with the electricity at work regulations 1989.

Date(s) on which the inspection and testing were carried out to

C. Details of Installation which is the Subject of this Report

Description of premises Domestic Commercial Industrial Other (please specify)

Estimated age of the wiring system years

Evidence of alterations or addition Yes No Not apparent if 'Yes', estimated years

Records of installation available Yes No Records held by

Date of last inspection Electrical Installation Certificate No. or previous Inspection Report No.

D. Extent of Electrical Installation Covered by this Report:

Testing of all sub mains, lighting and power circuits, within the constraints of the agreed limitations.

Agreed Limitations and Operational Limitations (Regulations 653.2)

Unable to access the sealed supply device characteristics. Ze and Ipf have been taken as close to the origin as possible. Insulation resistance testing has been carried out to regulation 643.3.3 on circuits where it was impracticable to disconnect load.

Agreed with:

The inspection and testing detailed within this report and accompanying schedule has been carried out in accordance with BS 7671: 2018 (IET Wiring Regulations) amended to

It should be noted that cables concealed within trunkings and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

E. Summary of the Condition of the Installation

General conditions of the installation (in terms of electrical safety)

Installation Details The installation approximately 10 years old. The Main Supply is located in the Ground Floor Plant Room. Main Earthing arrangement for the installation appears to be TNCS. Wiring Systems. The wiring systems utilized for final circuit wiring in the installation are (A) PVC T&E Cables and --Please see Continuation Page--

Overall assessment of the installation in terms of its suitability for continued use **SATISFACTORY** *UNSATISFACTORY

*An UNSATISFACTORY assessment indicates that dangerous (code C1), or potentially dangerous (code C2), Further investigation (code FI) conditions have been identified

F. Recommendations

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potential dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further Investigation required' (code FI). Observations classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by (date)

ELECTRICAL INSTALLATION CONDITION REPORT

FT/ 110148512
EICR

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



G. Declaration

I/we being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Company	PHS Compliance	Inspected and tested by	Authorised for issue by
Address	Kid Glove Road, Golborne, Warrington,	Name:	Tre Lever
		Signature:	
Postcode	WA3 3GR	Position:	Electrical Test Engineer
Branch No.		Date:	18/07/2022
Scheme No.			Technical Auditor
			23/08/2022

EICRs are produced by a UKAS accredited inspection body, No. 0433

H. Schedule(s)

1 schedule(s) of inspection and 139 schedule(s) of test results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

I. Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S TN-C-S TT Other Please specify _____

Number & Type of live conductors AC DC No. of phases 3 No. of wires 4

Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)

Nominal voltage, U/U₀ ⁽¹⁾ 400 v Nominal frequency, f⁽¹⁾ 50 Hz Confirmation of supply polarity

Prospective fault current, I_{pr} ⁽²⁾ 3.58 kA External loop impedance, Z_e ⁽²⁾ 0.10 Ω

Supply Protective Device BS (EN) LIM Type LIM Rated Current LIM A

No. of Additional Supplies N/A

J. Particulars of Installation Referred to in this Report

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) _____ Distributors facility Installation Earth Electrode

Location _____ Electrode resistance to earth _____ Ω Maximum Demand (load) LIM Amps KVA

Main Protective Conductors	Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Copper	150	Continuity Verified <input checked="" type="checkbox"/>	Ω Connection Verified <input checked="" type="checkbox"/>
Protective Bonding Conductor (to extraneous-conductive-parts)	Copper	35	Continuity Verified <input checked="" type="checkbox"/>	Ω Connection Verified <input checked="" type="checkbox"/>

Main Supply Conductor Copper 150 (connection / continuity) (✓) or Value (✓) or Value

Main Switch Location DB/M Water installation Ω To structural steel NA Ω

Fuse/device rating or setting 400 A Voltage rating 400 V Gas installation pipes Ω To lightning protection NA Ω

If RCD main switch: Rated residual operating current I Δn N/A mA Oil installation pipes NA Ω Other NA Ω

BS(EN) 60947-2 MCCB No. of Poles 4 Current Rating 400 A Rated time delay N/A ms Measured operating trip time NA ms

K. Observations

Referring to the attached schedule of inspection and test results, and subject to the limitations at Section D.

- No remedial work required
- The following observations are made

Explanation of codes

C1	Danger present. Risk of Injury. Immediate remedial action required.
C2	Potentially dangerous. Urgent remedial action required.
C3	Improvement recommended.
F1	Further Investigation required without delay

Item No.	Observations	Code

One of the following codes, as appropriate, has been allocated to each of the observations made above and/or any attached observation sheets to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

C1	Danger present. Risk of Injury. Immediate remedial action required.	0
C2	Potentially dangerous. Urgent remedial action required.	0
C3	Improvement recommended.	0
F1	Further Investigation required without delay	0

The above values are a total count of Observation per outcome

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

Outcomes

Acceptable condition:	Unacceptable condition: State	Improvement recommended:	Further Investigation:	Not Verified:	Limitation:	Not Applicable:
	or					

Item No.	Description	Outcome
----------	-------------	---------

1.0 External Condition Of Intake Equipment (Visual Inspection Only) Where inadequacies are encountered, it is recommended that the person ordering the report informs the appropriate authority

1.1	Service cable	
1.2	Service head	
1.3	Earthing arrangement	
1.4	Meter tails	
1.5	Metering equipment	
1.6	Isolator (where present)	

2.0 Parallel Or Switched Alternative Sources Of Supply

2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	

3.0 Automatic Disconnection Of Supply

3.1	Main earthing/bonding arrangements (411.3; Chap 54)	
3.1.1	Presence of distributors earthing arrangement (542.1.2.1; 542.1.2.2)	
3.1.2	Presence of installation earth electrode arrangement (542.1.2.3)	
3.1.3	Adequacy of earthing conductor size (542.3; 543.1.1)	
3.1.4	Adequacy of earthing conductor connections (542.3.2)	
3.1.5	Accessibility of earthing conductor connections (543.3.2)	
3.1.6	Adequacy of main protective bonding conductor sizes (544.1)	
3.1.7	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)	
3.1.8	Accessibility of all protective bonding connections (543.3.2)	
3.1.9	Provision of earthing/bonding labels at all appropriate locations (514.13)	
3.2	FELV - requirements satisfied (411.7; 411.7.1)	

4.0 Other Methods Of Protection (Where any of the methods listed below are employed details should be provided on separate sheets)

4.1	Non-conducting location (418.1)	
4.2	Earth-free local equipotential bonding (418.2)	
4.3	Electrical separation (Section 413; 418.3)	
4.4	Double insulation (Section 412)	
4.5	Reinforced insulation (Section 412)	

5.0 Distribution Equipment

5.1	Adequacy of working space/accessibility to equipment (132.12; 513.1)	
5.2	Security of fixing (134.1.1)	
5.3	Condition of insulation of live parts (416.1)	
5.4	Adequacy/security of barriers (416.2)	
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)	
5.6	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	
5.7	Enclosure not damaged/deteriorated so as to impair safety (651.2)	
5.8	Presence and effectiveness of obstacles (417.2)	
5.9	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	
5.10	Operation of main switch(es) (functional check) (643.10)	
5.11	Manual operation of circuit-breakers and RCD(s) to prove disconnection (643.10)	
5.12	Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (643.10)	
5.13	RCD(s) provided for fault protection – includes RCBO(s) (411.4.204; 411.5.2; 531.2)	
5.14	RCD(s) provided for additional protection / requirements, where required - includes RCBO(s) (411.3.3; 415.1)	
5.15	Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)	
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)	
5.17	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)	
5.18	Presence of alternative supply warning notice at or near equipment, where required (514.15)	
5.19	Presence of next inspection recommendation label (514.12.1)	
5.2	Presence of other required labelling (please specify) (Section 514)	
5.21	Compatibility of protective device, base and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.4.5; 411.4.6; Sections 432; 433)	
5.22	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	
5.23	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)	
5.24	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	

6.0 Distribution Circuits

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)



6.1	Identification of conductors (514.3.1)	✓
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓
6.3	Condition of insulation of live parts (416.1)	✓
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. Integrity of containment (521.10.1)	✓
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	✓
6.6	Cables correctly terminated in enclosures (Section 526)	✓
6.7	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration (421.1; 522.6)	✓
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	✓
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓
6.13	Cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522)	✓
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	✓
6.15	Cables concealed under floors, above ceilings, in walls/partitions less than 50 mm from a surface, and in partitions containing metal parts	
6.15.1	Installed in prescribed zones (see Section D. Extent and limitations) (522.6.202) or	✓
6.15.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.204)	✓
6.16	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
6.17	Band II cables segregated/separated from Band I cables (528.1)	✓
6.18	Cables segregated/separated from non-electrical services (528.3)	✓
6.19	Condition of circuit accessories (651.2)	✓
6.20	Suitability of circuit accessories for external influences (512.2)	✓
6.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
6.22	Adequacy of connections, including cpc's, within accessories and to fixed and stationary equipment – identify/record numbers and locations of items inspected (Section 526)	✓
6.23	Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; 537)	✓
6.24	General condition of wiring systems (651.2)	✓
6.25	Temperature rating of cable insulation (522.1.1; Table 52.1)	✓
7.0 CONSUMER UNIT/DISTRIBUTION BOARD(S)		
7.1	Adequacy of working space/accessibility to consumer unit/distribution board (132.12; 513.1)	✓
7.2	Security of fixing (134.1.1)	✓
7.3	Condition of enclosure(s) in terms of IP rating (Barriers etc) (416.2)	✓
7.4	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	✓
7.5	Enclosure/obstacles not damaged/deteriorated so as to impair safety (651.2)	✓
7.5.1	Presence and effectiveness of obstacles (417.2)	✓
7.6	Presence of main linked switch (as required by 462.1.201)	✓
7.7	Operation of main switch (functional check) (643.10)	✓
7.8	Manual operation of circuit-breakers and RCD(s) (test button) to prove disconnection (643.10)	✓
7.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	✓
7.10	Presence of RCD six-monthly test notice at or near consumer unit/distribution board (514.12.2)	✓
7.11	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)	✓
7.12	Presence of alternative supply warning notice at or consumer unit/distribution board (514.15)	✓
7.13	Presence of other required labelling (Please specify) (Section 514)	✓
7.14	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)	✓
7.15	Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3)	✓
7.16	Protection against mechanical damage where cables enter consumer unit/distribution board (132.14.1; 522.8.1; 522.8.5; 522.8.11)	✓
7.17	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	✓
7.18	RCD(s) provided for fault protection - includes RCBO(s)(411.4.204; 411.5.2; 531.2)	✓
7.19	RCD(s) provided for additional protection/requirements, where required - includes RCBO(s) (411.3.3; 415.1)	✓
7.20	Confirmation of indication that SPD is functional (651.4)	✓
7.21	Confirmation that ALL conductor connections, including connections to the busbars are correctly located in terminals and are tight and secure (526.1)	✓
7.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	NA
7.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	NA
8.0 FINAL CIRCUITS		
8.1	Identification of conductors (514.3.1)	✓
8.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓
8.3	Condition of insulation of live parts (416.1)	✓

for Industrial/Commercial Premises



Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

8.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)	✓
8.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)	✓
8.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
8.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓
8.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
8.8	Presence and adequacy of circuit protective conductors (411.3.1; Section 543)	✓
8.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	✓
8.10	Connected cables installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)	✓
8.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (522.6.204)	✓
8.12	Provision of additional requirements for protection by RCD not exceeding 30 mA:	
8.12.1	For all socket-outlets of rating 32 A or less unless exempt (4.11.3.3)	✓
8.12.2	For the supply of Mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	✓
8.12.3	For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	✓
8.12.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)	✓
8.12.5	For circuits supplying luminaires within domestic (household) premises (411.3.4)	✓
8.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
8.14	Band II cables segregated/separated from Band I cables (528.1)	✓
8.15	Cables segregated/separated from communications cabling (528.2)	✓
8.16	Cables segregated/separated from non-electrical services (528.3)	✓
8.17	Termination of cables at enclosures - indicate extent of sampling in section d of the report (section 526)	
8.17.1	Connections soundly made and under no undue strain (526.6)	✓
8.17.2	No basic insulation of a conductor visible outside enclosure (526.8)	✓
8.17.3	Connections of live conductors adequately enclosed (526.5)	✓
8.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	✓
8.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2 (v))	✓
8.19	Suitability of accessories for external influences (512.2)	✓
8.20	Adequacy or working space/accessibility to equipment (132.12; 513.1)	✓
8.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
9.0 ISOLATION AND SWITCHING		
9.1	Isolators (Section 460; 537)	
9.1.1	Presence and condition of appropriate devices (462; 537.2.7)	✓
9.1.2	Acceptable location - state if local or remote from equipment in question (462; 537.2.7)	✓
9.1.3	Capable of being secured in the OFF position (462.3)	✓
9.1.4	Correct operation verified (643.10)	✓
9.1.5	Clearly identified by position and/or durable marking (537.2.6)	✓
9.1.6	Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	✓
9.2	Switching off for mechanical maintenance (Section 464; 537.3.2)	
9.2.1	Presence and condition of appropriate devices (464.1; 527.3.2)	✓
9.2.2	Acceptable location - state if local or remote from equipment in question (537.3.2.4)	✓
9.2.3	Capable of being secured in the OFF position (462.3)	✓
9.2.4	Correct operation verified (643.10)	✓
9.2.5	Clearly identified by position and/or durable marking (537.3.2.4)	✓
9.3	Emergency switching/stopping (465; 537.3.3)	
9.3.1	Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4)	✓
9.3.2	Readily accessible for operation where danger might occur (537.3.3.6)	✓
9.3.3	Correct operation verified (643.10)	✓
9.3.4	Clearly identified by position and/or durable marking (537.3.3.6)	✓
9.4	Functional switching (section 463; 537.3.1)	
9.4.1	Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	✓
9.4.2	Correct operation verified (537.3.1.1; 537.3.1.2)	✓
10.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)		
10.1	Condition of equipment in terms of IP rating etc (416.2)	✓
10.2	Equipment does not constitute a fire hazard (Section 421)	✓
10.3	Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2)	✓
10.4	Suitability for the environment and external influences (512.2)	✓
10.5	Security of fixing (134.1.1)	✓
10.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2)	✓
10.7	Recessed luminaires (downlighters)	
10.7.1	Correct type of lamps fitted (559.3.1)	✓
10.7.2	Installed to minimize build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.1.2)	✓
10.7.3	No signs of overheating to surrounding building fabric (559.4.1)	✓

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)



10.7.4	No signs of overheating to conductors/terminations (526.1)	✓
--------	--	---

11.0 PART 7 SPECIAL INSTALLATIONS OR LOCATIONS

11.01	If any special installations or locations are present, list the particular inspections applied.	N/A
-------	---	-----

12.0 Schedule of Tests

Results to be recorded on Schedule of Test Results

12.1	External earth loop impedance, Z^e	Yes
12.2	Installation earth electrode	N/A
12.3	Prospective fault current, I_p^f	Yes
12.4	Continuity of Earth Conductors	Yes
12.5	Continuity of Circuit Protective Conductors	Yes
12.6	Continuity of ring final circuit	Yes
12.7	Continuity of Protective Bonding Conductors	Yes
12.8	Volt drop verified	Yes

12.9	Insulation Resistance between Live Conductors	N/A
12.10	Insulation Resistance between Live Conductors & Earth	Yes
12.11	Polarity (prior to energisation)	Yes
12.12	Polarity (after energisation) including phase sequence	Yes
12.13	Earth Fault Loop Impedance	Yes
12.14	RCDs/RCBOs including selectivity	Yes
12.15	Functional testing of RCD devices	Yes
12.16	Functional testing of AFDD(s) devices	N/A

Inspector's Name: Tre Lever

Date: 18/07/2022

Signature:

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Service Riser (Schneider)	Supply to distribution board is from: Sub Mains(DB/M, 5/TP)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/Busbar 1	Overcurrent protective device for the distribution circuit: Type NA Rating 200 A Voltage 400 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 12 Num. of phases: 3	BS(EN) 60974 MCCB	30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Time delay (if applicable): NA	RCD: 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2		R2																		
1/TP	Sub Mains(DB/LL2/L, DB/LL2/P)	F	E	1	25	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.03	N/A	250	LIM	>299	✓	0.14	N/A	N/A	N/A	N/A
2/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
2/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
2/L3	Sub Mains(DB/CL3)	G	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.16	N/A	N/A	N/A	N/A
3/L1	Sub Mains(DB/CL4)	G	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.16	N/A	N/A	N/A	N/A
3/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
3/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
4/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
4/L2	Sub Mains(DB/CL7)	G	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.16	N/A	N/A	N/A	N/A
4/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
5/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
5/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
5/L3	Sub Mains(DB/CL8)	G	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.16	N/A	N/A	N/A	N/A
6/TP	Sub Mains(DB/LL4/P, DB/LL4/L)	F	E	1	25	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.18	N/A	N/A	N/A	N/A
7/L1	Sub Mains(DB/CL11)	G	E	1	16	16	5	88-2 HRC	gG	63	80	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.16	N/A	N/A	N/A	N/A
7/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
7/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 18/07/2022 To 18/07/2022 Date(s) live testing 18/07/2022 To 18/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 18/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location Service Riser (Schneider)	Supply to distribution board is from Sub Mains(DB/M, 12/TP)	Associated RCD(if any): BS (EN) N/A Above 30mA (if applicable) ms Operating at 1 IΔn N/A	Loop impedance 102118371
Designation DB/Busbar 2	Overcurrent protective device for the distribution circuit: Type NA Rating 160 A Voltage 400 V	Z _s 0.10 Ω No. of poles N/A 30mA or below I _{pr} 3.30 kA IΔn N/A Operating at 5 IΔn N/A ms	Insulation resistance 102118371
Num. of ways 12 Num. of phases 3		Time delay (if applicable) NA	Continuity 102118371
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>			RCD 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Z _s Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2
1/TP	Sub Mains(DB/LL1/P, DB/LL1/L)	G	E	1	25	16	5	88-2 HRC	gG	63	36	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.16	N/A	N/A	N/A	N/A
2/L1	Sub Mains(DB/CL1)	G	E	1	16	16	5	88-2 HRC	gG	63	36	N/A	0.62	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.17	N/A	N/A	N/A	N/A
2/L2	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
2/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
3/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
3/L2	Sub Mains(DB/CL2)	G	E	1	16	16	5	88-2 HRC	gG	63	36	N/A	0.62	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.17	N/A	N/A	N/A	N/A
3/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
4/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
4/L2	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
4/L3	Sub Mains(DB/CL5)	G	E	1	16	16	5	88-2 HRC	gG	63	36	N/A	0.62	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.16	N/A	N/A	N/A	N/A
5/L1	Sub Mains(DB/CL6)	G	E	1	16	16	5	88-2 HRC	gG	63	36	N/A	0.62	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.16	N/A	N/A	N/A	N/A
5/L2	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
5/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
6/TP	Sub Mains(DB/LL3/L, DB/LL3/P)	G	E	1	25	16	5	88-2 HRC	gG	63	36	N/A	0.62	N/A	N/A	N/A	N/A	0.07	N/A	250	LIM	>299	✓	0.18	N/A	N/A	N/A	N/A
7/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
7/L2	Sub Mains(DB/CL9)	G	E	1	16	16	5	88-2 HRC	gG	63	36	N/A	0.62	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.16	N/A	N/A	N/A	N/A
7/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 18/07/2022 To 18/07/2022 Date(s) live testing 18/07/2022 To 18/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 18/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Roof Plant Room (Schneider)	Designation: DB/PL1/P	Supply to distribution board is from: Sub Mains(DB/Busbar 2, 11/TP)	Associated RCD(if any): BS (EN)	Above 30mA (if applicable) ms
Num. of ways: 12	Num. of phases: 3	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400 V	Operating at 1 IΔn N/A	30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input checked="" type="checkbox"/>		I _{pr} 2.21 kA IΔn N/A	Operating at 5 IΔn N/A
			Time delay (if applicable) NA	
			Test instrument serial number(s)	
			Loop impedance	102118371
			Insulation resistance	102118371
			Continuity	102118371
			RCD	102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn	30mA or below 5 IΔn			RCD (✓)	APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2
																		V	M(Ω)	M(Ω)	ms			ms				
1/L1	Plant Room Ring Main	A	E	3	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.19	0.20	0.31	✓	0.08	N/A	250	LIM	>299	✓	0.20	29.8	28.6	✓	N/A
1/L2	Shaft AOV	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.21	N/A	N/A	N/A	N/A
1/L3	Plant Room Heater	A	E	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.20	N/A	N/A	N/A	N/A
2/TP	Ext Fan 1	G	E	1	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.37	N/A	N/A	N/A	N/A
3/TP	Ext Fan 2	G	E	1	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.35	N/A	N/A	N/A	N/A
4/TP	Ext Fan 3	G	E	1	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.40	N/A	N/A	N/A	N/A
5/TP	Ext Fan 4	G	E	1	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.34	N/A	N/A	N/A	N/A
6/TP	Ext Fan 5	G	E	1	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.39	N/A	N/A	N/A	N/A
7/TP	Ext Fan 6	G	E	1	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A
8/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
9/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
10/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
11/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
12/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 18/07/2022 To 18/07/2022 Date(s) live testing 18/07/2022 To 18/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 18/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Roof Plant Room (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 2, 11/TP)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/PL1/L	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 8 Num. of phases: 3		30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 102118371
		Time delay (if applicable): NA	

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	Plant Room Lights	A	E	4	2.5	1.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.11	N/A	250	LIM	>299	✓	0.30	29.7	18.7	✓	N/A
1/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
1/L3	Plant Room Stair Lights	A	E	4	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.33	29.8	28.7	✓	N/A
2/L1	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
2/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
2/L3	Plant Room Access Lights	A	E	2	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.13	N/A	250	LIM	>299	✓	0.35	29.7	28.5	✓	N/A
3/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
4/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
5/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
6/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
7/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
8/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 18/07/2022 To 18/07/2022 Date(s) live testing 18/07/2022 To 18/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 18/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location	Flat 3 Kitchen (Schneider)	Supply to distribution board is from	Associated RCD(if any): BS (EN)		Above 30mA (if applicable)		Loop impedance
Designation	DB/LL1/P	Sub Mains(DB/Busbar 2, 1/TP)	N/A		Operating at 1 IΔn		Insulation resistance
Num. of ways	8	Overcurrent protective device for the distribution circuit: Type	BS(EN) 88-2 HRC		30mA or below		Continuity
		Rating	gG		Operating at 5 IΔn		RCD
		Voltage	63		N/A		
			A				
			400				
			V				

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn	30mA or below 5 IΔn	RCD (✓)			APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2
																		All circuits to be completed using R1R2 or R2, not both										
1/L1	GF IT Hub Sockets	A	E	3	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	1.09	0.44	0.43	0.60	✓	0.24	N/A	250	LIM	>299	✓	0.40	39.7	28.7	✓	N/A
1/L2	FF Cleaners Sockets	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	1.09	0.56	0.55	0.76	✓	0.32	N/A	250	LIM	>299	✓	0.50	29.7	28.7	✓	N/A
1/L3	2F Cleaners Sockets	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	1.09	0.60	0.61	0.84	✓	0.36	N/A	250	LIM	>299	✓	0.56	28.7	28.6	✓	N/A
2/L1	GF Main Door Access	A	E	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.31	N/A	250	LIM	>299	✓	0.40	N/A	N/A	N/A	N/A
2/L2	FF Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.36	N/A	N/A	N/A	N/A
2/L3	2F Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.37	N/A	N/A	N/A	N/A
3/L1	GF IT Hub Commando	A	E	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.40	N/A	N/A	N/A	N/A
3/L2	FF Door Access PSU	A	E	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.23	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A
3/L3	2F Door Access PSU	A	E	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.46	N/A	N/A	N/A	N/A
4/L1	GF IT Hub Commando	A	E	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.42	N/A	N/A	N/A	N/A
4/L2	Door Access Booster	A	E	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	✓	0.40	N/A	N/A	N/A	N/A
4/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
5/L1	GF IT Hub Commando	A	E	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.39	N/A	N/A	N/A	N/A
5/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
5/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
6/L1	IT Hub Tubular Heaters	A	E	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.40	N/A	N/A	N/A	N/A
6/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
6/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

CIRCUIT DETAILS														TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
	DB/LL1/P				Circuit designation	L/N		CPC	BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)			L/E, N/E M(Ω)	Above 30mA Idn ms	30mA or below 5 Idn ms	RCD (✓)	AFDD (✓)	
															R1 + R2	R2													
	r1																m												r2
7/L1	Intercom Unit	A	E	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.23	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A	
7/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A		
7/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A		
8/L1	GF Booster Room Sockets	A	E	3	2x2.5	2x1.5	0.4	60898 MCB	B	32	10	N/A	0.54	0.39	0.40	0.57	✓	0.22	N/A	250	LIM	>299	✓	0.34	N/A	N/A	N/A	N/A	
8/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A		
8/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A		

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance		Company Address Kid Glove Road		Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd		Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN		
Distribution board details - Complete in every case				Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Flat 3 Kitchen (Schneider)		Supply to distribution board is from: Sub Mains(DB/Busbar 2, 1/TP)		Associated RCD(if any): BS (EN) N/A		Test instrument serial number(s) Loop impedance: 102118371 Insulation resistance: 102118371 Continuity: 102118371 RCD: 102118371
Designation: DB/LL1/L		Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC		Operating at 1 IΔn: N/A ms		
Num. of ways: 6		Type: gG Rating: 63 A Voltage: 400 V		30mA or below: N/A ms		
Num. of phases: 3		Supply polarity confirmed: <input checked="" type="checkbox"/>		Operating at 5 IΔn: N/A ms		
Phase sequence confirmed: <input checked="" type="checkbox"/>				Time delay (if applicable): NA		

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2
																		V	M(Ω)	M(Ω)								
1/L1	GF Staircase Lighting	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.58	N/A	250	LIM	>299	✓	0.78	29.8	28.7	✓	N/A
1/L2	FF Staircase Lighting	A	E	7	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.62	N/A	250	LIM	>299	✓	0.84	39.7	28.7	✓	N/A
1/L3	2F Staircase Lighting	A	E	7	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	LIM	0.71	N/A	250	LIM	>299	✓	0.90	29.7	28.6	✓	N/A
2/L1	GF IT Hub Lighting	A	E	2	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.35	N/A	250	LIM	>299	✓	0.54	29.7	28.6	✓	N/A
2/L2	FF Circulation Lighting	A	E	11	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.66	29.7	29.7	✓	N/A
2/L3	2F Circulation Lighting	A	E	11	2.5	1.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.60	N/A	250	LIM	>299	✓	0.79	29.7	28.7	✓	N/A
3/L1	GF Bus Power Supply	A	E	1	2.5	1.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.50	N/A	250	LIM	>299	✓	0.70	28.7	29.6	✓	N/A
3/L2	FF Circulation Lighting	A	E	13	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.57	N/A	250	LIM	>299	✓	0.75	28.7	29.6	✓	N/A
3/L3	2F Circulation Lighting	A	E	13	2.5	1.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.70	N/A	250	LIM	>299	✓	0.89	29.7	28.5	✓	N/A
4/L1	GF Booster Room Lighting	A	E	1	2.5	1.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.56	N/A	250	LIM	>299	✓	0.76	28.7	29.6	✓	N/A
4/L2	Colonnade Lighting	A	E	6	2.5	1.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.71	N/A	250	LIM	>299	✓	0.92	29.7	28.5	✓	N/A
4/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
5/L1	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
5/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
5/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
6/L1	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
6/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
6/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)		
Location	Flat 3 Kitchen (Schneider)	Supply to distribution board is from	Sub Mains(DB/Busbar 2, 3/L2)		Associated RCD(if any): BS (EN)	Loop impedance	102118371	
Designation	DB/CL2	Overcurrent protective device for the distribution circuit: Type	gG	Rating	63	A	Insulation resistance	102118371
Num. of ways	18	BS(EN)	88-2	HRC			Continuity	102118371
Supply polarity confirmed	<input checked="" type="checkbox"/>	Voltage	230	V			RCD	102118371
Phase sequence confirmed	<input type="checkbox"/>	Operating at 1 IΔn		N/A	ms	(if applicable)		
		Operating at 5 IΔn		N/A	ms			
		Time delay (if applicable)		NA				

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn	30mA or below 5 IΔn			RCD (✓)	APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2
																		All circuits to be completed using R1R2 or R2, not both										
1/L2	Common Room Lighting	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.28	N/A	250	LIM	>299	✓	0.45	28.7	29.7	✓	N/A
2/L2	Bedroom Lights 1,2,3	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.50	N/A	250	LIM	>299	✓	0.67	28.7	28.6	✓	N/A
3/L2	Bedroom Lights 4,5,6	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.58	N/A	250	LIM	>299	✓	0.75	29.7	28.6	✓	N/A
4/L2	Bedroom Lights 7,8	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.62	N/A	250	LIM	>299	✓	0.80	29.7	28.7	✓	N/A
5/L2	Bedroom Lights 9,10	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.65	N/A	250	LIM	>299	✓	0.82	29.7	28.7	✓	N/A
6/L2	Common Room Ring Main 1	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.35	0.36	0.44	✓	0.19	N/A	250	LIM	>299	✓	0.33	28.7	29.6	✓	N/A
7/L2	Common Room Ring Main 2	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.29	0.30	0.42	✓	0.17	N/A	250	LIM	>299	✓	0.32	28.7	29.6	✓	N/A
8/L2	Common Room Cooker 1	A	E	1	10	4	0.4	61009 RCD/	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.24	29.7	29.7	✓	N/A
9/L2	Common Room Cooker 2	A	E	1	10	4	0.4	61009 RCD/	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.23	28.6	28.5	✓	N/A
10/L2	Sub Mains(DB/CL2/1, DB/CL2/2, DB/CL2/3)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.30	0.31	0.42	✓	0.18	N/A	250	LIM	>299	✓	0.44	29.7	38.5	✓	N/A
11/L2	Sub Mains(DB/CL2/4, DB/CL2/5, DB/CL2/6)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.38	0.39	0.56	✓	0.23	N/A	250	LIM	>299	✓	0.46	29.7	28.6	✓	N/A
12/L2	Sub Mains(DB/CL2/9, DB/CL2/10)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.41	0.60	✓	0.24	N/A	250	LIM	>299	✓	0.48	28.7	28.7	✓	N/A
13/L2	Sub Mains(DB/CL2/7, DB/CL2/8)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.37	0.37	0.55	✓	0.23	N/A	250	LIM	>299	✓	0.47	29.7	29.7	✓	N/A
14/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
15/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
16/L2	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 3 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL2, 10/L2)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL2/3		Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Operating at 1 IΔn 29.7 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn 38.5 ms
				Time delay (if applicable) NA
				Test instrument serial number(s)
				Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)		
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both
1/L2	Room 3 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.60	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 3 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL2, 11/L2)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL2/4		Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Operating at 1 IΔn 29.7 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn 28.6 ms
				Time delay (if applicable) NA
				Test instrument serial number(s)
				Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS														TEST RESULTS													
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														r1	r2	r3											
1/L2	Room 4 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 3 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL2, 11/L2)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL2/5		Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Operating at 1 IΔn 29.7 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn 28.6 ms
				Time delay (if applicable) NA
				Test instrument serial number(s)
				Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
1/L2	Room 5 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 3 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL2, 12/L2)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL2/9		Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Operating at 1 IΔn 28.7 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn 28.7 ms
				Time delay (if applicable) NA
				Test instrument serial number(s)
				Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)		
														r1	rn	r2										Fig 8 check (✓)	R1 + R2
1/L2	Room 9 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:		
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN				
Distribution board details - Complete in every case Location: Flat 3 Cupboard (Schneider) Designation: DB/CL2/8 Num. of ways: 1 Num. of phases: 1 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains (DB/CL2, 13/L2) Overcurrent protective device for the distribution circuit: Type: B Rating: 32 A Voltage: 230 V			Characteristics at this distribution board Associated RCD (if any): BS (EN) N/A Operating at 1 IΔn: 29.7 ms Above 30mA (if applicable) Z _s : 0.47 Ω No. of poles: N/A 30mA or below I _{pr} : 0.44 kA IΔn: 30 Operating at 5 IΔn: 29.7 ms Time delay (if applicable): NA	Test instrument serial number(s) Loop impedance: 102118371 Insulation resistance: 102118371 Continuity: 102118371 RCD: 102118371

CIRCUIT DETAILS													TEST RESULTS																	
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation				
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L2	Room 8 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.68	N/A	N/A	N/A	N/A		

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 4 Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 2, 2/L1)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/CL1	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 18 Num. of phases: 1	BS(EN) 88-2 HRC	30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Time delay (if applicable): NA	RCD: 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2	R2																			
1/L1	Common Room Lights	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.26	N/A	250	LIM	>299	✓	0.45	29.6	29.7	✓	N/A
2/L1	Lights 4,5,6	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.52	N/A	250	LIM	>299	✓	0.70	28.7	29.7	✓	N/A
3/L1	Lights 1,2,3	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.47	N/A	250	LIM	>299	✓	0.65	28.7	28.7	✓	N/A
4/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
5/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
6/L1	Common Room Ring 1	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.30	0.31	0.42	✓	0.18	N/A	250	LIM	>299	✓	0.29	29.7	28.7	✓	N/A
7/L1	Common Room Ring 2	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.44	0.44	0.60	✓	0.25	N/A	250	LIM	>299	✓	0.40	29.7	28.6	✓	N/A
8/L1	Common Room Cooker 1	A	E	1	10	4	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.24	38.7	28.7	✓	N/A
9/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
10/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
11/L1	Sub Mains(DB/CL1/4, DB/CL1/5, DB/CL1/6)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.34	0.35	0.51	✓	0.21	N/A	250	LIM	>299	✓	0.45	38.7	28.7	✓	N/A
12/L1	Sub Mains(DB/CL1/1, DB/CL1/2, DB/CL1/3)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.40	0.42	0.64	✓	0.25	N/A	250	LIM	>299	✓	0.50	29.6	29.7	✓	N/A
13/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
14/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
15/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
16/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
17/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 4 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL1, 11/L1)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL1/4		Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Above 30mA (if applicable) Operating at 1 IΔn 38.7 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below Operating at 5 IΔn 28.7 ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable) NA
				Test instrument serial number(s)
				Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS														TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r2	r3												R1 + R2
1/L1	Room 4 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.09	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 4 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL1, 11/L1)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL1/5		Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Above 30mA (if applicable) Operating at 1 IΔn 38.7 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below Operating at 5 IΔn 28.7 ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable) NA
				Test instrument serial number(s)
				Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
1/L1	Room 5 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 4 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL1, 12/L1)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL1/3		Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Operating at 1 IΔn 29.6 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn 29.7 ms
				Time delay (if applicable) NA
				Test instrument serial number(s)
				Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS														TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2
1/L1	Room 3 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.67	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)					
Location	Flat 7 Kitchen (Schneider)	Supply to distribution board is from	Sub Mains(DB/Busbar 2, 5/L1)		Associated RCD(if any): BS (EN)	Above 30mA (if applicable)					
Designation	DB/CL6	Overcurrent protective device for the distribution circuit: Type	gG	Rating	63	A	Voltage	230	V	Loop impedance	102118371
Num. of ways	18	Num. of phases	1	BS(EN)	88-2	HRC	Operating at 1 IΔn	N/A	ms	Insulation resistance	102118371
Supply polarity confirmed	<input checked="" type="checkbox"/>	Phase sequence confirmed	<input type="checkbox"/>	Operating at 5 IΔn	N/A	ms	Time delay (if applicable)	NA	ms	Continuity	102118371
										RCD	102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn	30mA or below 5 IΔn			RCD (✓)	APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2
																		All circuits to be completed using R1R2 or R2, not both										
1/L1	Common Room Lighting	A	E	7	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.34	28.7	29.6	✓	N/A
2/L1	Bedroom Lights 1,2,3	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.34	N/A	250	LIM	>299	✓	0.53	29.7	28.7	✓	N/A
3/L1	Bedroom Lights 9,10	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.40	N/A	250	LIM	>299	✓	0.60	29.8	28.6	✓	N/A
4/L1	Bedroom Lights 7,8	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.39	N/A	250	LIM	>299	✓	0.56	38.6	29.6	✓	N/A
5/L1	Bedroom Lights 4,5,6	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.43	N/A	250	LIM	>299	✓	0.59	29.7	28.7	✓	N/A
6/L1	Common Room Ring Main 1	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.30	0.30	0.42	✓	0.17	N/A	250	LIM	>299	✓	0.30	29.7	39.6	✓	N/A
7/L1	Common Room Ring Main 2	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.42	0.41	0.60	✓	0.24	N/A	250	LIM	>299	✓	0.42	29.8	28.5	✓	N/A
8/L1	Common Room Cooker 1	A	E	1	10	4	0.4	61009 RCD/	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.23	29.7	38.6	✓	N/A
9/L1	Common Room Cooker 2	A	E	1	10	4	0.4	61009 RCD/	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.22	29.7	28.7	✓	N/A
10/L1	Sub Mains(DB/CL6/1, DB/CL6/2, DB/CL6/3)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.32	0.32	0.42	✓	0.17	N/A	250	LIM	>299	✓	0.46	29.6	28.6	✓	N/A
11/L1	Sub Mains(DB/CL6/4, DB/CL6/5, DB/CL6/6)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.34	0.34	0.46	✓	0.18	N/A	250	LIM	>299	✓	0.43	29.7	28.7	✓	N/A
12/L1	Sub Mains(DB/CL6/9, DB/CL6/10)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.40	0.60	✓	0.24	N/A	250	LIM	>299	✓	0.48	29.7	28.7	✓	N/A
13/L1	Sub Mains(DB/CL6/7, DB/CL6/8)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.38	0.38	0.58	✓	0.22	N/A	250	LIM	>299	✓	0.46	29.6	29.6	✓	N/A
14/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
15/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
16/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Flat 7 Cupboard (Schneider)	Designation: DB/CL6/2	Supply to distribution board is from: Sub Mains(DB/CL6, 10/L1)	Associated RCD(if any): BS (EN) N/A	Above 30mA (if applicable) Operating at 1 IΔn 29.6 ms
Num. of ways: 1	Num. of phases: 1	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V	Zs 0.46 Ω	30mA or below Operating at 5 IΔn 28.6 ms
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>		No. of poles: N/A	Time delay (if applicable): NA
			Test instrument serial number(s)	
			Loop impedance	102118371
			Insulation resistance	102118371
			Continuity	102118371
			RCD	102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														r1	rn	r2											
1/L1	Room 2 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.52	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Flat 7 Cupboard (Schneider)	Designation: DB/CL6/8	Supply to distribution board is from: Sub Mains(DB/CL6, 13/L1)	Associated RCD(if any): BS (EN) N/A	Above 30mA (if applicable) Operating at 1 IΔn 29.6 ms
Num. of ways: 1	Num. of phases: 1	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V	Z _s 0.46 Ω	30mA or below Operating at 5 IΔn 29.6 ms
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>		I _{pf} 0.51 kA	IΔn 30
			Time delay (if applicable) NA	
			Test instrument serial number(s)	
			Loop impedance	102118371
			Insulation resistance	102118371
			Continuity	102118371
			RCD	102118371

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r _n	r2												R1 + R2
1/L1	Room 8 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.57	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 8 Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 2, 4/L3)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/CL5	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 18 Num. of phases: 1	BS(EN) 88-2 HRC	30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 102118371
		Time delay (if applicable): NA	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
								R1 + R2	R2																			
1/L3	Common Room Lights	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.41	29.8	28.7	✓	N/A
2/L3	Lights Rooms 1,2,3	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.59	28.7	28.7	✓	N/A
3/L3	Lights Rooms 4,5,6	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.57	N/A	250	LIM	>299	✓	0.75	29.6	28.6	✓	N/A
4/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
5/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
6/L3	Common Room Ring 1	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.29	0.28	0.40	✓	0.17	N/A	250	LIM	>299	✓	0.30	29.7	28.7	✓	N/A
7/L3	Common Room Ring 2	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	C	32	10	30	0.54	0.35	0.35	0.47	✓	0.19	N/A	250	LIM	>299	✓	0.34	29.6	28.7	✓	N/A
8/L3	Common Room Cooker 1	A	E	1	10	4	0.4	61009 RCD/	C	32	10	30	0.54	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.22	29.7	28.7	✓	N/A
9/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
10/L3	Sub Mains(DB/CL5/4, DB/CL5/5, DB/CL5/6)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.45	0.45	0.62	✓	0.26	N/A	250	LIM	>299	✓	0.47	29.7	28.7	✓	N/A
11/L3	Sub Mains(DB/CL5/1, DB/CL5/2, DB/CL5/3)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	30	0.54	0.44	0.44	0.60	✓	0.25	N/A	250	LIM	>299	✓	0.46	29.7	29.6	✓	N/A
12/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
13/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
14/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
15/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
16/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
17/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 8 Cupboard (Schneider)	Supply to distribution board is from: Sub Mains(DB/CL5, 10/L3)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/CL5/4	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Operating at 1 IΔn: 29.7 ms	Insulation resistance: 102118371
Num. of ways: 1 Num. of phases: 1	BS(EN) 61009 RCD/RCBO	30mA or below: 28.7 ms	Continuity: 102118371
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Time delay (if applicable): NA	RCD: 102118371

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r2	r2												R1 + R2	R2	
					80%	80%		80%	80%	80%				80%	80%	80%	80%	80%	80%	80%	80%			80%	80%	80%	80%	80%	80%	
1/L3	Room 4 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A		
				</																										

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 8 Cupboard (Schneider)	Supply to distribution board is from Sub Mains(DB/CL5, 10/L3)	Associated RCD(if any): BS (EN) N/A		Test instrument serial number(s) Loop impedance 102118371 Insulation resistance 102118371 Continuity 102118371 RCD 102118371
Designation DB/CL5/5	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Operating at 1 IΔn 29.7 ms		
Num. of ways 1 Num. of phases 1	BS(EN) 61009 RCD/RCBO	30mA or below		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Operating at 5 IΔn 28.7 ms		
		Time delay (if applicable) NA		

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
1/L3	Room 5 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 8 Cupboard (Schneider)	Designation DB/CL5/6	Supply to distribution board is from Sub Mains(DB/CL5, 10/L3)	Associated RCD(if any): BS (EN) N/A	Above 30mA (if applicable) Operating at 1 IΔn 29.7 ms
Num. of ways 1	Num. of phases 1	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Z _s 0.47 Ω	30mA or below No. of poles N/A
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>		I _{pr} 0.48 kA	IΔn 30
				Operating at 5 IΔn 28.7 ms
			Time delay (if applicable) NA	
			Test instrument serial number(s)	
			Loop impedance	102118371
			Insulation resistance	102118371
			Continuity	102118371
			RCD	102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														r1	r _n	r2											
1/L3	Room 6 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.54	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 8 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL5, 11/L3)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL5/2		Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V		Operating at 1 IΔn 29.7 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn 29.6 ms
				Time delay (if applicable) NA
				Test instrument serial number(s)
				Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
1/L3	Room 2 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.60	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 12 Kitchen (Schneider)	Supply to distribution board is from Sub Mains(DB/Busbar 2, 7/L2)	Associated RCD(if any): BS (EN) N/A		Test instrument serial number(s) Loop impedance 102118371 Insulation resistance 102118371 Continuity 102118371 RCD 102118371
Designation DB/CL9	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn N/A ms		
Num. of ways 15 Num. of phases 1		Zs 0.16 Ω No. of poles N/A		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Ipr 1.33 kA IΔn N/A Operating at 5 IΔn N/A ms		
		Time delay (if applicable) NA		

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L2	Lights Common Room	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.37	29.8	28.7	✓	N/A
2/L2	Lights 4,5,6	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.36	N/A	250	LIM	>299	✓	0.54	29.7	28.6	✓	N/A
3/L2	Lights 1,2,3	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.60	29.7	28.6	✓	N/A
4/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
5/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
6/L2	Common Room Ring 1	A	E	6	2X2.5	2X1.5	0.4	61009 RCD/	B	32	10	30	0.54	0.34	0.34	0.42	✓	0.18	N/A	250	LIM	>299	✓	0.43	29.7	28.7	✓	N/A
7/L2	Common Room Ring 2	A	E	5	2X2.5	2X1.5	0.4	61009 RCD/	B	32	10	30	0.54	0.28	0.27	0.39	✓	0.14	N/A	250	LIM	>299	✓	0.30	28.7	29.7	✓	N/A
8/L2	Common Room Cooker	A	E	1	10	4	0.4	61009 RCD/	B	32	10	30	0.54	N/A	N/A	N/A	N/A	0.03	N/A	250	LIM	>299	✓	0.21	29.6	29.7	✓	N/A
9/L2	Sub Mains(DB/CL9/4, DB/CL9/5, DB/CL9/6)	A	E	9	2X2.5	2X1.5	0.4	61009 RCD/RCBO	B	32	10	30	0.54	0.45	0.46	0.62	✓	0.27	N/A	250	LIM	>299	✓	0.50	29.7	29.5	✓	N/A
10/L2	Sub Mains(DB/CL9/1, DB/CL9/2, DB/CL9/3)	A	E	9	2X2.5	2X1.5	0.4	61009 RCD/RCBO	B	32	10	30	0.54	0.44	0.43	0.60	✓	0.26	N/A	250	LIM	>299	✓	0.47	29.7	29.8	✓	N/A
11/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
12/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
13/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
14/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
15/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 12 Cupboard (Schneider)	Designation DB/CL9/4	Supply to distribution board is from Sub Mains(DB/CL9, 9/L2)	Associated RCD(if any): BS (EN) N/A	Above 30mA (if applicable) Operating at 1 IΔn 29.7 ms
Num. of ways 1	Num. of phases 1	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V	Z _s 0.50 Ω	No. of poles N/A
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>		I _{pf} 0.48 kA	IΔn 30
			Operating at 5 IΔn 29.5 ms	Time delay (if applicable) NA
			Test instrument serial number(s)	
			Loop impedance	102118371
			Insulation resistance	102118371
			Continuity	102118371
			RCD	102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														r1	r _n	r2											
1/L2	Room 4 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.57	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:		
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN				
Distribution board details - Complete in every case Location: Flat 12 Cupboard (Schneider) Designation: DB/CL9/2 Num. of ways: 1 Num. of phases: 1 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains (DB/CL9, 10/L2) Overcurrent protective device for the distribution circuit: Type: B Rating: 32 A Voltage: 230 V			Characteristics at this distribution board Associated RCD (if any): BS (EN) N/A Operating at 1 IΔn: 29.7 ms Above 30mA (if applicable) Z _s : 0.47 Ω No. of poles: N/A 30mA or below I _{pr} : 0.48 kA IΔn: 30 Operating at 5 IΔn: 29.8 ms Time delay (if applicable): NA	Test instrument serial number(s) Loop impedance: 102118371 Insulation resistance: 102118371 Continuity: 102118371 RCD: 102118371

CIRCUIT DETAILS													TEST RESULTS																	
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation				
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L2	Room 1 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.54	N/A	N/A	N/A	N/A		

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 11 Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 2, 8/L3)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/CL10	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 18 Num. of phases: 1	BS(EN) 88-2 HRC	30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable): NA	RCD: 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2
																		All circuits to be completed using R1R2 or R2, not both										
1/L3	Common Room Lighting	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.30	N/A	250	LIM	>299	✓	0.47	29.7	28.7	✓	N/A
2/L3	Bedroom Lights 1,2,3	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.48	N/A	250	LIM	>299	✓	0.66	28.7	28.6	✓	N/A
3/L3	Bedroom Lights 9,10	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.68	N/A	250	LIM	>299	✓	0.87	28.6	29.7	✓	N/A
4/L3	Bedroom Lights 7,8	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.60	N/A	250	LIM	>299	✓	0.79	28.7	28.7	✓	N/A
5/L3	Bedroom Lights 4,5,6	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.50	N/A	250	LIM	>299	✓	0.67	29.6	28.5	✓	N/A
6/L3	Common Room Ring Main 1	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.43	0.42	0.60	✓	0.25	N/A	250	LIM	>299	✓	0.43	29.7	29.7	✓	N/A
7/L3	Common Room Ring Main 2	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.29	0.27	0.42	✓	0.18	N/A	250	LIM	>299	✓	0.34	29.7	29.6	✓	N/A
8/L3	Common Room Cooker 1	A	E	1	10	4	0.4	61009 RCD/	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.21	29.7	38.7	✓	N/A
9/L3	Common Room Cooker 2	A	E	1	10	4	0.4	61009 RCD/	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.23	28.7	29.6	✓	N/A
10/L3	Sub Mains(DB/CL10/1, DB/CL10/2, DB/CL10/3)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.35	0.36	0.49	✓	0.21	N/A	250	LIM	>299	✓	0.45	28.6	29.5	✓	N/A
11/L3	Sub Mains(DB/CL10/4, DB/CL10/5, DB/CL10/6)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.43	0.43	0.60	✓	0.26	N/A	250	LIM	>299	✓	0.52	29.7	29.7	✓	N/A
12/L3	Sub Mains(DB/CL10/7, DB/CL10/8)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.41	0.41	0.58	✓	0.25	N/A	250	LIM	>299	✓	0.55	28.7	29.6	✓	N/A
13/L3	Sub Mains(DB/CL10/10, DB/CL10/9)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.39	0.37	0.54	✓	0.23	N/A	250	LIM	>299	✓	0.51	29.6	29.7	✓	N/A
14/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
15/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
16/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 11 Cupboard (Schneider)	Designation DB/CL10/9	Supply to distribution board is from Sub Mains(DB/CL10, 13/L3)	Associated RCD(if any): BS (EN) N/A	Above 30mA (if applicable) Operating at 1 IΔn 29.6 ms
Num. of ways 1	Num. of phases 1	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V	Zs 0.51 Ω	No. of poles N/A
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>		Ipf 0.45 kA	IΔn 30
			Time delay (if applicable) NA	Operating at 5 IΔn 29.7 ms
			Test instrument serial number(s)	
			Loop impedance	102118371
			Insulation resistance	102118371
			Continuity	102118371
			RCD	102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
1/L3	Room 9 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 11 Cupboard (Schneider)	Supply to distribution board is from Sub Mains(DB/CL10, 13/L3)	Associated RCD(if any): BS (EN) N/A		Test instrument serial number(s) Loop impedance 102118371 Insulation resistance 102118371 Continuity 102118371 RCD 102118371
Designation DB/CL10/10	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V	Operating at 1 IΔn 29.6 ms		
Num. of ways 1 Num. of phases 1	BS(EN) 61009 RCD/RCBO	30mA or below		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Operating at 5 IΔn 29.7 ms		
		Time delay (if applicable) NA		

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r2	r2												R1 + R2
					80%	(Ω)		(Ω)	(Ω)	(Ω)				(Ω)	(Ω)													
1/L3	Room 10 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.07	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 11 Kitchen (Schneider)	Supply to distribution board is from Sub Mains(DB/Busbar 2, 6/TP)	Associated RCD(if any): BS (EN) N/A		Test instrument serial number(s) Loop impedance 102118371 Insulation resistance 102118371 Continuity 102118371 RCD 102118371
Designation DB/LL3/L	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400 V	Operating at 1 IΔn Above 30mA (if applicable) N/A ms		
Num. of ways 6 Num. of phases 3	BS(EN) 88-2 HRC	30mA or below No. of poles N/A		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Operating at 5 IΔn N/A ms		
		Time delay (if applicable) NA		

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	APCD (✓)			
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	3F Stair Lighting	A	E	7	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.01	N/A	250	LIM	>299	✓	0.23	29.7	28.6	✓	N/A
1/L2	4F Stair Lighting	A	E	7	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.01	N/A	250	LIM	>299	✓	0.23	28.7	29.5	✓	N/A
1/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
2/L1	3F Circulation Lighting	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.01	N/A	250	LIM	>299	✓	0.20	29.7	33.6	✓	N/A
2/L2	4F Circulation Lighting	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.24	29.7	29.6	✓	N/A
2/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
3/L1	3F Circulation Lighting	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.02	N/A	250	LIM	>299	✓	0.24	29.6	29.7	✓	N/A
3/L2	4F Circulation Lighting	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.01	N/A	250	LIM	>299	✓	0.23	29.7	29.6	✓	N/A
3/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
4/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
4/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
4/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
5/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
5/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
5/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
6/L1	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
6/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
6/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 20/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 11 Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 2, 6/TP)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/LL3/P	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 8 Num. of phases: 3	BS(EN) 88-2 HRC	30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 102118371
		Time delay (if applicable): NA	

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	3F Cleaners Sockets	A	E	5	2X2.5	2X1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.64	0.65	1.06	✓	0.41	N/A	250	LIM	>299	✓	0.58	39.7	28.7	✓	N/A
1/L2	4F Cleaners Sockets	A	E	5	2X2.5	2X1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.67	0.67	1.10	✓	0.43	N/A	250	LIM	>299	✓	0.60	34.7	22.4	✓	N/A
1/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
2/L1	3F Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.43	N/A	N/A	N/A	N/A
2/L2	4F Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.41	N/A	N/A	N/A	N/A
2/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
3/L1	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
3/L2	4F Head of Staircore AOV	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A
3/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
4/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
5/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
6/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
7/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
8/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR

110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 14 Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 2, 9/L1)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/CL13	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 18 Num. of phases: 1	BS(EN) 88-2 HRC	30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 102118371
		Time delay (if applicable): NA	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			APDD (✓)			
														r1	r2	r2										Fig 8 check (✓)	R1 + R2	R2
																		All circuits to be completed using R1R2 or R2, not both										
1/L1	Lights Common Room	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.39	29.8	28.7	✓	N/A
2/L1	Lights Room 4,5	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.31	N/A	250	LIM	>299	✓	0.52	29.7	28.7	✓	N/A
3/L1	Lights Room 6,7	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.34	N/A	250	LIM	>299	✓	0.56	29.7	28.6	✓	N/A
4/L1	Lights Room 8,9,10	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.37	N/A	250	LIM	>299	✓	0.59	29.7	28.5	✓	N/A
5/L1	Lights Room 1,2,3	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.49	N/A	250	LIM	>299	✓	0.67	28.7	28.7	✓	N/A
6/L1	Common Room Ring 1	A	E	6	2x2.5	2x2.5	0.4	61009 RCD/	B	32	10	30	0.54	0.42	0.41	0.59	✓	0.24	N/A	250	LIM	>299	✓	0.40	26.8	28.7	✓	N/A
7/L1	Common Room Ring 2	A	E	5	2x2.5	2x2.5	0.4	61009 RCD/	B	32	10	30	0.54	0.28	0.28	0.42	✓	0.18	N/A	250	LIM	>299	✓	0.36	29.7	28.7	✓	N/A
8/L1	Common Room Cooker 1	A	E	1	10	4	0.4	61009 RCD/	B	32	10	30	0.54	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.22	29.7	29.6	✓	N/A
9/L1	Common Room Cooker 2	A	E	1	10	4	0.4	61009 RCD/	B	32	10	30	0.54	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.21	29.7	28.7	✓	N/A
10/L1	Sub Mains(DB/CL13/4, DB/CL13/5)	A	E	6	2x2.5	2x2.5	0.4	61009 RCD/RCBO	B	32	10	30	0.54	0.44	0.42	0.60	✓	0.24	N/A	250	LIM	>299	✓	0.47	29.6	29.6	✓	N/A
11/L1	Sub Mains(DB/CL13/6, DB/CL13/7)	A	E	6	2x2.5	2x2.5	0.4	61009 RCD/RCBO	B	32	10	30	0.54	0.40	0.40	0.58	✓	0.22	N/A	250	LIM	>299	✓	0.50	29.7	39.7	✓	N/A
12/L1	Sub Mains(DB/CL13/8, DB/CL13/9, DB/CL13/10)	A	E	6	2x2.5	2x2.5	0.4	61009 RCD/RCBO	B	32	10	30	0.54	0.37	0.38	0.56	✓	0.20	N/A	250	LIM	>299	✓	0.48	29.7	28.7	✓	N/A
13/L1	Sub Mains(DB/CL13/1, DB/CL13/2, DB/CL13/3)	A	E	6	2x2.5	2x2.5	0.4	61009 RCD/RCBO	B	32	10	30	0.54	0.39	0.39	0.58	✓	0.22	N/A	250	LIM	>299	✓	0.46	29.7	29.6	✓	N/A
14/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
15/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
16/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 14 Cupboard (Schneider)	Designation DB/CL13/6	Supply to distribution board is from Sub Mains(DB/CL13, 11/L1)	Associated RCD(if any): BS (EN) N/A	Above 30mA (if applicable) Operating at 1 IΔn 29.7 ms
Num. of ways 1	Num. of phases 1	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V	Z _s 0.50 Ω No. of poles N/A	30mA or below Operating at 5 IΔn 39.7 ms
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>		I _{pr} 0.46 kA IΔn 30	Time delay (if applicable) NA
			Test instrument serial number(s)	
			Loop impedance	102118371
			Insulation resistance	102118371
			Continuity	102118371
			RCD	102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r _n	r2												R1 + R2
1/L1	Room 6 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.57	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 14 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL13, 11/L1)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL13/7		Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Above 30mA (if applicable) Operating at 1 IΔn 29.7 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below Operating at 5 IΔn 39.7 ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable) NA
Test instrument serial number(s)				
Loop impedance 102118371				
Insulation resistance 102118371				
Continuity 102118371				
RCD 102118371				

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r2	r2												R1 + R2
1/L1	Room 7 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.07	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 14 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL13, 13/L1)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL13/2		Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Operating at 1 IΔn 29.7 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn 29.6 ms
				Time delay (if applicable) NA
				Test instrument serial number(s)
				Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS														TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
1/L1	Room 2 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.59	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 2 Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 1, 1/TP)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/LL2/L	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 6 Num. of phases: 3	BS(EN) 88-2 HRC	30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 102118371
		Time delay (if applicable): NA	

CIRCUIT DETAILS													TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn	30mA or below 5 IΔn	RCD (✓)			APDD (✓)				
														r1	r2	r3										Fig 8 check (✓)	R1 + R2	R2	V
1/L1	GF Staircase Lighting	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.21	28.7	29.7	✓	N/A	
1/L2	FF Staircase Lighting	A	E	7	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.19	28.7	28.7	✓	N/A	
1/L3	2F Staircase Lighting	A	E	7	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.20	28.7	29.7	✓	N/A	
2/L1	GF IT Hub Lighting	A	E	2	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.50	N/A	250	LIM	>299	✓	0.66	29.7	28.7	✓	N/A	
2/L2	FF Circulation Lighting	A	E	11	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.21	28.7	28.6	✓	N/A	
2/L3	2F Circulation Lighting	A	E	11	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.20	29.5	29.5	✓	N/A	
3/L1	GF Bus Power Supply	A	E	1	2.5	1.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.14	N/A	250	LIM	>299	✓	0.30	29.8	28.7	✓	N/A	
3/L2	FF Circulation Lighting	A	E	11	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.03	N/A	250	LIM	>299	✓	0.18	28.7	28.7	✓	N/A	
3/L3	2F Circulation Lighting	A	E	11	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.20	28.7	27.5	✓	N/A	
4/L1	SPARE													N/A	N/A	N/A	N/A											N/A	N/A
4/L2	SPARE													N/A	N/A	N/A	N/A											N/A	N/A
4/L3	SPARE													N/A	N/A	N/A	N/A											N/A	N/A
5/TP	SPARE													N/A	N/A	N/A	N/A											N/A	N/A
6/TP	SPARE													N/A	N/A	N/A	N/A											N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location	Flat 2 Kitchen (Schneider)	Supply to distribution board is from	Associated RCD(if any): BS (EN)		Above 30mA (if applicable)		Loop impedance
Designation	DB/LL2/P	Sub Mains(DB/Busbar 1, 1/TP)	N/A		Operating at 1 IΔn		Insulation resistance
Num. of ways	8	Overcurrent protective device for the distribution circuit: Type	BS(EN) 88-2 HRC		30mA or below		Continuity
Num. of phases	3	Rating	gG		Operating at 5 IΔn		RCD
Supply polarity confirmed	<input checked="" type="checkbox"/>	Voltage	63 A		N/A		102118371
Phase sequence confirmed	<input checked="" type="checkbox"/>		400 V				102118371
							102118371
							102118371

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn	30mA or below 5 IΔn			RCD (✓)	APDD (✓)				
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2	
																		All circuits to be completed using R1R2 or R2, not both											
1/L1	GF IT Hub Sockets	A	E	2	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	0.54	0.39	0.39	0.54	✓	0.22	N/A	250	LIM	>299	✓	0.45	28.7	29.7	✓	N/A	
1/L2	FF Cleaners Sockets	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	0.54	0.44	0.45	0.60	✓	0.25	N/A	250	LIM	>299	✓	0.51	29.7	28.7	✓	N/A	
1/L3	2F Cleaners Sockets	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	0.54	0.50	0.51	0.75	✓	0.31	N/A	250	LIM	>299	✓	0.52	29.7	28.6	✓	N/A	
2/L1	GF Main Door Access	A	E	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.34	N/A	N/A	N/A	N/A	
2/L2	FF Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.35	N/A	N/A	N/A	N/A	
2/L3	2F Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	✓	0.38	N/A	N/A	N/A	N/A	
3/L1	GF IT Hub Commando	A	E	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.34	N/A	N/A	N/A	N/A	
3/L2	SPARE													N/A	N/A	N/A	N/A											N/A	N/A
3/L3	SPARE													N/A	N/A	N/A	N/A											N/A	N/A
4/L1	GF IT Hub Commando	A	E	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.19	N/A	250	LIM	>299	✓	0.35	N/A	N/A	N/A	N/A	N/A
4/L2	SPARE													N/A	N/A	N/A	N/A											N/A	N/A
4/L3	SPARE													N/A	N/A	N/A	N/A											N/A	N/A
5/L1	SPARE													N/A	N/A	N/A	N/A											N/A	N/A
5/L2	SPARE													N/A	N/A	N/A	N/A											N/A	N/A
5/L3	SPARE													N/A	N/A	N/A	N/A											N/A	N/A
6/L1	GF Smoke Shaft AOD	A	E	1	2.5	1.5	0.4	60898 MCB	B	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.33	N/A	N/A	N/A	N/A	N/A
6/L2	SPARE													N/A	N/A	N/A	N/A											N/A	N/A
6/L3	SPARE													N/A	N/A	N/A	N/A											N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 2 Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 1, 2/L3)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/CL3	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 18 Num. of phases: 1		30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Time delay (if applicable): NA	RCD: 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2
																		All circuits to be completed using R1R2 or R2, not both										
1/L3	Lighting Common Room	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.35	28.7	29.7	✓	N/A
2/L3	Lighting Rooms 1,2	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.39	28.7	26.8	✓	N/A
3/L3	Lighting Rooms 3,4,5	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.28	N/A	250	LIM	>299	✓	0.48	28.7	29.8	✓	N/A
4/L3	Lighting Rooms 6,7,8	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.50	N/A	250	LIM	>299	✓	0.69	28.7	28.7	✓	N/A
5/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
6/L3	Common Room Ring 1	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.42	0.42	0.60	✓	0.24	N/A	250	LIM	>299	✓	0.44	28.6	28.7	✓	N/A
7/L3	Common Room Ring 2	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.28	0.28	0.42	✓	0.16	N/A	250	LIM	>299	✓	0.30	28.6	28.7	✓	N/A
8/L3	Common Room Cooker 1	A	E	1	6	2.5	0.4	61009 RCD/	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.07	N/A	250	LIM	>299	✓	0.24	29.7	28.7	✓	N/A
9/L3	Common Room Cooker 2	A	E	1	6	2.5	0.4	61009 RCD/	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.25	28.7	28.7	✓	N/A
10/L3	Sub Mains(DB/CL3/1, DB/CL3/2)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.42	0.42	0.60	✓	0.25	N/A	250	LIM	>299	✓	0.44	29.7	28.7	✓	N/A
11/L3	Sub Mains(DB/CL3/3, DB/CL3/4, DB/CL3/5)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.39	0.39	0.57	✓	0.22	N/A	250	LIM	>299	✓	0.52	28.7	29.7	✓	N/A
12/L3	Sub Mains(DB/CL3/6, DB/CL3/7, DB/CL3/8)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.28	0.28	0.43	✓	0.16	N/A	250	LIM	>299	✓	0.60	28.6	27.5	✓	N/A
13/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
14/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
15/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
16/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
17/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 6 Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 1, 4/L2)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/CL7	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 I _{Δn} : N/A ms	Insulation resistance: 102118371
Num. of ways: 18 Num. of phases: 1		30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Time delay (if applicable): NA	RCD: 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA I _{Δn} ms	30mA or below 5 I _{Δn} ms	RCD (✓)			APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Lighting Common Room	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.40	28.7	29.6	✓	N/A
2/L2	Lighting Rooms 1,2	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.47	28.7	28.6	✓	N/A
3/L2	Lighting Rooms 3,4,5	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.28	N/A	250	LIM	>299	✓	0.55	28.7	29.7	✓	N/A
4/L2	Lighting Rooms 6,7,8	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.52	N/A	250	LIM	>299	✓	0.72	29.7	29.7	✓	N/A
5/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
6/L2	Common Room Ring 1	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.43	0.43	0.60	✓	0.25	N/A	250	LIM	>299	✓	0.39	28.7	29.7	✓	N/A
7/L2	Common Room Ring 2	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.28	0.29	0.44	✓	0.16	N/A	250	LIM	>299	✓	0.27	28.7	29.7	✓	N/A
8/L2	Common Room Cooker 1	A	E	1	6	2.5	0.4	61009 RCD/	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.23	29.7	28.6	✓	N/A
9/L2	Common Room Cooker 2	A	E	1	6	2.5	0.4	61009 RCD/	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.22	29.7	29.7	✓	N/A
10/L2	Sub Mains(DB/CL7/1, DB/CL7/2)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.47	0.47	0.64	✓	0.27	N/A	250	LIM	>299	✓	0.46	29.7	28.7	✓	N/A
11/L2	Sub Mains(DB/CL7/3, DB/CL7/4, DB/CL7/5)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.39	0.40	0.56	✓	0.23	N/A	250	LIM	>299	✓	0.56	28.7	28.7	✓	N/A
12/L2	Sub Mains(DB/CL7/6, DB/CL7/7, DB/CL7/8)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.40	0.59	✓	0.23	N/A	250	LIM	>299	✓	0.65	29.7	28.7	✓	N/A
13/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
14/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
15/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
16/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
17/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 20/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board		Test instrument serial number(s)	
Location	Flat 5 Kitchen (Schneider)	Supply to distribution board is from	Associated RCD(if any): BS (EN)		Above 30mA (if applicable)		Loop impedance
Designation	DB/CL8	Sub Mains(DB/Busbar 1, 5/L3)	N/A		Operating at 1 IΔn		Insulation resistance
Num. of ways	18	Overcurrent protective device for the distribution circuit: Type	BS(EN) 88-2 HRC		30mA or below		Continuity
Supply polarity confirmed	<input checked="" type="checkbox"/>	Type	gG		Operating at 5 IΔn		RCD
Phase sequence confirmed	<input type="checkbox"/>	Rating	63		Time delay (if applicable)		102118371
		A	V				102118371
		Voltage	230				102118371

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2
																		All circuits to be completed using R1R2 or R2, not both										
1/L3	Lighting Common Room	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.38	28.7	29.7	✓	N/A
2/L3	Lighting Rooms 4,5,6	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.49	N/A	250	LIM	>299	✓	0.67	28.7	28.7	✓	N/A
3/L3	Lighting Rooms 1,2,3	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.33	N/A	250	LIM	>299	✓	0.52	29.6	28.7	✓	N/A
4/L3	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
5/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
6/L3	Common Room Ring 1	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.41	0.41	0.60	✓	0.25	N/A	250	LIM	>299	✓	0.30	28.7	28.7	✓	N/A
7/L3	Common Room Ring 2	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.39	0.38	0.58	✓	0.23	N/A	250	LIM	>299	✓	0.26	29.6	28.7	✓	N/A
8/L3	Common Room Cooker 1	A	E	1	6	2.5	0.4	61009 RCD/	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.23	29.6	29.7	✓	N/A
9/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
10/L3	Sub Mains(DB/CL8/4, DB/CL8/5, DB/CL8/6)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.46	0.46	0.64	✓	0.28	N/A	250	LIM	>299	✓	0.59	28.7	29.7	✓	N/A
11/L3	Sub Mains(DB/CL8/1, DB/CL8/2, DB/CL8/3)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.40	0.40	0.58	✓	0.25	N/A	250	LIM	>299	✓	0.50	28.7	29.7	✓	N/A
12/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
13/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
14/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
15/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
16/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
17/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 2 Cupboard (Schneider)	Supply to distribution board is from Sub Mains(DB/CL3, 11/L3)	Associated RCD(if any): BS (EN) N/A		Test instrument serial number(s) Loop impedance 102118371 Insulation resistance 102118371 Continuity 102118371 RCD 102118371
Designation DB/CL3/4	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V	Operating at 1 IΔn 28.7 ms		
Num. of ways 1 Num. of phases 1	BS(EN) 61009 RCD/RCBO	30mA or below		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Operating at 5 IΔn 29.7 ms		
		Time delay (if applicable) NA		

CIRCUIT DETAILS														TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r2	r2												R1 + R2
1/L3	Room 4 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.07	N/A	250	LIM	>299	✓	0.60	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 2 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL3, 11/L3)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL3/5		Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Operating at 1 IΔn 28.7 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn 29.7 ms
				Time delay (if applicable) NA
				Test instrument serial number(s)
				Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L3	Room 5 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.64	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 2 Cupboard (Schneider)	Supply to distribution board is from Sub Mains(DB/CL3, 12/L3)	Associated RCD(if any): BS (EN) N/A		Test instrument serial number(s)
Designation DB/CL3/7	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V	Operating at 1 IΔn 28.6 ms		
Num. of ways 1 Num. of phases 1	BS(EN) 61009 RCD/RCBO	30mA or below		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Operating at 5 IΔn 27.5 ms		
		Time delay (if applicable) NA		Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
1/L3	Room 7 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.07	N/A	250	LIM	>299	✓	0.69	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 6 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL7, 10/L2)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL7/1		Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Above 30mA (if applicable) Operating at 1 IΔn 29.7 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below Operating at 5 IΔn 28.7 ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable) NA
Test instrument serial number(s)				
Loop impedance 102118371				
Insulation resistance 102118371				
Continuity 102118371				
RCD 102118371				

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r2	r3												R1 + R2
1/L2	Room 1 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.07	N/A	250	LIM	>299	✓	0.55	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:		
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN				
Distribution board details - Complete in every case Location: Flat 6 Cupboard (Schneider) Designation: DB/CL7/2 Num. of ways: 1 Num. of phases: 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains (DB/CL7, 10/L2) Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V			Characteristics at this distribution board Associated RCD (if any): BS (EN) N/A Operating at 1 IΔn 29.7 ms Above 30mA (if applicable) Z _s 0.46 Ω No. of poles N/A 30mA or below I _{pr} 0.53 kA IΔn 30 Operating at 5 IΔn 28.7 ms Time delay (if applicable) NA	Test instrument serial number(s) Loop impedance: 102118371 Insulation resistance: 102118371 Continuity: 102118371 RCD: 102118371

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation				
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L2	Room 2 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.07	N/A	250	LIM	>299	✓	0.57	N/A	N/A	N/A	N/A		

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 6 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL7, 12/L2)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL7/6		Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Above 30mA (if applicable) Operating at 1 IΔn 29.7 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below Operating at 5 IΔn 28.7 ms
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Time delay (if applicable) NA
				Test instrument serial number(s)
				Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														r1	r2	r2											
1/L2	Room 6 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.72	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location: Flat 5 Cupboard (Schneider)	Designation: DB/CL8/4	Supply to distribution board is from: Sub Mains(DB/CL8, 10/L3)	Associated RCD(if any): BS (EN)	Above 30mA (if applicable)
Num. of ways: 1	Num. of phases: 1	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V	Operating at 1 IΔn: 28.7 ms	30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>		Ipf: 0.39 kA IΔn: 30	Operating at 5 IΔn: 29.7 ms
			Time delay (if applicable): NA	
			Test instrument serial number(s)	
			Loop impedance	102118371
			Insulation resistance	102118371
			Continuity	102118371
			RCD	102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														r1	rn	r2											
1/L3	Room 4 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.67	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 10 Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 1, 7/L1)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/CL11	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 18 Num. of phases: 1		No. of poles: N/A	Continuity: 102118371
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 102118371
		Time delay (if applicable): NA	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2
																		All circuits to be completed using R1R2 or R2, not both										
1/L1	Lighting Common Room	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.18	N/A	250	LIM	>299	✓	0.35	38.7	28.7	✓	N/A
2/L1	Lighting Rooms 1,2	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.39	28.7	37.7	✓	N/A
3/L1	Lighting Rooms 3,4,5	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.31	N/A	250	LIM	>299	✓	0.53	28.7	29.7	✓	N/A
4/L1	Lighting Rooms 6,7,8	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	3.49	N/A	N/A	N/A	N/A	0.45	N/A	250	LIM	>299	✓	0.63	28.7	26.7	✓	N/A
5/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
6/L1	Common Room Ring 1	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.43	0.43	0.60	✓	0.26	N/A	250	LIM	>299	✓	0.34	28.7	26.7	✓	N/A
7/L1	Common Room Ring 2	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.24	0.24	0.40	✓	0.13	N/A	250	LIM	>299	✓	0.25	35.5	27.5	✓	N/A
8/L1	Common Room Cooker 1	A	E	1	6	2.5	0.4	61009 RCD/	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.23	29.7	18.7	✓	N/A
9/L1	Common Room Cooker 2	A	E	1	6	2.5	0.4	61009 RCD/	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.22	28.7	28.7	✓	N/A
10/L1	Sub Mains(DB/CL11/1, DB/CL11/2)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.44	0.45	0.61	✓	0.26	N/A	250	LIM	>299	✓	0.45	28.6	28.7	✓	N/A
11/L1	Sub Mains(DB/CL11/3, DB/CL11/4, DB/CL11/5)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.38	0.38	0.57	✓	0.23	N/A	250	LIM	>299	✓	0.54	29.7	28.7	✓	N/A
12/L1	Sub Mains(DB/CL11/6, DB/CL11/7, DB/CL11/8)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.30	0.30	0.53	✓	0.18	N/A	250	LIM	>299	✓	0.67	28.7	28.7	✓	N/A
13/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
14/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
15/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
16/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
17/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 10 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL11, 10/L1)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL11/1		Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Operating at 1 IΔn 28.6 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn 28.7 ms
				Time delay (if applicable) NA
				Test instrument serial number(s)
				Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r2	r3												R1 + R2
1/L1	Room 1 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.07	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 10 Cupboard (Schneider)	Designation DB/CL11/4	Supply to distribution board is from Sub Mains(DB/CL11, 11/L1)	Associated RCD(if any): BS (EN) N/A	Above 30mA (if applicable) Operating at 1 IΔn 29.7 ms
Num. of ways 1	Num. of phases 1	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V	Z _s 0.54 Ω	30mA or below Operating at 5 IΔn 28.7 ms
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>		I _{pr} 0.42 kA	IΔn 30
				Time delay (if applicable) NA
			Test instrument serial number(s)	
			Loop impedance	102118371
			Insulation resistance	102118371
			Continuity	102118371
			RCD	102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)
														r1	r _n	r2											
1/L1	Room 4 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.62	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 1 Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 1, 3/L1)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/CL4	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 18	BS(EN) 88-2 HRC	30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed: <input checked="" type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 102118371
Phase sequence confirmed: <input type="checkbox"/>		Time delay (if applicable): NA	

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2
																		All circuits to be completed using R1R2 or R2, not both										
1/L1	Lighting Common Room	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.12	N/A	250	LIM	>299	✓	0.34	28.7	29.7	✓	N/A
2/L1	Lighting Rooms 4,5,6	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.45	N/A	250	LIM	>299	✓	0.66	37.7	28.7	✓	N/A
3/L1	Lighting Rooms 1,2,3	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.43	28.7	28.6	✓	N/A
4/L1	SPARE													N/A	N/A	N/A	N/A									N/A	N/A	
5/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
6/L1	Common Room Ring 1	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	0.54	0.40	0.41	0.60	✓	0.25	N/A	250	LIM	>299	✓	0.40	28.7	29.7	✓	N/A
7/L1	Common Room Ring 2	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	0.54	0.27	0.27	0.48	✓	0.16	N/A	250	LIM	>299	✓	0.27	28.7	26.8	✓	N/A
8/L1	Common Room Cooker 1	A	E	1	6	2.5	0.4	61009 RCD/	B	32	10	30	0.54	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.22	28.7	29.7	✓	N/A
9/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
10/L1	Sub Mains(DB/CL4/4, DB/CL4/5, DB/CL4/6)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.44	0.45	0.61	✓	0.25	N/A	250	LIM	>299	✓	0.65	28.7	28.7	✓	N/A
11/L1	Sub Mains(DB/CL4/1, DB/CL4/2, DB/CL4/3)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.09	0.39	0.39	0.58	✓	0.23	N/A	250	LIM	>299	✓	0.53	29.7	28.7	✓	N/A
12/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
13/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
14/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
15/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
16/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
17/L1	SPARE													N/A	N/A	N/A	N/A										N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 9 Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 1, 8/L2)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/CL12	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 18 Num. of phases: 1	BS(EN) 88-2 HRC	30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 102118371
		Time delay (if applicable): NA	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	APDD (✓)			
														r1	r2	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L2	Lighting Common Room	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.27	N/A	250	LIM	>299	✓	0.45	29.7	28.7	✓	N/A
2/L2	Lighting Rooms 4,5,6	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.50	N/A	250	LIM	>299	✓	0.67	28.7	29.7	✓	N/A
3/L2	Lighting Rooms 1,2,3	A	E	15	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.40	N/A	250	LIM	>299	✓	0.57	29.6	29.7	✓	N/A
4/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
5/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
6/L2	Common Room Ring 1	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	0.54	0.43	0.41	0.60	✓	0.25	N/A	250	LIM	>299	✓	0.42	20.7	29.7	✓	N/A
7/L2	Common Room Ring 2	A	E	5	2x2.5	2x1.5	0.4	61009 RCD/	B	32	10	30	0.54	0.26	0.26	0.48	✓	0.14	N/A	250	LIM	>299	✓	0.34	29.7	29.6	✓	N/A
8/L2	Common Room Cooker 1	A	E	1	6	2.5	0.4	61009 RCD/	B	32	10	30	0.54	N/A	N/A	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.24	28.7	29.6	✓	N/A
9/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
10/L2	Sub Mains(DB/CL12/4, DB/CL12/5, DB/CL12/6)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	0.54	0.48	0.47	0.62	✓	0.28	N/A	250	LIM	>299	✓	0.50	29.7	29.6	✓	N/A
11/L2	Sub Mains(DB/CL12/1, DB/CL12/2, DB/CL12/3)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	B	32	10	30	0.54	0.45	0.43	0.61	✓	0.26	N/A	250	LIM	>299	✓	0.46	29.7	28.6	✓	N/A
12/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
13/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
14/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
15/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
16/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
17/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 9 Cupboard (Schneider)	Supply to distribution board is from Sub Mains(DB/CL12, 10/L2)	Associated RCD(if any): BS (EN) N/A		Test instrument serial number(s)
Designation DB/CL12/4	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V	Operating at 1 IΔn 29.7 ms		
Num. of ways 1 Num. of phases 1	BS(EN) 61009 RCD/RCBO	30mA or below		
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Operating at 5 IΔn 29.6 ms		
		Time delay (if applicable) NA		Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r2	r3												R1 + R2
1/L2	Room 4 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.58	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing _____ Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 9 Cupboard (Schneider)		Supply to distribution board is from Sub Mains(DB/CL12, 11/L2)		Associated RCD(if any): BS (EN) N/A
Designation DB/CL12/3		Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		Operating at 1 IΔn 29.7 ms
Num. of ways 1 Num. of phases 1		BS(EN) 61009 RCD/RCBO		30mA or below
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>				Operating at 5 IΔn 28.6 ms
				Time delay (if applicable) NA
				Test instrument serial number(s)
				Loop impedance 102118371
				Insulation resistance 102118371
				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS														TEST RESULTS														
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r2	r3												R1 + R2
1/L2	Room 3 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.57	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Flat 13 Kitchen (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 1, 9/L3)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/CL14	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 18 Num. of phases: 1	BS(EN) 88-2 HRC	30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 102118371
		Time delay (if applicable): NA	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	operating RCD (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	APDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	R1 + R2	R2
																		All circuits to be completed using R1R2 or R2, not both										
1/L3	Lights Common Room	A	E	8	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.26	N/A	250	LIM	>299	✓	0.45	29.7	28.7	✓	N/A
2/L3	Lights Room 4,5	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.38	N/A	250	LIM	>299	✓	0.56	28.7	29.7	✓	N/A
3/L3	Lights Room 6,7	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	✓	0.60	28.5	29.7	✓	N/A
4/L3	Lights Room 8,9,10	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.40	N/A	250	LIM	>299	✓	0.64	28.7	29.6	✓	N/A
5/L3	Lights Room 1,2,3	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.52	N/A	250	LIM	>299	✓	0.70	29.7	28.6	✓	N/A
6/L3	Common Room Ring 1	A	E	6	2x2.5	2x2.5	0.4	61009 RCD/	B	32	10	30	0.54	0.41	0.40	0.60	✓	0.25	N/A	250	LIM	>299	✓	0.42	29.7	28.7	✓	N/A
7/L3	Common Room Ring 2	A	E	5	2x2.5	2x2.5	0.4	61009 RCD/	B	32	10	30	0.54	0.28	0.27	0.54	✓	0.20	N/A	250	LIM	>299	✓	0.36	29.7	28.7	✓	N/A
8/L3	Common Room Cooker 1	A	E	1	6	2.5	0.4	61009 RCD/	B	32	10	30	0.54	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.23	29.6	28.4	✓	N/A
9/L3	Common Room Cooker 2	A	E	1	6	2.5	0.4	61009 RCD/	B	32	10	30	0.54	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.23	29.7	29.7	✓	N/A
10/L3	Sub Mains(DB/CL14/4, DB/CL14/5)	A	E	6	2x2.5	2x2.5	0.4	61009 RCD/RCBO	B	32	10	30	0.54	0.45	0.45	0.62	✓	0.27	N/A	250	LIM	>299	✓	0.43	29.7	28.7	✓	N/A
11/L3	Sub Mains(DB/CL14/6, DB/CL14/7)	A	E	6	2x2.5	2x2.5	0.4	61009 RCD/RCBO	B	32	10	30	0.54	0.43	0.43	0.58	✓	0.26	N/A	250	LIM	>299	✓	0.46	38.7	29.7	✓	N/A
12/L3	Sub Mains(DB/CL14/8, DB/CL14/9, DB/CL14/10)	A	E	6	2x2.5	2x2.5	0.4	61009 RCD/RCBO	B	32	10	30	0.54	0.38	0.38	0.52	✓	0.25	N/A	250	LIM	>299	✓	0.44	38.7	29.6	✓	N/A
13/L3	Sub Mains(DB/CL14/1, DB/CL14/2, DB/CL14/3)	A	E	6	2x2.5	2x2.5	0.4	61009 RCD/RCBO	B	32	10	30	0.54	0.35	0.35	0.49	✓	0.23	N/A	250	LIM	>299	✓	0.42	28.7	29.7	✓	N/A
14/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
15/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A
16/L3	SPARE													N/A	N/A	N/A	N/A										N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 20/07/2022 To 20/07/2022 Date(s) live testing 20/07/2022 To 20/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 20/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		
Distribution board details - Complete in every case Location: Flat 13 Cupboard (Schneider) Designation: DB/CL14/5 Num. of ways: 1 Num. of phases: 1 Supply polarity confirmed: <input checked="" type="checkbox"/> Phase sequence confirmed: <input type="checkbox"/>		Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains (DB/CL14, 10/L3) Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V		
Characteristics at this distribution board Associated RCD (if any): BS (EN) N/A Operating at 1 IΔn: 29.7 ms (Above 30mA) Z _s : 0.43 Ω No. of poles: N/A 30mA or below I _{pr} : 0.53 kA IΔn: 30 Operating at 5 IΔn: 28.7 ms Time delay (if applicable): NA		Test instrument serial number(s) Loop impedance: 102118371 Insulation resistance: 102118371 Continuity: 102118371 RCD: 102118371		

CIRCUIT DETAILS													TEST RESULTS																	
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation				
					L/N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)			
														r1	r _n	r2												R1 + R2	R2	
1/L3	Room 5 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.53	N/A	N/A	N/A	N/A		

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location Flat 13 Cupboard (Schneider)	Designation DB/CL14/1	Supply to distribution board is from Sub Mains(DB/CL14, 13/L3)	Associated RCD(if any): BS (EN) N/A	Above 30mA (if applicable) Operating at 1 IΔn 28.7 ms
Num. of ways 1	Num. of phases 1	Overcurrent protective device for the distribution circuit: Type B Rating 32 A Voltage 230 V	Z _s 0.42 Ω No. of poles N/A	30mA or below Operating at 5 IΔn 29.7 ms
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>		I _{pf} 0.54 kA IΔn 30	Time delay (if applicable) NA
			Test instrument serial number(s)	
			Loop impedance	102118371
			Insulation resistance	102118371
			Continuity	102118371
			RCD	102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)			Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	r _n	r2												R1 + R2
1/L3	Room 1 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	10	N/A	3.49	N/A	N/A	N/A	N/A	0.08	N/A	250	LIM	>299	✓	0.51	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Plant Room (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 1, 11/TP)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/PL2/L	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 6 Num. of phases: 3	BS(EN) 88-2 HRC	30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Operating at 5 IΔn: N/A ms	RCD: 102118371
		Time delay (if applicable): NA	

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms			30mA or below 5 IΔn ms	RCD (✓)	AFDD (✓)	
														r1	rn	r2												R1 + R2
																									✓	✓		
1/L1	Plant Room Lighting	A	E	3	2.5	1.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.33	29.7	28.7	✓	N/A
1/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
1/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2/L1	Plant Stair Lighting	A	E	4	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	✓	0.37	28.7	29.7	✓	N/A
2/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
2/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
3/L1	Plant Room Access Lighting	A	E	3	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.39	38.7	29.6	✓	N/A
3/L2	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
3/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
4/TP	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
5/TP	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
6/TP	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN		

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board	Test instrument serial number(s)
Location: Plant Room (Schneider)	Supply to distribution board is from: Sub Mains(DB/Busbar 1, 11/TP)	Associated RCD(if any): BS (EN) N/A	Loop impedance: 102118371
Designation: DB/PL2/P	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 230 V	Operating at 1 IΔn: N/A ms	Insulation resistance: 102118371
Num. of ways: 8 Num. of phases: 3		30mA or below: N/A ms	Continuity: 102118371
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Time delay (if applicable): NA	RCD: 102118371

CIRCUIT DETAILS TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage	L/L, L/N	L/E, N/E	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2	V	M(Ω)	M(Ω)										
1/L1	Plant Room Ring Main	B	B	3	2.5	1.5	0.4	61009 RCD/	B	32	10	30	1.09	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.35	29.7	28.6	✓	N/A
1/L2	Head Of Shaft AOV	O	E	1	2.5	1.5	0.4	60898 MCB	C	16	10	N/A	1.09	N/A	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	✓	0.40	N/A	N/A	N/A	N/A
1/L3	Plant Room Tubular Heater	A	E	1	4	1.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A
2/TP	Roof Extract Fan 1	G	E	1	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	✓	0.43	N/A	N/A	N/A	N/A
3/TP	Roof Extract Fan 2	G	E	1	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.39	N/A	N/A	N/A	N/A
4/TP	Roof Extract Fan 3	G	E	1	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.28	N/A	250	LIM	>299	✓	0.47	N/A	N/A	N/A	N/A
5/TP	Roof Extract Fan 4	G	E	1	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.45	N/A	N/A	N/A	N/A
6/TP	Roof Extract Fan 5	G	E	1	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.23	N/A	250	LIM	>299	✓	0.44	N/A	N/A	N/A	N/A
7/TP	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
8/TP	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 19/07/2022 To 19/07/2022 Date(s) live testing 19/07/2022 To 19/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 19/07/2022 Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/ EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name: PHS Compliance	Company Address: Kid Glove Road	Postcode: WA3 3GR	Branch No.:	Scheme No.:		
Client: UPP Residential Services Ltd	Installation Address: Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode: SA1 8EN				
Distribution board details - Complete in every case Location: 3F Common Room Kitchen (Schneider) Designation: DB/LL4/L Num. of ways: 6 Num. of phases: 3 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>		Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains(DB/Busbar 1, 6/TP) Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400 V			Characteristics at this distribution board Associated RCD(if any): BS (EN) N/A Above 30mA (if applicable) ms Operating at 1 IΔn N/A ms Z _s 0.18 Ω No. of poles N/A 30mA or below I _{pr} 2.22 kA IΔn N/A Operating at 5 IΔn N/A ms Time delay (if applicable) NA	Test instrument serial number(s) Loop impedance: 102118371 Insulation resistance: 102118371 Continuity: 102118371 RCD: 102118371

CIRCUIT DETAILS													TEST RESULTS															
Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other 80% (Ω)	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing		Manual test button operation	
					L / N	CPC	Maximum disconnection	BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms	RCD (✓)			AFDD (✓)			
														r1	r _n	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
1/L1	3F Stair Lighting	A	E	7	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.07	N/A	250	LIM	>299	✓	0.27	29.7	28.7	✓	N/A
1/L2	4F Stair Lighting	A	E	7	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.25	28.7	28.6	✓	N/A
1/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
2/L1	3F Circulation Lighting	A	E	10	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.25	29.6	28.5	✓	N/A
2/L2	4F Circulation Lighting	A	E	11	2.5	1.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.06	N/A	250	LIM	>299	✓	0.26	29.7	28.6	✓	N/A
2/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
3/L1	3F Circulation Lighting	A	E	11	1.5	1	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.24	29.7	28.6	✓	N/A
3/L2	4F Circulation Lighting	A	E	6	2.5	1.5	0.4	61009 RCD/	C	10	10	30	1.75	N/A	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.25	29.7	28.4	✓	N/A
3/L3	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
4/TP	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
5/TP	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	
6/TP	SPARE													N/A	N/A	N/A	N/A						N/A			N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing: 25/07/2022 To 25/07/2022 Date(s) live testing: 25/07/2022 To 25/07/2022

Tested by: Name (capital letters) TRE LEVER Position: Electrical Test Engineer Date: 25/07/2022

Signature:

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

for Industrial/Commercial Premises

FT/
EICR 110148512



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University - Manobier 11A & Llywelyn Fawr 11B, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea		Postcode SA1 8EN	
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation		Characteristics at this distribution board
Location 3F Common Room Kitchen (Schneider)	Supply to distribution board is from Sub Mains(DB/Busbar 1, 6/TP)		Associated RCD(if any): BS (EN) N/A Above 30mA (if applicable) ms	
Designation DB/LL4/P	Overcurrent protective device for the distribution circuit: Type gG Rating 63 A Voltage 400 V		Operating at 1 IΔn N/A ms	
Num. of ways 8 Num. of phases 3	BS(EN) 88-2 HRC		30mA or below	
Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>			Operating at 5 IΔn N/A ms	
			Time delay (if applicable) NA	
			Test instrument serial number(s)	
			Loop impedance 102118371	
			Insulation resistance 102118371	
			Continuity 102118371	
			RCD 102118371	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices			Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω					Insulation resistance (Record lower reading)			Polarity (✓)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.	Rating (A)				Ring final circuits only (measured end-to-end)			Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)	Above 30mA IΔn ms	30mA or below 5 IΔn ms			RCD (✓)	AFDD (✓)			
														r1	rn	r2										Fig 8 check (✓)	All circuits to be completed using R1R2 or R2, not both	
														R1 + R2	R2													
1/L1	3F Cleaners Sockets	A	E	5	2X2.5	2X1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.32	0.32	0.44	✓	0.19	N/A	250	LIM	>299	✓	0.40	29.7	38.7	✓	N/A
1/L2	4F Cleaners Sockets	A	E	5	2X2.5	2X1.5	0.4	61009 RCD/	B	32	10	30	1.09	0.33	0.33	0.45	✓	0.19	N/A	250	LIM	>299	✓	0.43	39.6	39.7	✓	N/A
1/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
2/L1	3F Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	✓	0.37	N/A	N/A	N/A	N/A
2/L2	4F Smoke Shaft AOD	O	E	1	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.40	N/A	N/A	N/A	N/A
2/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
3/L1	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
3/L2	4F Head Of Stair Core AOV	O	E	1	2.5	2.5	0.4	60898 MCB	B	16	10	N/A	2.18	N/A	N/A	N/A	N/A	0.24	N/A	250	LIM	>299	✓	0.46	N/A	N/A	N/A	N/A
3/L3	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
4/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
5/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
6/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
7/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A
8/TP	SPARE													N/A	N/A	N/A	N/A						N/A				N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 25/07/2022 To 25/07/2022 Date(s) live testing 25/07/2022 To 25/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 25/07/2022

Signature

Wiring Types. A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

Generic Continuation

General Conditions of the Electrical Installation:

(G) SWA Cables.

Installation methods used are (E) Ran on Tray.

The final circuits are protected by 60898 MCB's with 61009 RCD Protection.

The Main Gas Supply Enters the in the Ground floor Plant Room and is Bonded with a 50mm Earthing Cable with Warning Labels Attached.

The Main water enters the property in the Top Floor Plant room and is Bonded with a 50mm Earthing Cable with Warning Labels Attached.

Observation notes

All information and documentation (where available) were used to help compile this report.

Circuit charts should be present for each Distribution Board providing relevant information in accordance with Regulation 514.9.1 of the BS 7671:2018.

On the distribution board schedules of circuit details cable types and sizes have been typed in as what is visible at the distribution board only. Circuits may have been jointed with a different cable type further along the circuit Only a percentage of the installation has been dismantled for inspection purposes. The correct connection of every conductor and link throughout the premises cannot be ensured.

Additional Comments

No access to sealed supply authority fuses therefore Characteristics of Primary Supply Protective Devices are not filled in on page 2

A new regulation 421.1.7 has been introduced recommending the installation of Arc Fault detection devices conforming to BS EN 62606 to mitigate the risk of fire in AC final circuits of a fixed installation due to arc fault currents.

This installation has been designed and installed prior to July 2018. There is no evidence of overvoltage protection within the electrical installation, we recommend Surge Protective Devices be installed in order to reduce the risk of damage to the installation by external transient overvoltage's or switching.

Overall Assessment

It is recommended a maximum 5-year period for the next inspection and test to be carried out.

Abbreviations contained in this Report: -

RHS – Right Hand Side

LHS – Left Hand Side

BOH – Back Of House.

D/B - Distribution board.

RCD - Residual current device.

CPC - Circuit protective conductor.

FCU – Fused Connection Unit.

CSA - Cross Sectional Area.

MET – Main Earthing Terminal.

LIM – Limitation (Agreed or Operational)

MIC – Sheath of MICC cable used as CPC

SWA – Steel Wire Armouring used as CPC

MW – Metalwork used as CPC.

FP – FP200 Fire Resistant Cable.

GF – Ground Floor

1F – First Floor

2F – Second Floor

3F – Third Floor

4F – Fourth Floor

ELECTRICAL INSTALLATION CONDITION REPORT

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

FT/
EICR 110148512



Remarks:

DB/LL3/P Remarks:

2/L1 - 3F Smoke Shaft AOD: FP200 Cable
2/L2 - 4F Smoke Shaft AOD: FP200 Cable
3/L2 - 4F Head of Staircore AOV : FP200 Cable

DB/LL2/P Remarks:

2/L2 - FF Smoke Shaft AOD: fp200 cable
2/L3 - 2F Smoke Shaft AOD : fp200 cable

DB/PL2/P Remarks:

1/L2 - Head Of Shaft AOV : fp200 cable

DB/LL4/P Remarks:

2/L1 - 3F Smoke Shaft AOD : FP200
2/L2 - 4F Smoke Shaft AOD : FP200
3/L2 - 4F Head Of Stair Core AOV : FP200