

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL/1 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA Below 30mA ms	Manual test button operation
					L / N	CPC		Type No.	Rating (A)				BS EN Number	Test voltage	L/L L/N M(Ω)			

TEST RESULTS

All circuits to be completed using R1R2 or R2, not both R1 + R2		Ring final circuits only (measured end-to-end)		Circuit impedance Ω		Insulation resistance (Record lower reading)		RCD testing		Manual test button operation			
r1	r2	r1	r2	Fig 5.8 & 5.9	Fig 5.10	Test voltage	L/L L/N M(Ω)	L/E N/E M(Ω)	Above 30mA Below 30mA ms	Max. Measured Zs (Ω)	Polarity	RCD	AFDD
				(✓)	(✓)	V					(✓)	(✓)	(✓)

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022 Signature *Tre Lever*

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL/3 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA Below 30mA ms	Manual test button operation
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi S _g S _a S _b	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature 

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Cymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case				
Location Flat 13 Hallway Cupboard (Schneider)	Complete only if the distribution board is not connected directly to the origin of the installation			
Designation DB/CL13/5	Supply to distribution board is from Sub Mains (DB/CL13, 7(L)3)	Characteristics at this distribution board		
Num. of ways 1	Overcurrent protective device for the distribution circuit: Type C	Associated RCD (if any): BS (EN)	Test instrument serial number(s)	
<input checked="" type="checkbox"/> Supply polarity confirmed	Rating 32	Z_s 0.24	Loop impedance 102118371	
<input type="checkbox"/> Phase sequence confirmed	Type C	No. of poles N/A	Insulation resistance 102118371	
	Rating 32	IΔn 30	Continuity 102118371	
	A Voltage 230	Time delay (if applicable) N/A	RCD 102118371	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)	Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 permitted Z _s Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)	L ₁ L ₂ L _N M(Ω)	L ₁ L ₂ N/E M(Ω)	Polarity	Max. Measured Z _s (Ω)	RCD testing	Manual test button operation									
							Type No.	BS EN Number				Rating (A)	Ring final circuits only (measured end-to-end)	All circuits to be completed using R1+R2 or R2, not both R1+R2	Test voltage V								Test voltage V	Test voltage V	Above 30mA or below 5 IΔn ms	30mA or below 5 IΔn ms	Above 30mA or below 5 IΔn ms				
1/L3	Room 5 Sockets	A	E	3	2.5	1.5	CPC	6	N/A	3.49	80%	r1	m	r2	N/A	N/A	0.21	N/A	250	250	LIM	>299	(✓)	0.45	N/A	N/A	N/A	(✓)	N/A	(✓)	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022 Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in non-metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MV Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XPLE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XPLE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL T3/5 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA Below 30mA ms	Manual test button operation
					L / N	CPC		Type No.	Rating (A)				BS EN Number	Test voltage V	L/L L/N M(Ω)			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Cymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case				
Location Flat 18 Hallway Cupboard (Schneider)	Complete only if the distribution board is not connected directly to the origin of the installation			
Designation DB/CL18/5	Supply to distribution board is from Sub Mains (DB/CL18, 7L12)	Characteristics at this distribution board		
Num. of ways 1	Overcurrent protective device for the distribution circuit: Type C	Associated RCD (if any): BS (EN) N/A	Operating at 1 IΔn 28.7 ms	Loop impedance 102118371
<input checked="" type="checkbox"/> Supply polarity confirmed	Rating 32 A	No. of poles N/A	30mA or below 30mA	Insulation resistance 102118371
	Phase sequence confirmed <input type="checkbox"/>	IΔn 30	Operating at 5 IΔn 29.7 ms	Continuity 102118371
		Time delay (if applicable) N/A		RCD 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)	Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)	Polarity	Max. Measured Zs (Ω)	RCD testing	Manual test button operation												
							Type No.	BS EN Number				Rating (A)	Ring final circuits only (measured end-to-end)	r1	r2						r	Test voltage V	L/L M(Ω)	L/N M(Ω)	L/E N/E M(Ω)							
1/L2	Room 5 Sockets	A	E	3	2.5	1.5	CPC	6	N/A	3.49	80%	r1	N/A	r2	N/A	r	N/A	0.23	N/A	250	LIM	>299	(✓)	0.51	N/A	N/A	N/A	(✓)	N/A	(✓)	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022 Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in non-metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MV Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XPLE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XPLE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL 18/5 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 50mA 50mA 50mA ms ms ms ms	Manual test button operation RCD (✓) AFDD (✓)
					CSA (mm ²)	L / N		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi, S, Zs & R1 + R2	Test voltage			
						CPC												

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Cymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation			
Location Flat 17 Hallway Cupboard (Schneider)	Supply to distribution board is from DB/CL17/7	Associated RCD(if any): BS (EN) N/A	Operating at 1 IAn 29.7 ms	
Designation DB/CL17/7	Sub Mains(DB/CL17, 7L2)	Zi 0.24 Ω	No. of poles N/A	Above 30mA 30mA or below
Num. of ways 1	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	Ipr 0.95 kA	IAn 30	Continuity 102118371
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Time delay (if applicable) N/A		

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)	Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 permitted Zs Other 80% (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)	Polarity	Max. Measured Zs (Ω)	RCD testing	Manual test button operation										
							Type No.	BS EN Number				Rating (A)	Ring final circuits only (measured end-to-end)	L/L	L/N						L/E	N/E	M(Ω)	M(Ω)						
1/L2	Room 7 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	3.49	r1	m	r2	N/A	N/A	0.28	N/A	250	V	LIM	>299	(✓)	0.54	Above 30mA 30mA or below 5 IAn ms	N/A	N/A	N/A	RCD (✓)	AFDD (✓)

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)	Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 permitted Zs Other 80% (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)	Polarity	Max. Measured Zs (Ω)	RCD testing	Manual test button operation										
							Type No.	BS EN Number				Rating (A)	Ring final circuits only (measured end-to-end)	L/L	L/N						L/E	N/E	M(Ω)	M(Ω)						
1/L2	Room 7 Sockets	A	E	3	2.5	1.5	0.4	60898 MCB	B	10	3.49	r1	m	r2	N/A	N/A	0.28	N/A	250	V	LIM	>299	(✓)	0.54	Above 30mA 30mA or below 5 IAn ms	N/A	N/A	N/A	RCD (✓)	AFDD (✓)

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature *Tre Lever*

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in non-metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MV Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XPLE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XPLE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

Created by FastTest © Copyright FastTest 2022

4th Floor, Mill 3, Pleasley Vale Business Park, Mansfield, Nottinghamshire NG19 8RL

Page 250 of 356

NA/EICR/001

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω		Insulation resistance (Record lower reading)	Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					csa (mm ²)	L / N		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi, S, & R2				All circuits to be completed using R1R2 or R2, not both R1 + R2	Test voltage		Above 30mA 50mA 100mA 500mA
	DB/CL1777						CPC									(✓)					
	Circuit designation															(✓)					

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To	Signature
		14/07/2022		14/07/2022		<i>[Signature]</i>

Tested by: Name (capital letters) **TRE LEVER** Position **Electrical Test Engineer** Date **14/07/2022**

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL18/2 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 30mA 50mA ms	Manual test button operation RCD AFDD
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi S _g S _a S _b	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL1/3 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 30mA 50mA ms	Manual test button operation RCD AFDD
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi S _g S _a S _b	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB/CLB/2 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 30mA 50mA ms	Manual test button operation	
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi S _g S _a S _b	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2				Test voltage V

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022
Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation			
Location Flat 5 Kitchen (Schneider)	Supply to distribution board is from Sub Mains (Busbar 2, 8/L2)	Associated RCD (if any): BS (EN) N/A	Operating at 1 IΔn Above 30mA ms	Test instrument serial number(s) 102118371
Designation DB/CL5	Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC	Z _e 0.16 Ω	No. of poles N/A	Insulation resistance 102118371
Num. of ways 18	Type: gg	I _{pr} 1.42 kA	IΔn N/A	Continuity 102118371
Supply polarity confirmed <input checked="" type="checkbox"/>	Rating 63	Time delay (if applicable) N/A		RCD 102118371
	A	Voltage 230	V	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 permitted Zs Other 80% (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)	Max. Measured	Polarity	RCD testing	Manual test button operation					
					L / N	CPC		BS EN Number	Type				Rating (A)	Type No.	Ring final circuits only (measured end-to-end)	g, t, p, s, c						r1	r2	r1 + r2	R2	L/L
1/L2	Common Room Lights	A	E	1	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.15	N/A	250	LIM	>299	0.34	28.7	24.5	✓	✓	N/A
2/L2	Lights Bedrooms 5,7	A	E	20	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.57	N/A	250	LIM	>299	0.75	28.9	28.7	✓	✓	N/A
3/L2	Lights Bedrooms 1,3	A	E	20	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.31	N/A	250	LIM	>299	0.49	28.7	29.7	✓	✓	N/A
4/L2	Lights Bedrooms 2,4	A	E	20	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.30	N/A	250	LIM	>299	0.52	38.7	28.6	✓	✓	N/A
5/L2	Lights Bedrooms 6,8	A	E	20	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.42	N/A	250	LIM	>299	0.66	39.8	27.8	✓	✓	N/A
6/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	✓	✓	N/A
7/L2	Sub Mains (DB/CL5/7, DB/CL5/5)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.21	0.29	0.13	N/A	N/A	250	LIM	>299	0.26	28.7	29.6	✓	✓	N/A
8/L2	Sub Mains (DB/CL5/1, DB/CL5/3)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.33	0.34	0.19	N/A	N/A	250	LIM	>299	0.20	28.7	29.8	✓	✓	N/A
9/L2	Sub Mains (DB/CL5/2, DB/CL5/4)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.35	0.49	0.23	N/A	N/A	250	LIM	>299	0.27	28.5	29.5	✓	✓	N/A
10/L2	Sub Mains (DB/CL5/6, DB/CL5/8)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.22	0.21	0.14	N/A	N/A	250	LIM	>299	0.28	29.7	28.6	✓	✓	N/A
11/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	✓	✓	N/A
12/L2	Ring Main Common Room	A	E	4	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.39	0.39	0.24	N/A	N/A	250	LIM	>299	0.26	29.7	28.7	✓	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022

Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

AA/1 - Single Core PVC Cables (4D1A), AA/2 - Multicore PVC Cables (4D2A), FF/1 - Single-core armoured PVC SWA Cables (4D3A), FF/2 - PVC SWA Cables (4D4A), AA/3 - PVC Twin & Earth (4D5), OO/1 - LSF single core cables 90°C rated (4E1A), OO/2 - Multi-core LSF cables 90°C rated (4E2A), GG/1 - Single-core armoured XLPE cables or 90°C rated (4E3A), GG/2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), HH/1 - MCCC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB/CL5 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation			
					L / N	CPC		BS EN Number	Rating (A)				Ring final circuits only (measured end-to-end)	Fig 5.4 & 5.5	All circuits to be completed using R1R2 or R2, not both R1 + R2				Test voltage V	L/L, L/N, M(Ω)		L/E, N/E, M(Ω)	Above 30mA 50mA 100mA 150mA 200mA 250mA 300mA 350mA 400mA 450mA 500mA 550mA 600mA 650mA 700mA 750mA 800mA 850mA 900mA 950mA 1000mA	30mA or below 50mA 100mA 150mA 200mA 250mA 300mA 350mA 400mA 450mA 500mA 550mA 600mA 650mA 700mA 750mA 800mA 850mA 900mA 950mA 1000mA
13/L2	Ring Main Common Room	A	E	7	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C 32	10	30	0.54	0.24	0.24	0.50	0.17	N/A	250	250	28.7	28.7	✓	✓	N/A
14/L2	Hob 1	A	E	1	6	2.5	0.4	61009 RCD/RCBO	C 32	10	30	0.54	N/A	N/A	N/A	0.06	N/A	250	250	28.6	29.8	✓	✓	N/A
15/L2	Hob 2	A	E	1	6	2.5	0.4	61009 RCD/RCBO	C 32	10	30	0.54	N/A	N/A	0.05	N/A	250	250	27.5	22.5	✓	✓	N/A	
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022 Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022 Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in non-metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MVCC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL5 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA Below 30mA ms	Manual test button operation
					L / N	CPC		BS EN Number	Type No.				Rating (A)	Test voltage	L/L L/N			

TEST RESULTS

Circuit No. and Line No.	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)	Maximum disconnection	Overcurrent protective devices	Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA Below 30mA ms	Manual test button operation			
										Ring final circuits only (measured end-to-end)	Fig 54 & 55	All circuits to be completed using R1/R2 or R2, not both R1 + R2				Test voltage	L/L L/N	L/E N/E

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022 Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022 Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/WPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Cymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case				
Location Flat 2 Hallway Cupboard (Schneider)	Complete only if the distribution board is not connected directly to the origin of the installation			
Designation DB/CL2/1	Supply to distribution board is from Sub Mains (DB/CL2, 8/L2)	Characteristics at this distribution board		
Num. of ways 1	Overcurrent protective device for the distribution circuit: Type C	Associated RCD (if any): BS (EN)	Test instrument serial number(s)	
<input checked="" type="checkbox"/> Supply polarity confirmed	Rating 32 A	Operating at 1 IΔn 29.8 ms	Loop impedance 102118371	
<input type="checkbox"/> Phase sequence confirmed	Voltage 230 V	Operating at 5 IΔn 27.8 ms	Insulation resistance 102118371	
		Time delay (if applicable) N/A	Continuity 102118371	
			RCD 102118371	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)	Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)	Polarity	Max. Measured Zs (Ω)	RCD testing	Manual test button operation												
							Type No.	BS EN Number				Rating (A)	Ring final circuits only (measured end-to-end)	L/L	L/N						L/E	N/E	M(Ω)	Above 30mA or below 5 IΔn	30mA or below 5 IΔn	ms	ms					
1/L2	Room 1 Sockets	A	E	3	2.5	1.5	CPC	6	10	6	3.49	r1	m	r2	N/A	N/A	0.19	N/A	250	V	LIM	>299	(✓)	0.48	N/A	N/A	N/A	(✓)	N/A	(✓)	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022 Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in non-metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MV Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XPLE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XPLE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL2/1 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 50mA 100mA 500mA 1000mA ms	Manual test button operation RCD (✓) AFDD (✓)
					L / N	CPC		Type No.	Rating (A)				BS EN Number	Test voltage	L/L			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To	Polarity	Max. Measured Zs (Ω)	RCD testing	Manual test button operation
		14/07/2022		14/07/2022		(✓)			(✓)

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation			
Location Flat 6 Kitchen (Schneider)	Supply to distribution board is from Sub Mains (Busbar 1, 11/L3)	Associated RCD (if any): BS (EN) N/A	Operating at 1 IΔn Above 30mA ms	Loop impedance 102118371
Designation DB/CL8	Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC	Z _e 0.17 Ω	No. of poles N/A	Insulation resistance 102118371
Num. of ways 18	Type: gg	I _{pr} 1.27 kA	IΔn N/A	Continuity 102118371
Supply polarity confirmed <input checked="" type="checkbox"/>	Rating 63	Time delay (if applicable) N/A		RCD 102118371
	A	Voltage 230	V	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other 80% (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)	Polarity	Max. Measured	RCD testing	Manual test button operation					
					L / N	CPC		BS EN Number	Type				Rating (A)	Ring final circuits only (measured end-to-end)	r1	m						r2	Test voltage	L/L	L/N	M(Ω)
1/L3	Common Room Lights	A	E	1	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.10	N/A	250	LIM	>299	✓	0.32	29.7	28.7	✓	N/A
2/L3	Lighting Bedrooms 1,2,3	A	E	30	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.41	28.7	28.7	✓	N/A
3/L3	Lighting Bedrooms 5,7	A	E	30	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.41	N/A	250	LIM	>299	✓	0.65	29.7	28.6	✓	N/A
4/L3	Lighting Bedrooms 4,6	A	E	30	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.31	N/A	250	LIM	>299	✓	0.53	29.5	24.5	✓	N/A
5/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L3	Sub Mains(DB/CL8/1, DB/CL8/2, DB/CL8/3)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.35	0.46	✓	0.20	N/A	250	LIM	>299	✓	0.20	38.7	29.6	✓	N/A
7/L3	Sub Mains(DB/CL8/5, DB/CL8/7)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.32	0.43	✓	0.18	N/A	250	LIM	>299	✓	0.23	28.7	29.7	✓	N/A
8/L3	Sub Mains(DB/CL8/4, DB/CL8/6)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.36	0.47	✓	0.21	N/A	250	LIM	>299	✓	0.21	28.7	29.6	✓	N/A
9/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L3	Common Room Ring	A	E	4	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.40	0.59	✓	0.24	N/A	250	LIM	>299	✓	0.44	28.6	28.7	✓	N/A
11/L3	Common Room Ring	A	E	7	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.24	0.33	✓	0.14	N/A	250	LIM	>299	✓	0.27	29.7	28.7	✓	N/A
12/L3	Hob 1	A	E	2	6	2.5	0.4	61009 RCD/RCBO	C	32	10	0.54	N/A	N/A	0.04	N/A	250	LIM	>299	✓	0.24	29.0	27.4	✓	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022

Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER **Position** Electrical Test Engineer **Date** 13/07/2022

Signature *Tre Lever*

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICCC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation			
Location Flat 11 Kitchen (Schneider)	Supply to distribution board is from Sub Mains (Busbar 2, 16/12)	Associated RCD (if any): BS (EN) N/A	Operating at 1 IΔn N/A	Above 30mA ms
Designation DB/CL11	Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC	Z _s 0.16 Ω	No. of poles N/A	Insulation resistance 102118371
Num. of ways 18	Type: gg	I _{pr} 1.60 kA	IΔn N/A	Continuity 102118371
Supply polarity confirmed <input checked="" type="checkbox"/>	Rating 63	Time delay (if applicable) N/A		RCD 102118371
	A	Voltage 230	V	

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 permitted Z _s Other 80% (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)	Polarity	Max. Measured	RCD testing	Manual test button operation					
					L / N	CPC		BS EN Number	Type				Rating (A)	Ring final circuits only (measured end-to-end)	r1	r2						r1 + r2	R2	L/L	L/N	L/E
1/L2	Common Room Lights	A	E	1	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	✓	0.39	39.7	28.7	✓	N/A
2/L2	Lighting Bedrooms 5,7	A	E	20	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.60	N/A	250	LIM	>299	✓	0.78	28.7	28.7	✓	N/A
3/L2	Lighting Bedrooms 1,3	A	E	20	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.35	N/A	250	LIM	>299	✓	0.53	29.7	28.7	✓	N/A
4/L2	Lighting Bedrooms 2,4	A	E	30	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.40	N/A	250	LIM	>299	✓	0.57	27.6	29.8	✓	N/A
5/L2	Lighting Bedrooms 6,8	A	E	20	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.46	N/A	250	LIM	>299	✓	0.64	28.7	29.7	✓	N/A
6/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/L2	Sub Mains (DB/CL11/5, DB/CL11/7)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.22	0.32	0.13	N/A	N/A	250	LIM	>299	✓	0.24	29.7	29.7	✓	N/A
8/L2	Sub Mains (DB/CL11/1, DB/CL11/3)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.36	0.45	0.19	N/A	N/A	250	LIM	>299	✓	0.20	29.7	28.7	✓	N/A
9/L2	Sub Mains (DB/CL11/2, DB/CL11/4)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.36	0.44	0.18	N/A	N/A	250	LIM	>299	✓	0.20	28.7	29.7	✓	N/A
10/L2	Sub Mains (DB/CL11/6, DB/CL11/8)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.23	0.32	0.12	N/A	N/A	250	LIM	>299	✓	0.18	27.8	28.7	✓	N/A
11/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/L2	Ring Main Common Room	A	E	4	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.40	0.40	0.24	N/A	N/A	250	LIM	>299	✓	0.43	37.8	27.8	✓	N/A

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022

Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022

Signature *Tre Lever*

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

AA1 - Single Core PVC Cables (4D1A), AA2 - Multicore PVC Cables (4D2A), FF1 - Single-core armoured PVC SWA Cables (4D3A), FF2 - PVC SWA Cables (4D4A), AA3 - PVC Twin & Earth (4D5), OO1 - LSF single core cables 90°C rated (4E1A), OO2 - Multi-core LSF cables 90°C rated (4E2A), GG1 - Single-core armoured XLPE cables or 90°C rated (4E3A), GG2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), HH1 - MICC exposed to touch (4G1A)

Created by FastTest © Copyright FastTest 2022

4th Floor, Mill 3, Pleasley Vale Business Park, Mansfield, Nottinghamshire NG19 8RL

Page 270 of 356

NA/EICR/001

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation				
					L / N	CPC		BS EN Number	Rating (A)				Ring final circuits only (measured end-to-end)	Fig 5.4 & 5.5	All circuits to be completed using R1/R2 or R2, not both R1 + R2			Test voltage V	L/L, L/N, M(Ω)		L/E, N/E, M(Ω)	Above 30mA 50mA 100mA 150mA 200mA 250mA 300mA 350mA 400mA 450mA 500mA 550mA 600mA 650mA 700mA 750mA 800mA 850mA 900mA 950mA 1000mA	30mA or below 50mA 100mA 150mA 200mA 250mA 300mA 350mA 400mA 450mA 500mA 550mA 600mA 650mA 700mA 750mA 800mA 850mA 900mA 950mA 1000mA	
13/L2	Ring Main Common Room	A	E	7	2x2.5	2x1.5	0.4	C	32	10	30	0.54	0.29	0.41	0.16	✓	0.24	26.8	29.7	✓	AFDD (✓)			
14/L2	Hob 1	A	E	2	6	2.5	0.4	C	32	10	30	0.54	N/A	N/A	N/A	✓	0.23	28.7	28.7	✓	N/A			
15/L2	Hob 2	A	E	2	6	2.5	0.4	C	32	10	30	0.54	N/A	N/A	N/A	✓	0.23	29.7	28.7	✓	N/A			
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022 Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022 Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in non-metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing	Manual test button operation
					csa (mm ²)	L / N		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fig 5.4 & 5.5	All circuits to be completed using R1/R2 or R2, not both R1 + R2			
	DB/CL11					CPC												
	Circuit designation																	

TEST RESULTS

Max. Measured Zs (Ω)	Polarity (✓)	Insulation resistance (Record lower reading)	Test voltage	L/L, L/N, M(Ω)	L/E, N/E, M(Ω)	All circuits to be completed using R1/R2 or R2, not both R1 + R2	Ring final circuits only (measured end-to-end)	Fig 5.4 & 5.5	BS 7671 Max. permitted Zs Other 80% (Ω)	Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω	Date(s) live testing	Date(s) dead testing	Details of circuits and/or installed equipment vulnerable to damage when testing	To	To
	(✓)		V				r1 m r2	(✓)						13/07/2022	13/07/2022		13/07/2022	13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/WPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					L / N	CPC		BS EN Number	Rating (A)				Ring final circuits only (measured end-to-end)	Fig 9.8 & 9.9	All circuits to be completed using R1/R2 or R2, not both R1 + R2				Test voltage V	L/L, L/N, M(Ω)		L/E, N/E, M(Ω)
13/L2	Ring Main Common Room	A	E	7	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C 32	10	30	0.54	0.28	0.40	0.16	250	250	0.28	39.7	29.6	✓	AFDD (✓)
14/L2	Hob 1	A	E	2	6	2.5	0.4	61009 RCD/RCBO	C 32	10	30	0.54	N/A	N/A	0.07	250	250	0.25	28.6	29.7	✓	✓
15/L2	Hob 2	A	E	2	6	2.5	0.4	61009 RCD/RCBO	C 32	10	30	0.54	N/A	N/A	0.05	250	250	0.24	29.7	28.7	✓	✓
16/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022 Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022 Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in non-metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω		All circuits to be completed using R1/R2 or R2, not both R1 + R2	Insulation resistance (Record lower reading)			RCD testing	Manual test button operation	
					L / N	CPC		BS EN Number	Type No.				Rating (A)	Test voltage		L/L	L/N	L/E			N/E
	DB/CL17																				
	Circuit designation																				

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To	Signature
		13/07/2022	13/07/2022	13/07/2022	13/07/2022	

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/WPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL/14/3 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 30mA 50mA ms	Manual test button operation RCD AFDD
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi S _g S _a S _b	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance Client UPP Residential Services Ltd	Company Address Kid Glove Road Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode WA3 3GR Branch No.	Scheme No. SA1 8EN Postcode
Distribution board details - Complete in every case Location: Rooftop Plant Room (Schneider) Designation: DB/PL Num. of ways: 24 Num. of phases: 3 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input checked="" type="checkbox"/>			
Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from: Sub Mains (Busbar 1, 25/TP) Overcurrent protective device for the distribution circuit: BS(EN) 88-2 HRC Type: gg Rating: 63 A Voltage: 400 V			
Characteristics at this distribution board Associated RCD (if any): BS (EN) N/A Operating at 1 In: N/A ms Operating at 5 In: N/A ms Z _s : 0.12 Ω No. of poles: N/A I _{pr} : 3.64 kA I _{Δn} : N/A Time delay (if applicable): N/A			
Test instrument serial number(s) Loop impedance: 102118371 Insulation resistance: 102118371 Continuity: 102118371 RCD: 102118371			

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 permitted Z _s Other 80% (Ω)	Circuit impedance Ω				Polarity	Max. Measured	RCD testing	Manual test button operation							
					L / N	CPC		BS EN Number	Type				Rating (A)	Ring final circuits only (measured end-to-end)	Insulation resistance (Record lower reading)	Test voltage					L/L	L/N	L/E	N/E	Test voltage	Z _s	Ω
1/TP	Sub Mains (Mechanical Control Panel)	G	E	1	16	16	5	61009 RCD/RCBO	C	32	30	0.54	N/A	N/A	N/A	0.05	N/A	250	LIM	>299	✓	0.18	29.7	28.6	✓	N/A	
2/L1	EXT Fan 1	A	E	LIM	2.5	2.5	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.40	28.7	28.7	✓	N/A	
2/L2	EXT Fan 2	A	E	LIM	2.5	2.5	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.35	29.7	26.8	✓	N/A	
2/L3	EXT Fan 3	A	E	LIM	2.5	2.5	0.4	61009 RCD/RCBO	C	16	30	1.09	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.33	28.7	29.6	✓	N/A	
3/L1	EXT Fan 4	A	E	LIM	2.5	2.5	0.4	61009 RCD/RCBO	C	16	30	1.09	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.36	28.7	28.5	✓	N/A	
3/L2	EXT Fan 5	A	E	LIM	2.5	2.5	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.23	N/A	250	LIM	>299	✓	0.37	28.6	29.7	✓	N/A	
3/L3	Isolated Circuit	A	E	11	2.5	2.5	0.4	61009 RCD/RCBO	C	16	30	1.09	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	LIM	LIM	LIM	LIM	LIM	✓	N/A
4/L1	EXT Fan 7	A	E	LIM	2.5	2.5	0.4	61009 RCD/RCBO	C	16	30	1.09	N/A	N/A	N/A	0.22	N/A	250	LIM	>299	✓	0.35	28.5	29.5	✓	N/A	
4/L2	EXT Fan 8	A	E	LIM	2.5	2.5	0.4	61009 RCD/RCBO	C	16	30	1.09	N/A	N/A	N/A	0.20	N/A	250	LIM	>299	✓	0.33	29.7	28.6	✓	N/A	
4/L3	Ring Main Plant Room	A	E	4	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	30	0.54	0.15	0.14	0.18	0.07	N/A	250	LIM	>299	✓	0.24	29.7	28.5	✓	N/A	
5/L1	Lighting Plant Room	A	E	7	1.5	1.5	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.25	N/A	250	LIM	>299	✓	0.38	28.7	29.7	✓	N/A	
5/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022 Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022 Signature

Wiring Types: A PVC/PVC; B PVC cables in metallic conduit; C PVC cables in non-metallic conduit; D PVC cables in metallic trunking; E PVC cables in non-metallic trunking; F PVC/SWA cables; G SWA/PVC cables; H Mineral Insulated, MW Metal Work; FM Ferrous Metal; O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4E1A), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS										TEST RESULTS												
Circuit No. and Line No.	Distribution board Designation DB/PL Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					L / N	CPC		BS EN Number	Type No.			Rating (A)	Breaking capacity (kA)	Ring final circuits only (measured end-to-end)	Fi Sg & R1R2 or R2, not both R1 + R2			Test voltage	L/L, L/N, M(Ω)		L/E, N/E, M(Ω)	Above 30mA 50ms
												r1	r2	r1 + r2	V	M(Ω)	M(Ω)	ms	ms	AFDD	RCB	
5/L3	Fan Contactors via Fire Alarm Interface	A	E	9	1.5	1.5	0.4	61009 RCD/RCBO	C	6	10	30	2.91	N/A	N/A	250	LIM	>299	28.7	28.7	✓	✓
6/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
19/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
20/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
21/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
22/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
23/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
24/TP	Surge Protection	A	E	1	16	16	5	61009 RCD/RCBO	C	63	10	30	0.28	N/A	N/A	250	LIM	>299	38.7	28.6	✓	✓

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022

Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022

Signature *Tre Lever*

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/PL Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 50mA 50mA 50mA ms ms ms ms	Manual test button operation RCD (✓) AFDD (✓)
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end) r1 r2	Fig 5.4 & 5.5 R1 + R2 R2	Test voltage V			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		13/07/2022	13/07/2022	13/07/2022	13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL1/1/5 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 50mA 50mA or below 50mA ms	Manual test button operation RCD (✓) AFDD (✓)
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end) r1 r2	Fig 9 & 10 R1 + R2 R2	Test voltage V			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi Zs of R1 & R2	All circuits to be completed using R1R2 or R2, not both R1 + R2			Test voltage	L/L, L/N, M(Ω)	
11/L3	Sub Mains(DB/CL7)	A	E	1	16	16	5	88-2 HRC	gG 63	80	N/A	0.62	N/A	N/A	N/A	0.14	N/A	N/A	N/A	
12/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
13/L1	Sub Mains(DB/CL9)	A	E	1	16	16	5	88-2 HRC	gG 63	80	N/A	0.62	N/A	N/A	N/A	0.16	N/A	N/A	N/A	
13/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
13/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
14/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
15/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
16/L2	Sub Mains(DB/CL11)	A	E	1	16	16	5	88-2 HRC	gG 63	80	N/A	0.62	N/A	N/A	N/A	0.16	N/A	N/A	N/A	
16/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
17/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
18/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
19/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
19/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
19/L3	Sub Mains(DB/CL13)	A	E	1	16	16	5	88-2 HRC	gG 63	80	N/A	0.62	N/A	N/A	N/A	0.16	N/A	N/A	N/A	
20/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
21/L1	Sub Mains(DB/CL15)	A	E	1	16	16	5	88-2 HRC	gG 63	80	N/A	0.62	N/A	N/A	N/A	0.16	N/A	N/A	N/A	
21/L2	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
21/L3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
22/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
23/TP	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
24/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
24/L2	Sub Mains(DB/CL17)	A	E	1	16	16	5	88-2 HRC	gG 63	80	N/A	0.62	N/A	N/A	N/A	0.16	N/A	N/A	N/A	

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022 Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022 Signature

Wiring Types: A PVC/PVC; B PVC cables in metallic conduit; C PVC cables in non-metallic conduit; D PVC cables in metallic trunking; E PVC cables in non-metallic trunking; F PVC/SWA cables; G SWA/XPLE cables; H Mineral Insulated, MW Metal Work; FM Ferrous Metal; O Other

AA1 - Single Core PVC Cables (4D1A), AA2 - Multicore PVC Cables (4D2A), FF1 - Single-core armoured PVC SWA Cables (4D3A), FF2 - PVC SWA Cables (4D4A), AA3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), GG1 - Single-core armoured XLPE cables or 90°C rated (4E3A), GG2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), HH1 - MCC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing	Manual test button operation
					csa (mm ²)	L / N		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi, S, G & R2	All circuits to be completed using R1R2 or R2, not both R1 + R2			
	Busbar 2						CPC											
	Circuit designation																	

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To	Polarity	Max. Measured Zs (Ω)	RCD testing	Manual test button operation
		13/07/2022		13/07/2022		(✓)			

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022

Signature [Signature] Date(s) live testing 13/07/2022 To 13/07/2022

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

AA1 - Single Core PVC Cables (4D1A), AA2 - Multicore PVC Cables (4D2A), FF1 - Single-core armoured PVC SWA Cables (4D3A), FF2 - PVC SWA Cables (4D4A), AA3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL5/1 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA Below 30mA ms	Manual test button operation RCD (✓) (✓)
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi S _g S _a S _b	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Cymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation			
Location Flat 15 Hallway Cupboard (Schneider)	Supply to distribution board is from DB/CL15/7	Sub Mains (DB/CL15, 7L1)	Associated RCD (if any): BS (EN) N/A	Operating at 1 IAn 29.5 ms
Designation DB/CL15/7	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	Type C	No. of poles N/A	Operating at 5 IAn 28.5 ms
Num. of ways 1	Num. of phases 1	Phase sequence confirmed <input checked="" type="checkbox"/>	Zs 0.24 Ω	Time delay (if applicable) N/A
Supply polarity confirmed <input checked="" type="checkbox"/>			Ipr 0.99 kA	

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)	Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)	L/E N/E M(Ω)	Polarity	Max. Measured Zs (Ω)	RCD testing	Manual test button operation		
							Type No.	BS EN Number				Rating (A)	Ring final circuits only (measured end-to-end)	r1	r2							r	Test voltage V
1/L1	Room 7 Sockets	A	E	3	2.5	1.5	CPC	60898 MCB	B	10	6	N/A	0.33	N/A	250	LIM	>299	(✓)	0.57	N/A	N/A	RCD (✓)	AFDD (✓)

TEST RESULTS

Test	Result
Insulation resistance	>299 MΩ
Loop impedance	0.57 Ω
RCD testing	N/A
Manual test button operation	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing To 14/07/2022 **Date(s) dead testing** 14/07/2022 **To** 14/07/2022 **Date(s) live testing** 14/07/2022 **To** 14/07/2022

Tested by: Name (capital letters) TRE LEVER **Position** Electrical Test Engineer **Date** 14/07/2022 **Signature**

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in non-metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MV Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XPLE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XPLE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

Created by FastTest © Copyright FastTest 2022
4th Floor, Mill 3, Pleasley Vale Business Park, Mansfield, Nottinghamshire NG19 8RL
Page 293 of 356
NA/EICR/001

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω		Insulation resistance (Record lower reading)	Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					csa (mm ²)	L / N		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi, S, & R2				Test voltage	L/N		L/E, N/E, M(Ω)
	DB/CL1577						CPC						r1	r2	V	(✓)		ms	ms	RCD (✓)	AFDD (✓)

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL14/6 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 50mA 50mA 50mA ms ms ms ms	Manual test button operation RCD (✓) AFDD (✓)
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi, S, G & R2	All circuits to be completed using R1R2 or R2, not both R1 + R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To	Polarity	Max. Measured Zs (Ω)	RCD testing	Manual test button operation
		14/07/2022		14/07/2022		(✓)			(✓)

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Cymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation	Characteristics at this distribution board		
Location Flat 6 Hallway Cupboard (Schneider)	Supply to distribution board is from DB/CL6/3	Associated RCD(if any): BS (EN) N/A	Above 30mA ms 102118371	Loop impedance
Designation DB/CL6/3	Sub Mains(DB/CL6, 6/L2)	No. of poles N/A	30mA or below ms 102118371	Insulation resistance
Num. of ways 1	Overcurrent protective device for the distribution circuit: BS(EN) 61009 RCD/RCBO	IAn 30	Operating at 5 IAn ms 102118371	Continuity
Supply polarity confirmed <input checked="" type="checkbox"/>	Type C	IAn 30	Operating at 1 IAn ms 102118371	RCD
	Rating 32	Time delay (if applicable) N/A		
	A	Voltage 230		

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)	Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)				Polarity	Max. Measured Zs (Ω)	RCD testing	Manual test button operation				
							Type No.	BS EN Number				Rating (A)	Ring final circuits only (measured end-to-end)	r1	r2	m	n	L/L	L/N					Test voltage V	L/L	L/N	L/E
1/L2	Room 3 Sockets	A	E	3	2.5	1.5	CPC	60898 MCB	B	10	6	N/A	N/A	0.22	N/A	250	LIM	>299	(✓)	0.49	N/A	N/A	N/A	(✓)	(✓)	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022 Signature *Tre Lever*

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XPLE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XPLE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/FFS Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA Below 30mA ms	Manual test button operation
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi S _g S _{sc} S _{oc}	All circuits to be completed using R1R2 or R2, not both R1 + R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		13/07/2022	13/07/2022	13/07/2022	13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022

Signature 

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					CSA (mm ²)	L / N		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fig 5.4 & 5.5	All circuits to be completed using R1R2 or R2, not both R1 + R2			Test voltage	L/L, L/N, M(Ω)		L/E, N/E, M(Ω)
	DB/CL12					CPC															
	Circuit designation																				

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation		
					CSA (mm ²)	L / N		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fig 5.4 & 5.5	All circuits to be completed using R1R2 or R2, not both R1 + R2			Test voltage	L/L, L/N, M(Ω)		L/E, N/E, M(Ω)	Above 30mA 50mA 50ms
	DB/CL12					CPC																
	Circuit designation																					

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022 Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022 Signature *Tre Lever*

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL9/7 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 50mA 100mA 500mA 1000mA ms	Manual test button operation RCD (✓) AFDD (✓)
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end) r1 r2	Fi, S, G & R2	All circuits to be completed using R1R2 or R2, not both R1 + R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Cymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case				
Location Flat 18 Hallway Cupboard (Schneider)	Complete only if the distribution board is not connected directly to the origin of the installation			
Designation DB/CL18/6	Supply to distribution board is from Sub Mains (DB/CL18, 8(L2))	Characteristics at this distribution board		
Num. of ways 1	Overcurrent protective device for the distribution circuit: Type C Rating 32	Associated RCD (if any): BS (EN) N/A	Operating at 1 IΔn 29.7 ms	Loop impedance 102118371
<input checked="" type="checkbox"/> Supply polarity confirmed	<input type="checkbox"/> Phase sequence confirmed	No. of poles N/A	30mA or below 30mA or below	Insulation resistance 102118371
		IΔn 30	Operating at 5 IΔn 29.6 ms	Continuity 102118371
		Time delay (if applicable) N/A		RCD 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)	Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)	L/E N/E M(Ω)	Polarity	Max. Measured Zs (Ω)	RCD testing	Manual test button operation											
							Type No.	BS EN Number				Rating (A)	Ring final circuits only (measured end-to-end)	All circuits to be completed using R1+R2 or R2, not both	Test voltage V							L/L L/N M(Ω)	L/E N/E M(Ω)	Above 30mA or below 5 IΔn ms	30mA or below 5 IΔn ms							
1/L2	Room 6 Sockets	A	E	3	2.5	1.5	CPC	6	10	6	3.49	r1	m	r2	N/A	N/A	N/A	0.30	N/A	250	LIM	>299	(✓)	0.58	N/A	N/A	N/A	(✓)	N/A	(✓)	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022 Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MV Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XPLE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XPLE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL 18/6 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA Below 30mA ms	Manual test button operation
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi S _g S _a S _b	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL/1 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 30mA 50mA ms	Manual test button operation RCD AFDD
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi S _g S _a S _b	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation			
Location Flat 4 Hallway Cupboard (Schneider)	Supply to distribution board is from	Characteristics at this distribution board		
Designation DB/CL4/3	Sub Mains (DB/CL4, 8/L1)	Associated RCD (if any): BS (EN)	Test instrument serial number(s)	
Num. of ways 1	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 230 V	N/A	Loop impedance 102118371	
Supply polarity confirmed <input checked="" type="checkbox"/>		Z _s 0.24 Ω	Insulation resistance 102118371	
Num. of phases 1		I _{pr} 1.02 kA	Continuity 102118371	
Phase sequence confirmed <input type="checkbox"/>			RCD 102118371	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)	Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 permitted Z _s Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)				Polarity	Max. Measured Z _s (Ω)	RCD testing	Manual test button operation				
							Type No.	BS EN Number				Rating (A)	Ring final circuits only (measured end-to-end)	r1	r2	r	Test voltage V	L/L M(Ω)	L/N M(Ω)					L/E N/E M(Ω)	Above 30mA or below 50mA	30mA or below 50mA	Below 30mA
1/L1	Room 3 Sockets	A	E	3	2.5	1.5	CPC	60898 MCB	B	10	6	N/A	N/A	0.21	N/A	250	LIM	>299	(✓)	0.50	N/A	N/A	N/A	(✓)	(✓)	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022 Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in non-metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MV Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XPLE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XPLE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					csa (mm ²)	L / N		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi, S, & R2	All circuits to be completed using R1R2 or R2, not both R1 + R2				Test voltage	L/L, L/N, M(Ω)		L/E, N/E, M(Ω)
	DB/CL4/3 Circuit designation					CPC																

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To	Signature
		14/07/2022		14/07/2022		<i>[Signature]</i>

Tested by: Name (capital letters) **TRE LEVER** Position **Electrical Test Engineer** Date **14/07/2022**

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL7/4 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 30mA 50mA ms	Manual test button operation RCD AFDD
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi S _g S _a S _b	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature 

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CLB/3 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 50mA 50mA 50mA ms ms ms ms	Manual test button operation RCD (✓) AFDD (✓)
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi, S, G & R2	All circuits to be completed using R1R2 or R2, not both R1 + R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022		14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL1/1/ Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 30mA 50mA ms	Manual test button operation	
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi S _g S _a S _b	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2				Test voltage V

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL 18/4 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA Below 30mA ms	Manual test button operation
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi S _g S _{sc} S _{oc}	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance Client UPP Residential Services Ltd	Company Address Kid Glove Road Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea	Postcode WA3 3GR Branch No.	Scheme No. SA1 8EN Postcode
Distribution board details - Complete in every case Location Flat 9 Kitchen (Schneider) Designation DB/CL9 Num. of ways 18 Num. of phases 1 Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed <input type="checkbox"/>			
Complete only if the distribution board is not connected directly to the origin of the installation Supply to distribution board is from Sub Mains (Busbar 2, 13L1) Overcurrent protective device for the distribution circuit: Type gg Rating 63 A Voltage 230 V			
Characteristics at this distribution board Associated RCD (if any): BS (EN) N/A Operating at 1 IΔn N/A ms Above 30mA N/A 30mA or below N/A Z _e 0.16 Ω No. of poles N/A IΔn 1.20 kA IΔn N/A Operating at 5 IΔn N/A ms Time delay (if applicable) N/A			
Test instrument serial number(s) Loop impedance 102118371 Insulation resistance 102118371 Continuity 102118371 RCD 102118371			

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 permitted Z _s Other 80% (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)	L ₁ L ₂ L _N M(Ω)	L ₁ L ₂ L _N M(Ω)	L ₁ L ₂ L _N M(Ω)	Polarity (✓)	Max. Measured Z _s (Ω)	RCD testing Above 30mA or below 5 IΔn ms	Manual test button operation RCD (✓) AFDD (✓)					
					L / N	CPC		BS EN Number	Type No.				Rating (A)	Ring final circuits only (measured end-to-end)	All circuits to be completed using R1+R2 or R2, not both R1+R2	Test voltage V									Test voltage V	Test voltage V			
1/L1	Common Room Lights	A	E	1	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.17	N/A	250	LIM	>299	>299	>299	✓	0.35	28.7	28.5	✓	N/A	
2/L1	Lighting Bedrooms 5,7	A	E	20	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.35	N/A	250	LIM	>299	>299	>299	✓	0.53	29.7	28.6	✓	N/A	
3/L1	Lighting Bedrooms 1,3	A	E	20	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.21	N/A	250	LIM	>299	>299	>299	✓	0.39	29.7	28.6	✓	N/A	
4/L1	Lighting Bedrooms 2,4	A	E	30	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.27	N/A	250	LIM	>299	>299	>299	✓	0.45	28.7	26.8	✓	N/A	
5/L1	Lighting Bedrooms 6,8	A	E	20	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.43	N/A	250	LIM	>299	>299	>299	✓	0.60	28.7	29.7	✓	N/A	
6/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	✓	N/A	
7/L1	Sub Mains (DB/CL9/5, DB/CL9/7)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.19	0.19	0.30	✓	0.13	N/A	250	LIM	>299	>299	>299	✓	0.24	39.7	28.6	✓	N/A
8/L1	Sub Mains (DB/CL9/3, DB/CL9/1)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.32	0.32	0.48	✓	0.20	N/A	250	LIM	>299	>299	>299	✓	0.23	38.7	28.6	✓	N/A
9/L1	Sub Mains (DB/CL9/2, DB/CL9/4)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.38	0.38	0.59	✓	0.25	N/A	250	LIM	>299	>299	>299	✓	0.23	29.6	28.7	✓	N/A
10/L1	Sub Mains (DB/CL9/6, DB/CL9/8)	A	E	6	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.25	0.25	0.43	✓	0.17	N/A	250	LIM	>299	>299	>299	✓	0.23	28.7	29.7	✓	N/A
11/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	✓	N/A	
12/L1	Ring Main Common Room	A	E	4	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	0.44	0.44	0.60	✓	0.25	N/A	250	LIM	>299	>299	>299	✓	0.47	27.6	29.7	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022 Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022 Signature *Tre Lever*

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

AA/1 - Single Core PVC Cables (4D1A), AA/2 - Multicore PVC Cables (4D2A), FF/1 - Single-core armoured PVC SWA Cables (4D3A), FF/2 - PVC SWA Cables (4D4A), AA/3 - PVC Twin & Earth (4D5), OO/1 - LSF single core cables 90°C rated (4E1A), OO/2 - Multi-core LSF cables 90°C rated (4E2A), GG/1 - Single-core armoured XLPE cables or 90°C rated (4E3A), GG/2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), HH/1 - MCCC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL9 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA or below 50mA ms	Manual test button operation
					L / N	CPC		BS EN Number	Type No.				Rating (A)	Test voltage	L/L L/N			

TEST RESULTS

Circuit No. and Line No.	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)	Maximum disconnection	Overcurrent protective devices	Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA or below 50mA ms	Manual test button operation	
										Ring final circuits only (measured end-to-end)	Fig 54 & 55	All circuits to be completed using R1/R2 or R2, not both R1 + R2				Test voltage

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022 Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022 Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/WPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MCCC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation			
Location Rooftop Plant Room (Schneider)	Supply to distribution board is from Sub Mains (DB/PL, 1/TP)	Associated RCD (if any): BS (EN) N/A	Operating at 1 IΔn 29.7 ms	Loop impedance 102118371
Designation Mechanical Control Panel	Overcurrent protective device for the distribution circuit: Type C Rating 32 A Voltage 400 V	BS (EN) 61009 RCD/RCBO	Operating at 5 IΔn 28.6 ms	Insulation resistance 102118371
Num. of ways 6 Num. of phases 3 Phase sequence confirmed <input checked="" type="checkbox"/>				Continuity 102118371
				RCD 102118371

CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm²)	Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)			Polarity	Max. Measured Zs (Ω)	RCD testing	Manual test button operation									
							BS EN Number	Rating (A)				Type	No.	Ring final circuits only (measured end-to-end)	r1	r2	r1+r2					All circuits to be completed using R1/R2 or R2, not both	Test voltage V	L/L M(Ω)	L/N M(Ω)	L/E N/E M(Ω)				
1/L1	LTHW Press Unit	A	B	1	1	0.4	60898 MCB	D	6	N/A	2.91	N/A	N/A	0.03	N/A	250	LIM	>299	>299	>299	✓	0.23	N/A	N/A	N/A	N/A	AFDD	(✓)		
1/L2	Boiler 1	A	B	1	1	0.4	60898 MCB	C	4	N/A	4.37	N/A	N/A	0.04	N/A	250	LIM	>299	>299	>299	✓	0.25	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
1/L3	Boiler 2	A	B	1	1	0.4	60898 MCB	D	4	N/A	4.37	N/A	N/A	0.04	N/A	250	LIM	>299	>299	>299	✓	0.25	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
2/L1	VT Pump 1	A	B	1	1	0.4	60898 MCB	D	4	N/A	4.37	N/A	N/A	0.02	N/A	250	LIM	>299	>299	>299	✓	0.22	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
2/L2	HWS Heater 1	A	B	1	1.5	0.4	60898 MCB	C	10	N/A	1.75	N/A	N/A	0.03	N/A	250	LIM	>299	>299	>299	✓	0.24	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
2/L3	HWS Heater 2	A	B	1	1	0.4	60898 MCB	D	4	N/A	4.37	N/A	N/A	0.05	N/A	250	LIM	>299	>299	>299	✓	0.26	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L1	VT Pump 2	A	B	1	1	0.4	60898 MCB	D	4	N/A	4.37	N/A	N/A	0.01	N/A	250	LIM	>299	>299	>299	✓	0.20	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L2	HWS Sec Pump	A	B	1	1	0.4	60898 MCB	D	2	N/A	8.74	N/A	N/A	0.04	N/A	250	LIM	>299	>299	>299	✓	0.24	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3/L3	MCC Control Panel	G	B	1	16	5	60898 MCB	C	50	N/A	0.35	N/A	N/A	0.03	N/A	250	LIM	>299	>299	>299	✓	0.22	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4/TP	SPARE											N/A	N/A								N/A									
5/TP	SPARE											N/A	N/A								N/A									
6/TP	SPARE											N/A	N/A								N/A									

Details of circuits and/or installed equipment vulnerable to damage when testing 13/07/2022 To 13/07/2022 **Date(s) live testing** 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022 Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic trunking, D PVC cables in non-metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

AA1 - Single Core PVC Cables (4D1A), **AA2** - Multicore PVC Cables (4D2A), **FF1** - Single-core armoured PVC SWA Cables (4D3A), **FF2** - PVC SWA Cables (4D4A), **AA3** - PVC Twin & Earth (4D5), **O1** - LSF single core cables 90°C rated (4E1A), **O102** - Multi-core LSF cables 90°C rated (4E2A), **G1G1** - Single-core armoured XLPE cables or 90°C rated (4E3A), **G1G2** - Multi-core armoured XLPE cables or 90°C rated (4E4A), **H1H1** - MCCC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation Mechanical Control Panel Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 50mA 100mA 500mA 1000mA	Manual test button operation
					L / N	CPC		Type No.	Rating (A)				R1	r2	R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To	Signature
		13/07/2022	13/07/2022	13/07/2022	13/07/2022	<i>[Signature]</i>

Tested by: Name (capital letters) **TRE LEVER** Position **Electrical Test Engineer** Date **13/07/2022**

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Cymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case				
Location Flat 13 Hallway Cupboard (Schneider)	Complete only if the distribution board is not connected directly to the origin of the installation			
Designation DB/CL13/2	Supply to distribution board is from Sub Mains (DB/CL13, 9/L3)	Characteristics at this distribution board		
Num. of ways 1	Overcurrent protective device for the distribution circuit: Type C	Associated RCD (if any): BS (EN) N/A	Operating at 1 IΔn 39.7 ms	Loop impedance 102118371
<input checked="" type="checkbox"/> Supply polarity confirmed	Rating 32 A	No. of poles N/A	30mA or below	Insulation resistance 102118371
	Voltage 230 V	IΔn 30	ms	Continuity 102118371
		Time delay (if applicable) N/A		RCD 102118371

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)	Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 permitted Zs Other (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)	L/E N/E M(Ω)	Max. Measured Zs (Ω)	Polarity	RCD testing	Manual test button operation										
							Type No.	BS EN Number				Rating (A)	Ring final circuits only (measured end-to-end)	All circuits to be completed using R1+R2 or R2, not both	Test voltage V							L/L L/N M(Ω)	L/E N/E M(Ω)	Above 30mA or below 5 IΔn ms	30mA or below 5 IΔn ms						
1/L3	Room 2 Sockets	A	E	3	2.5	1.5	CPC	6	N/A	3.49	80%	r1	m	r2	N/A	N/A	0.19	N/A	250	LIM	>299	0.44	(✓)	✓	N/A	N/A	N/A	RCD	(✓)	AFDD	(✓)

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022 Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in non-metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MV Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XPLE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XPLE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL/1 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 50mA 50mA 50mA ms ms ms ms	Manual test button operation RCD (✓) AFDD (✓)
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end) r1 r2	Fi, S, & R2	All circuits to be completed using R1R2 or R2, not both R1 + R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL 1/6 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 30mA 50mA ms	Manual test button operation RCD AFDD
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi S _g S _a S _b	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL&T Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 50mA 50mA 50mA ms ms ms ms	Manual test button operation RCD (✓) AFDD (✓)
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi, S, G & R2	All circuits to be completed using R1R2 or R2, not both R1 + R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022	14/07/2022	14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CLB/2 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA or below 50mA ms	Manual test button operation
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi S _g S _a S _b	All circuits to be completed using R1R2 or R2, not both R1 + R2 R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022		14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation	
					CSA (mm ²)	L / N		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi, S, & R2	All circuits to be completed using R1R2 or R2, not both R1 + R2				Test voltage	L/L, L/N, M(Ω)		L/E, N/E, M(Ω)
	DB/CL4/7					CPC																
	Circuit designation																					

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022		14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing	Manual test button operation
					csa (mm ²)	L / N		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi, Si & R2	Fi, Si & R2			
	DB/CL6/5						CPC											
	Circuit designation																	

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		14/07/2022		14/07/2022	14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

AA1 - Single Core PVC Cables (4D1A), AA2 - Multicore PVC Cables (4D2A), FF1 - Single-core armoured PVC SWA Cables (4D3A), FF2 - PVC SWA Cables (4D4A), AA3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534



Requirements for Electrical Installations BS 7671:2018 (IET Wiring Regulations 18th Edition)

Company Name PHS Compliance	Company Address Kid Glove Road	Postcode WA3 3GR	Branch No.	Scheme No.
Client UPP Residential Services Ltd	Installation Address Swansea University Bay Campus - Owain 17, Reception - Ground Floor Tower Information Centre, Fabian Way, Crymlyn Burrows, Swansea			Postcode SA1 8EN
Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation			
Location Flat 10 Kitchin (Schneider)	Supply to distribution board is from	Characteristics at this distribution board		
Designation DB/CL10	Sub Mains (Busbar 1, 14/11)	Associated RCD (if any): BS (EN)	Test instrument serial number(s)	
Num. of ways 18	Overcurrent protective device for the distribution circuit: Type: gG Rating: 63 A Voltage: 230 V	N/A	Loop impedance 102118371	
Supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed <input type="checkbox"/>	Z _s 0.16 Ω	Insulation resistance 102118371	
		I _{pr} 1.19 kA	Continuity 102118371	
			RCD 102118371	

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Z _s Other 80% (Ω)	Circuit impedance Ω				Insulation resistance (Record lower reading)	Polarity	Max. Measured	RCD testing	Manual test button operation					
					L / N	CPC		BS EN Number	Type				Rating (A)	Ring final circuits only (measured end-to-end)	r1	r2						r ₁ + r ₂	R2	L/L	L/N	L/E
1/L1	Common Room Lights	A	E	1	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.16	N/A	250	LIM	>299	✓	0.32	28.7	29.6	✓	N/A
2/L1	Lighting Bedrooms 1,2,3	A	E	30	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.29	N/A	250	LIM	>299	✓	0.44	29.7	28.7	✓	N/A
3/L1	Lighting Bedrooms 5,7	A	E	30	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.34	N/A	250	LIM	>299	✓	0.52	29.7	26.8	✓	N/A
4/L1	Lighting Bedrooms 4,6	A	E	30	1.5	1	0.4	61009 RCD/RCBO	C	10	30	1.75	N/A	N/A	N/A	0.43	N/A	250	LIM	>299	✓	0.62	29.7	28.7	✓	N/A
5/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6/L1	Sub Mains (DB/CL10/1, DB/CL10/2, DB/CL10/3)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	✓	0.44	✓	0.18	N/A	250	LIM	>299	✓	0.20	28.7	28.6	✓	N/A
7/L1	Sub Mains (DB/CL10/5, DB/CL10/7)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	✓	0.43	✓	0.16	N/A	250	LIM	>299	✓	0.21	28.7	28.6	✓	N/A
8/L1	Sub Mains (DB/CL10/4, DB/CL10/6)	A	E	9	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	✓	0.42	✓	0.15	N/A	250	LIM	>299	✓	0.22	28.6	28.9	✓	N/A
9/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/L1	Common Room Ring	A	E	4	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	✓	0.51	✓	0.21	N/A	250	LIM	>299	✓	0.39	28.7	29.7	✓	N/A
11/L1	Common Room Ring	A	E	7	2x2.5	2x1.5	0.4	61009 RCD/RCBO	C	32	10	0.54	✓	0.36	✓	0.12	N/A	250	LIM	>299	✓	0.28	28.7	28.7	✓	N/A
12/L1	Hob 1	A	E	2	6	2.5	0.4	61009 RCD/RCBO	C	32	10	0.54	✓	0.13	✓	0.13	N/A	250	LIM	>299	✓	0.30	29.7	28.6	✓	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022

Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER **Position** Electrical Test Engineer **Date** 13/07/2022

Signature *Tre Lever*

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MV Metal Work, FM Ferrous Metal, O Other

AA/1 - Single Core PVC Cables (4D1A), AA/2 - Multicore PVC Cables (4D2A), FF/1 - Single-core armoured PVC SWA Cables (4D3A), FF/2 - PVC SWA Cables (4D4A), AA/3 - PVC Twin & Earth (4D5), OO/1 - LSF single core cables 90°C rated (4E1A), OO/2 - Multi-core LSF cables 90°C rated (4E2A), GG/1 - Single-core armoured XLPE cables or 90°C rated (4E3A), GG/2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), HH/1 - MICCC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS										TEST RESULTS																
Circuit No. and Line No.	Distribution board Designation DB/CL10 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω				Polarity	Max. Measured Zs (Ω)	RCD testing		Manual test button operation					
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end)	Fi	All circuits to be completed using R1/R2 or R2, not both R1 + R2	Test voltage			L/L, L/N, M(Ω)	L/E, N/E, M(Ω)		Above 30mA 30mA 50mA 50mA	30mA or below 50mA 50mA			
								BS EN Number				r1	r2	(✓)		(✓)										
13/L1	Hob 2	A	E	2	6	2.5	0.4	61009 RCD/RCBO	C	32	30	0.54	N/A	N/A	N/A	0.13	N/A	250	LIM	>299	0.31	28.6	29.7	✓	✓	N/A
14/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18/L1	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 13/07/2022 To 13/07/2022 Date(s) live testing 13/07/2022 To 13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022 Signature

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in non-metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other
 A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MIICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL10 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors csa (mm ²)		Maximum disconnection	Overcurrent protective devices		Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 50mA 50mA 50mA ms ms ms ms	Manual test button operation RCD (✓) AFDD (✓)
					L / N	CPC		Type No.	Rating (A)				Ring final circuits only (measured end-to-end) r1 r2	Fi, S, & R2	All circuits to be completed using R1R2 or R2, not both R1 + R2			

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	To	Date(s) live testing	To
		13/07/2022	13/07/2022	13/07/2022	13/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 13/07/2022

Signature [Signature]

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)

ELECTRICAL INSTALLATION CONDITION REPORT - Schedule of Tests

FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



CIRCUIT DETAILS

Circuit No. and Line No.	Distribution board Designation DB/CL7/3 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 50mA 100mA 500mA 1000mA 5000mA	Manual test button operation
					L / N	CPC		Type No.	Rating (A)				BS EN Number	Test voltage	L/L			

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation DB/CL7/3 Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices		Breaking capacity (KA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80% (Ω)	Circuit impedance Ω			Insulation resistance (Record lower reading)	RCD testing Above 30mA 50mA 100mA 500mA 1000mA 5000mA	Manual test button operation
					L / N	CPC		Type No.	Rating (A)				BS EN Number	Test voltage	L/L			

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 14/07/2022 To 14/07/2022 Date(s) live testing 14/07/2022 To 14/07/2022

Tested by: Name (capital letters) TRE LEVER Position Electrical Test Engineer Date 14/07/2022 Signature *Tre Lever*

Wiring Types: A PVC/PVC, B PVC cables in metallic conduit, C PVC cables in non-metallic conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

A/A1 - Single Core PVC Cables (4D1A), A/A2 - Multicore PVC Cables (4D2A), F/F1 - Single-core armoured PVC SWA Cables (4D3A), F/F2 - PVC SWA Cables (4D4A), A/A3 - PVC Twin & Earth (4D5), O/O1 - LSF single core cables 90°C rated (4E1A), O/O2 - Multi-core LSF cables 90°C rated (4E2A), G/G1 - Single-core armoured XLPE cables or 90°C rated (4E3A), G/G2 - Multi-core armoured XLPE cables or 90°C rated (4E4A), H/H1 - MICC exposed to touch (4G1A)



Generic Continuation

General Conditions of the Electrical Installation:

Wiring Systems.

The wiring systems utilized for final circuit wiring in the installation are (A) PVC T&E Cables and (G) SWA Cables.

Installation methods used are (E) Run on Tray.

The final circuits are protected by 60898 MCB's with 61009 RCD Protection.

The Main Gas Supply Enters the in the Entrance Lobby Shut off Hatch and is Bonded with a 50mm Earthing Cable with Warning Labels Attached.

The Main water enters the property in the Plant room and is Bonded with a 50mm Earthing Cable with Warning Labels Attached.

Observation notes

All information and documentation (where available) were used to help compile this report.

Circuit charts should be present for each Distribution Board providing relevant information in accordance with Regulation 514.9.1 of the BS 7671:2018.

On the distribution board schedules of circuit details cable types and sizes have been typed in as what is visible at the distribution board only. Circuits may have been jointed with a different cable type further along the circuit Only a percentage of the installation has been dismantled for inspection purposes. The correct connection of every conductor and link throughout the premises cannot be ensured.

Additional Comments

No access to sealed supply authority fuses therefore Characteristics of Primary Supply Protective Devices are not filled in on page 2

A new regulation 421.1.7 has been introduced recommending the installation of Arc Fault detection devices conforming to BS EN 62606 to mitigate the risk of fire in AC final circuits of a fixed installation due to arc fault currents.

This installation has been designed and installed prior to July 2018. There is no evidence of overvoltage protection within the electrical installation, we recommend Surge Protective Devices be installed in order to reduce the risk of damage to the installation by external transient overvoltage's or switching.

Overall Assessment

In general, the installation is a Un Satisfactory overall condition with the C2/FI Observations requiring Urgent Attention.

It is recommended a maximum 5-year period for the next inspection and test to be carried out.

Abbreviations contained in this Report: -

RHS – Right Hand Side

LHS – Left Hand Side

BOH – Back Of House.

D/B - Distribution board.

RCD - Residual current device.

CPC - Circuit protective conductor.

FCU – Fused Connection Unit.

CSA - Cross Sectional Area.

MET – Main Earthing Terminal.

LIM – Limitation (Agreed or Operational)

MIC – Sheath of MICC cable used as CPC

SWA – Steel Wire Armouring used as CPC

MW – Metalwork used as CPC.

FP – FP200 Fire Resistant Cable.

GF – Ground Floor

1F – First Floor

2F – Second Floor

3F – Third Floor

4F – Fourth Floor

Remarks:

DB/FFS Remarks:

2/L1 - Fire Alarm Panel: FP200 Cable

2/L2 - Refuge Alarm Panel: FP200 Cable

3/L1 - AOV Ground Floor: FP200 Cable

3/L2 - AOV 1st Floor: FP200 Cable

3/L3 - AOV 2nd Floor: FP200 Cable

4/L1 - AOV 3rd Floor: FP200 Cable

4/L2 - AOV 4th Floor: FP200 Cable

4/L3 - AOV 5th Floor: FP200 Cable

5/L1 - AOV 6th Floor: FP200 Cable

5/L2 - AOV 7th Floor: FP200 Cable

5/L3 - AOV 8th Floor: FP200 Cable

6/L1 - AOV Plantroom: FP200 Cable

7/L1 - Lighting Ground Floor: FP200 Cable

7/L2 - Lighting 1st Floor: FP200 Cable

ELECTRICAL INSTALLATION CONDITION REPORT


FT/EICR 11010534

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)



7/L3 - Lighting 2nd Floor: FP200 Cable
8/L1 - Lighting 3rd Floor: FP200 Cable
8/L2 - Lighting 4th Floor: FP200 Cable
8/L3 - Lighting 5th Floor: FP200 Cable
9/L1 - Lighting 6th Floor: FP200 Cable
9/L2 - Lighting 7th Floor: FP200 Cable
9/L3 - Lighting 8th Floor: FP200 Cable
10/L1 - Lighting Plant Room: FP200 Cable

Owain DB CL 13





New locking catch fitted by site team.

Owain DB Mechanical Control Panel



pected and
obtained, as
IEE Wiring
ished by the

-127.

Compliance ✓












All screws replaced / re-fitted by site team.

Owain DB CL 2





Blanks inserted by site team.